



Legend

- Practical limit of Fire Flow delivery
- ▨ Area of deficient Fire Flow capacity
- Public Gathering & Services Facility (with Facility ID Number - see Table)
- Existing Pipeline
- Major roads
- Minor Roads

Minimum Fire Flow Service Criteria

- 3,500 gpm
- 2,500 gpm
- 2,000 gpm
- 1,000 gpm
- 0 gpm - Parks
- 0 gpm - Village of Maple Bluff
- 0 gpm - Village of Shorewood Hills
- Water body

N
W — E
S

0 1 2 3 Miles

File: C:\PROJECTS\Madison_W_87269_411102_GIS\ProjectFiles\FireFlow\FireFlowScenarios\FireFlow_Scenario_Summer.mxd
Version: 1
By: DW
Date: Nov 17, 2008

1:35,000

Figure 5-8 - Fire Flow Analysis
 Madison Water Utility Planning Area
 Water Master Plan Update
 B&V PN 138101.3120

Madison Water Utility  BLACK & VEATCH  Building a world of difference