


Item 2

Water Quality Monitoring Report

2007 Monitoring Schedule



Monthly Report for: Aug-07

Analyte Group	Sample Locations	Monitoring Requirements (# of Samples)		Monitoring Activity (# of samples)		Violations & Public Notices
		Monthly	2007 Annual Requirement	Current Month	Year to Date 2007	Year to Date
Coliform Bacteria	Operating Wells and Distribution Sites	120	1500	383	2557	0
Free Chlorine Residual "Grab" Samples	Operating Wells and Distribution Sites	160 (1)	1900 (1)	794	4793	0
Fluoride	Operating Wells	450 (1)	5400 (1)	576	3258	0
Inorganic Contaminants (28 analytes) (2)	Wells	na	23	1	21	0
Disinfection/Disinfection Byproducts Total Trihalomethanes (TTHMs) Haloacetic Acids (HAA5s)	Distribution System Entry Points	na	7	0	0	0
<u>Annual</u> Volatile Organic Compounds (VOC) (41 analytes) (2)	Wells	na	6	0	14	0
<u>Quarterly</u> Volatile Organic Compounds (VOC) (41 analytes)	Wells	Per Quarter 6 (1)	24	0	9	0
Manganese Tap Samples	Citywide	na	na	0	30	na

- (1) Sampling requirement will vary depending on the number of wells in operation during specific days or quarters
- (2) Sampling is usually completed June to September in each calendar year, with results reported in the month following sampling.

Item 2

Calls logged to the Water Quality Correspondence Database - 2007

Update: 8/13/07

Month	All Calls	Color	Manganese	Pressure	Taste	Odor	No Water	Other
January	47	12	4	3	2	3	1	27
February	58	21	3	5	1	4	6	22
March	59	14	4	6	3	4	9	27
April	70	14	2	4	7	5	1	42
May	79	32	1	2	3	12	4	29
June	109	73	0	3	9	9	2	20
July	75	25	0	7	8	11	5	23

Month	All Calls	Color	Manganese	Pressure	Taste	Odor	No Water	Other	Alder District
7	5	1	0	0	0	0	0	4	None
7	3	0	0	2	0	0	0	1	01
7	2	2	0	0	0	0	0	0	02
7	4	2	0	0	0	0	0	2	03
7	2	0	0	0	1	0	1	0	04
7	2	0	0	0	0	0	0	2	05
7	17	10	0	0	2	6	0	2	06
7	2	1	0	0	0	1	0	0	09
7	9	4	0	0	1	1	0	3	10
7	4	1	0	0	2	0	0	1	11
7	4	1	0	0	1	1	0	2	12
7	2	0	0	0	0	0	0	2	13
7	2	1	0	0	1	0	0	0	14
7	3	0	0	0	0	2	0	1	16
7	7	1	0	1	0	0	4	1	17
7	1	1	0	0	0	0	0	0	18
7	5	0	0	4	0	0	0	1	19
7	1	0	0	0	0	0	0	1	20

Month	All Calls	Color	Manganese	Pressure	Taste	Odor	No Water	Other	Alder District
6	6	2	0	0	0	0	0	4	None
6	1	1	0	0	0	0	0	0	01
6	2	1	0	0	1	1	0	0	02
6	1	0	0	0	0	0	0	1	03
6	3	2	0	0	0	0	0	1	04
6	13	10	0	1	1	2	0	1	06
6	2	0	0	0	1	1	0	1	07
6	9	7	0	0	0	0	0	2	10
6	3	0	0	0	2	0	0	1	11
6	12	11	0	0	0	0	0	1	12
6	8	7	0	0	0	0	0	1	13
6	3	2	0	0	0	1	0	0	15
6	2	0	0	0	0	0	1	1	16
6	5	1	0	0	2	1	0	2	17
6	33	28	0	2	0	2	1	2	18
6	3	0	0	0	2	0	0	1	19
6	3	1	0	0	0	1	0	1	20