



Department of Planning & Development
Planning Unit

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266 4747
FAX 608 266-8739
PH 608 266-4635

September 20, 2005

Paul Terranova
Wexford Ridge Neighborhood Center, Inc.
7011 Flower Lane Apt. A/C
Madison, WI 53717

SUBJECT: 55 South Gammon Road

Dear Mr. Terranova:

The Plan Commission, at its September 19, 2005 meeting, determined that the ordinance standards could be met subject to the conditions below for a conditional use for a community center/neighborhood center to be located at 55 South Gammon Road. The Plan Commission also recommended approval of a zoning map amendment from Agriculture to R4 for this site. The Plan Commission approval of the conditional use for the center is contingent on the Common Council approval of the zoning map amendment. The Common Council will consider this matter at their October 11, 2005 meeting. If the Common Council alters these conditions of approval, or adds conditions of approval, I will send a second letter with that information.

In order to receive final approval of your proposal, the following conditions must be met:

Please contact John Leach in the Office of the City Traffic Engineer if you have questions regarding the following three items:

1. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
2. The developer shall post a deposit or reimburse the City for all costs associated with any modifications to Street Lighting, Signing and Pavement Marking including labor and materials for both temporary and permanent installations.
3. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact Gary Dallmann in the Office of the City Engineer if you have questions regarding the following nine items:

4. Although parking lot improvements are being permitted over the existing public storm sewer easement and facilities in the northeast corner of this site, make it be known that these parking lot improvements are at risk to non-compensable damage in the event the City has to perform any repairs, maintenance and/or reconstruction to the public storm sewer within the right of the existing easement of record.
5. Each lot shall have its own sanitary sewer lateral.
6. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5 tons per acre per year.
7. This site is greater than one (1) acre, and the Developer is required by State Statute to obtain a Notice of Intent Permit (NOI) from the Wisconsin Department of Natural Resources. Contact Jim Bertolacini of the WDNR at (608) 275-3201 to discuss this requirement.
8. If the lots within this certified survey map are inter-dependent upon one another for stormwater conveyance, and/or a private drainage system exists for the entire site, an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the certified survey map and recorded at the Dane County Register of Deeds.
9. Prior to recording, this plat shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Contact Greg Fries at 267-1199 to discuss this requirement.
10. The applicant shall submit, prior to plan sign-off, digital CAD files to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital copies shall be to scale and represent final construction.

CAD submittals can be either AutoCAD (dwg), MicroStation(dgn) or Universal (dxf) formats and contain the following data, each on a separate layer name/level number:

- a. Building Footprints
- b. Internal Walkway Areas
- c. Internal Site Parking Areas
- d. Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)

Note: Email file transmissions preferred: lzenchenko@cityofmadison.com

11. All outstanding Madison Metropolitan Sewerage District (MMSD) sanitary sewer connection charges are due and payable prior to connection to the public sewerage system.
12. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size and alignment of the proposed service.

Please contact Kathy Voeck, Assistant Zoning Administrator at 266-5978, if you have questions regarding the following five items:

13. Obtain approval of a 5-stall parking reduction.
14. Provide one 10' x 35' loading area with 14' vertical clearance to be shown on the plan. The loading area shall be exclusive of drive aisle and maneuvering space.
15. Show the number of bike parking stalls provided on the final plan. Note: The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: Bike stalls shall be a minimum dimension of 6' x 2' with a 5' access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.
16. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. Note: The required trees do not count toward the landscape point total. Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs.
17. Lighting is not required. However, if it is provided, it must comply with City of Madison outdoor lighting standards (see parking lot packet). Lighting will be limited to .08 watts per square foot.

Please contact John Lippitt, Madison Fire Department at 266-4484, if you have questions regarding the following item:

18. All portions of the exterior walls of newly constructed buildings and places of employment and open storage of combustible materials shall be within 500 feet of at least TWO fire hydrants. Distances are measured along the path traveled by the fire truck as the hose lays off the truck. See MGO 34.20 for additional information.
19. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a. The site plans shall clearly identify the location of all fire lanes.
 - b. Per IFC 503.3 show approved "fire lane, no parking" signs posted on the site plan. A maximum of 150-feet on center. Signs must be visual and easily read from any location on the fire lane. Fire lanes 20-27 feet wide will be posted as fire lane on both sides; 28-35 feet wide shall be posted fire lane on the appropriate side only.
 - c. Provide a completed MFD "Fire Apparatus Access and Fire Hydrant Worksheet" with the site plan submittal.

Approval of this proposal does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816. The trees shown in the street rights-of-way shall not be shown on the sign-off plan or construction plans

unless they have previously been approved by the City Forester. If these are existing trees or species and locations that have been approved by the Forester, they shall be so labeled on plans.

Please follow the procedures listed below to receive your conditional use approval.

1. Please revise plans per the above conditions and submit twelve (12) sets of the final site plans (including drainage and landscaping plans) to the Zoning Administrator. The final plans are reviewed and approved by Traffic Engineering, Fire Department, City Engineering, and Zoning. Any of these agencies may call you to request additional information or to resolve problems.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting cover sheet approval.
3. No alteration of this proposal shall be permitted unless approved by the City Plan Commission provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of Plan Commission approval unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the date of issuance of the building permit. See Section 28.12(11)(h)(3), Madison General Ordinances. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against this approved conditional use.

IF YOU HAVE ANY QUESTIONS REGARDING OBTAINING YOUR BUILDING PERMIT OR OCCUPANCY PERMIT, PLEASE CALL KATHY VOECK OF THE CITY ZONING STAFF AT 266-4551.

Sincerely,

I hereby acknowledge that I understand and will comply with the above conditions of approval for this conditional use.

Bill Roberts
Planning & Development

Applicant

cc: Zoning Administrator
City Engineering
Traffic Engineering
Madison Metropolitan School District, 545 W. Dayton St., Madison, WI 53703
Kee Architects, Inc., 621 Williamson St., Madison, WI 53703
Michael Christopher, DeWitt Ross & Stevens, 2 E. Mifflin St., Ste. 600, Madison, WI 53703

Zoning City Engineering Traffic Engineering Fire Dept.
