

PLANNING UNIT REPORT
DEPARTMENT OF PLANNING AND DEVELOPMENT
May 16, 2005

RE: I.D. #01005, Zoning Map Amendment I.D. 3097, to rezone 1802 Maplecrest Drive from R1 to R4

1. Requested Action: Approval of a request to rezone a 0.58-acre parcel located at 1802 Maplecrest Drive from R1 (Single-Family Residence District) to R4 (General Residence District).
2. Applicable Regulations: Section 28.12 (9) provides the process for zoning map amendments.
3. Report Drafted By: Timothy M. Parks, Planner

GENERAL INFORMATION

1. Applicant & Property Owner: Jeff Haen, JAKS Investment, LLC/ Hawks Landing, LLC; 322 Junction Road; Madison, Wisconsin 53717.

Agent: Dave Andruczyk, Arnold & O'Sheridan, Inc.; 1111 Deming Way; Madison, Wisconsin 53717.
2. Development Schedule: The applicant wishes to proceed with the planned residential development (see below) as soon as all necessary approvals have been granted, with occupancy in Summer 2005.
3. Location: Approximately 0.58 acres located at 1802 Maplecrest Drive; Aldermanic District 1; Madison Metropolitan School District.
4. Existing Conditions: Golf course edge and undeveloped land, zoned R4 (General Residence District).
5. Proposed Land Use: The property to be rezoned will be joined to 13.4 acres of land at 1802 Maplecrest Drive to be developed with 114 condominium units in 19 buildings.
6. Surrounding Land Use and Zoning: Land to the east of the site is being developed with single-family residences in the Hawk's Landing subdivision, zoned R1 (Single-family Residence District). Land to the north, south and west is developed with the Hawk's Landing golf course. Various condominium buildings, a bathhouse, pool and club recreational facilities are located further to the west across a course fairway.
7. Adopted Land Use Plan: The Mid-Town Road Amendment to the High Point-Raymond Neighborhood Development Plan recommends that is area for low to medium density residential uses.

Item #01005
1802 Maplecrest Drive
May 16, 2005
Page 2

8. Environmental Corridor Status: The subject site is not located in a mapped environmental corridor.
9. Public Utilities & Services: The property is served by a full range of urban services.

STANDARDS FOR REVIEW

This application is subject to the standards for zoning map amendments.

PREVIOUS CASE

On February 21, 2005, the Plan Commission approved a conditional use for a planned residential development on 13.4 acres of land zoned R4 located at 1802 Maplecrest Drive. The planned residential development proposes 114 condominium units to be constructed in 19 buildings.

ANALYSIS, EVALUATION AND CONCLUSION

The applicant is requesting approval of a zoning map amendment to rezone two small pieces of land totaling 0.58 acres in area from R1 to R4. The pieces of land to be rezoned are located along the western and southern edges of the 13.4-acre parcel (Lot 53, Hawks Landing Golf Club) that was previously approved for 19 multi-family buildings containing a total of 114 condominium units developed as a planned residential development. The 0.58 acres to be rezoned are currently part of one of the golf course fairways and are being added to provide additional setbacks for the multi-family development. The plans for the original project have not changed and no building development will occur on the properties to be rezoned.

The Planning Unit believes that the proposed rezoning aides in the implementation of the approved planned residential development, which the Plan Commission found to be in keeping with the overall development plan for Hawks Landing and the goals of the Midtown Road NDP.

RECOMMENDATION

The Planning Unit recommends that the Plan Commission forward Zoning Map Amendment I.D. 3097, rezoning 0.58 acres of undeveloped land located at 1802 Maplecrest Drive from R1 to R4, to the Common Council with a recommendation of **approval** subject to input at the public hearing and comments from reviewing agencies.



Department of Public Works
City Engineering Division

608 266 4751

Larry D. Nelson, P.E.
City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
608 264 9275 FAX
608 267 8677 TDD

Deputy City Engineer
Robert F. Phillips, P.E.

Principal Engineers
Michael R. Dailey, P.E.
Christina M. Bachmann, P.E.
John S. Fahrney, P.E.
David L. Benzschawel, P.E.
Gregory T. Fries, P.E.

Operations Supervisor
Kathleen M. Cryan

Hydrogeologist
Joseph L. DeMorett, P.G.

GIS Manager
David A. Davis, R.L.S.

DATE: May 3, 2005
TO: Plan Commission
FROM: Larry D. Nelson, P.E., City Engineer
SUBJECT: 1802 Maplecrest Drive Rezoning

The City Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. Necessary land interest dedications, either in fee simple or easement, require applicant to obtain and submit a legal description and scale map of the dedication area prepared and stamped by a Registered Land Surveyor. Submit the map, description and \$500 City Real Estate processing fee to City Engineering (Eric Pederson) for review and processing with City Real Estate Staff.
2. 4 Private street names will be needed and private street signage required per MGO. Clearly identify "Private" streets on plan when named.
3. Stormwater management for this site includes thermal control and infiltration. The applicant shall provide calculations showing compliance with Chapter 37 MGO.
4. The site grading plan does not incorporate all rain gardens shown on the overall site plan.
5. Prior to approval, owner shall pay stormwater connection charges for the Upper Badger Mill Creek Impact Fee District.
6. If sanitary sewer and water mains are intended to be public, applicant shall enter into a City/Developer agreement. Both utilities shall be designated public or private. One designated public while one is designated as private will not be allowed. If public, easements shall be required.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

Engineering Division Review of Planned Community Developments, Planned Unit Developments
and Conditional Use Applications.

5

Name: 1802 Maplecrest Drive Rezoning

General



- 1.1 The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
- 1.2 The site plan shall identify lot and block numbers of recorded Certified Survey Map or Plat.
- 1.3 The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing and proposed utility locations and landscaping.
- 1.4 The site plan shall identify the difference between existing and proposed impervious areas.
- 1.5 The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
- 1.6 The site plan shall include a full and complete legal description of the site or property being subjected to this application.

Right of Way / Easements

- 2.1 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.2 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.3 The Applicant shall Dedicate a Permanent Limited Easement for grading and sloping _____ feet wide along _____.
- 2.4 The City Engineer has reviewed the need for pedestrian and bicycle connections through the development and finds that no connections are required.
- 2.5 The Applicant shall Dedicate a Permanent Limited Easement for a pedestrian / bicycle easement _____ feet wide from _____ to _____.
- 2.6 The Developer shall provide a private easement for public pedestrian and bicycle use through the property running from _____ to _____.
- 2.7 The developer shall be responsible for the ongoing construction and maintenance of a path within the easement. The maintenance responsibilities shall include, but not be limited to, paving, repaving, repairing, marking and plowing. The developer shall work with the City of Madison Real Estate Staff to administer this easement. Applicable fees shall apply.

Streets and Sidewalks

- 3.1 The Applicant shall execute a waiver of notice and hearing on the assessments for the improvement of [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.2 **Value of sidewalk installation over \$5000.** The Applicant shall Construct Sidewalk to a plan approved by the City Engineer along _____.
- 3.3 **Value of sidewalk installation under \$5000.** The Applicant shall install public sidewalk along _____. The Applicant shall obtain a Street Excavation Permit for the sidewalk work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. All work must be completed within six months or the succeeding June 1, whichever is later.
- 3.4 The Applicant shall execute a waiver of their right to notice and hearings on the assessments for the installation of sidewalk along [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.5 The Applicant shall grade the property line along _____ to a grade established by the City Engineer. The grading shall be suitable to allow the installation of sidewalk in the future without the need to grade beyond the property line. The Applicant shall obtain a Street Excavation permit prior to the City Engineer signing off on this development.
- 3.6 The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
- 3.7 **Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation.** The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees.

5

- 3.8 The Applicant shall make improvements to _____ in order to facilitate ingress and egress to the development. The improvement shall include a (Describe what the work involves or strike this part of the comment.) _____
- 3.9 The Applicant shall make improvements to _____. The improvements shall consist of _____
- 3.10 The approval of this Conditional Use does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
- 3.11 The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
- 3.12 The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
- 3.13 The Applicant shall obtain a privilege in streets agreement for any encroachments inside the public right of way. The approval of this development does not constitute or guarantee approval of the encroachments.
- 3.14 The Applicant shall provide the City Engineer with the proposed soil retention system to accommodate the restoration. The soil retention system must be stamped by a Professional Engineer. The City Engineer may reject or require modifications to the retention system.
- 3.15 The Applicant shall complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate shall be approved by the City. The Construction Engineer shall be notified prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced.
- 3.16 All work in the public right-of-way shall be performed by a City licensed contractor.

Storm Water Management

- 4.1 The site plans shall be revised to show the location of all rain gutter down spout discharges.
- 4.2 Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public storm sewer.
- 4.3 The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
- 4.5 The applicant shall show storm water "overflow" paths that will safely route runoff when the storm sewer is at capacity.
- 4.6 The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
- 4.7 This site is greater than one (1) acre and the applicant is required by State Statute to obtain a Notice of Intent Permit (NOI) from the Wisconsin Department of Natural Resources. Contact Jim Bertolacini of the WDNR at 275-3201 to discuss this requirement.
- 4.8 This development includes multiple building permits within a single lot. The City Engineer and/or the Director of the Inspection Unit may require individual control plans and measures for each building.
- 4.9 If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds.
- 4.10 Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Please contact Greg Fries at 267-1199 to discuss this requirement.
- 4.11 The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
- 4.12 A portion of this project comes under the jurisdiction of the US Army Corp of Engineers and WDNR for wetland or flood plain issues. A permit for those matters shall be required prior to construction on any of the lots currently within the jurisdictional flood plain.

5

- 4.13 The Applicant shall submit, prior to plan sign-off, digital CAD files to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital copies shall be to scale and represent final construction.

CAD submittals can be either AutoCAD (dwg), MicroStation (dgn) or Universal (dxf) formats and contain the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com . Include the site address in this transmittal.

- 4.14 NR-151 of the Wisconsin Administrative Code will be effective on October 1, 2004. Future phases of this project shall comply with NR 151 in effect when work commences. Specifically, any phases not covered by a Notice of Intent (NOI) received from the WDNR under NR-216 prior to October 1, 2004 shall be responsible for compliance with all requirements of NR-151 Subchapter III. As most of the requirements of NR-151 are currently implemented in Chapter 37 of the Madison General Ordinances, the most significant additional requirement shall be that of infiltration.

NR-151 requires infiltration in accord with the following criteria. For the type of development, the site shall comply with one of the three (3) options provided below:

Residential developments shall infiltrate 90% of the predevelopment infiltration amount, 25% of the runoff from the 2-year post development storm or dedicated a maximum of 1% of the site area to active infiltration practices.

Commercial development shall infiltrate 60% of the predevelopment infiltration amount, 10% of the runoff from the 2-year post development storm or dedicate a maximum of 2% of the site area to active infiltration practices.

Utilities General

- 5.1 The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit.
- 5.2 The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work.
- 5.3 All proposed and existing utilities including gas, electric, phone, steam, chilled water, etc shall be shown on the plan.
- 5.4 The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction.
- 5.5 The site plans shall be revised to show the location of existing utilities, including depth, type, and size in the adjacent right-of-way.
- 5.6 The developer shall provide information on how the Department of Commerce's requirements regarding treatment of storm water runoff, from parking structures, shall satisfied prior to discharge to the public sewer system. Additionally, information shall be provided on which system (storm or sanitary) the pipe shall be connected to.

Sanitary Sewer

- 6.1 Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner.
- 6.2 All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior to connection to the public sewerage system.
- 6.3 Each unit of a duplex building shall be served by a separate and independent sanitary sewer lateral.
- 6.4 The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size and alignment of the proposed service.



Department of Planning & Development
 Planning/Inspection/Real Estate/Community & Economic Development
 Mark A. Olinger, Director

Bradley J. Murphy
 Planning Unit
 215 Martin Luther King, Jr. Boulevard
 P.O. Box 2985
 Madison, WI 53701-2985
 (608) 266-4635

REVIEW REQUEST FOR:

- PRELIMINARY
- FINAL PLAT
- LOT DIVISION
- CONDITIONAL USE
- REZONING
- INCLUSIONARY ZONING.
- OTHER: _____

1802 MAPLECREST DRIVE
 RZ: R1 → R4
 ADJUSTMENT TO CORRECT LEGAL DESCRIPTION & ZONING LINE
 JEFF HAEN - JAKS INVESTMENT (HAWKS LANDING)
 DAVE ANDRUCZYK - ARNOLD & OSHEIDAN

9

PLANNING UNIT CONTACT: TIM PARKS

RETURN COMMENTS BY: 06 MAY 2005

PLEASE ALSO EMAIL OR FAX ANY COMMENTS TO THE APPLICANT:

Applicant E-mail: dandruczyk@arnoldosheidan.com Fax: 821-8501

Date Submitted: 21 MARCH 2005 Plan Commission: 16 MAY 2005

Date Circulated: 29 MARCH 2005 Common Council: 07 APRIL 2005

CIRCULATED TO:

- | | | |
|--------------------------------------------------|-------------------------------------------------------|------------------------------------------------------------------------|
| <input type="checkbox"/> ZONING | <input type="checkbox"/> DISABILITY RIGHTS - SCHAEFER | <input checked="" type="checkbox"/> ALD. <u>FERRELL</u> DIST. <u>1</u> |
| <input type="checkbox"/> FIRE DEPARTMENT | <input type="checkbox"/> POLICE DEPT. - THURBER | <input type="checkbox"/> MADISON GAS & ELECTRIC |
| <input type="checkbox"/> PARKS DIVISION | <input type="checkbox"/> CITY ASSESSOR - SEIFERT | <input type="checkbox"/> ALLIANT ENERGY |
| <input type="checkbox"/> TRAFFIC ENGINEERING | <input type="checkbox"/> MADISON METRO - SOBOTA | <input type="checkbox"/> SBC |
| <input type="checkbox"/> CITY ENGINEERING | <input type="checkbox"/> BOARD OF EDUCATION C/O SUPT. | <input type="checkbox"/> MID PLAINS TELE |
| <input type="checkbox"/> WATER UTILITY | <input type="checkbox"/> PUBLIC HEALTH - K. VEDDER | <input type="checkbox"/> MT. VERNON TELE |
| <input type="checkbox"/> CDBG - HURIE | <input type="checkbox"/> NEIGHBORHOOD ORGANIZATION | _____ |
| <input type="checkbox"/> REAL ESTATE - D. WARREN | | _____ |

- Review the above as per time schedule set in Chapter 16.23(5)(b)2; 16.23(5)(3)3; or Chapter 28, City of Madison Ordinance; OR your agency's comments cannot be considered prior to action.
- One copy for your files; one copy for file of appropriate telephone company; PLEASE RETURN one copy with joint comments.
- The above is located in your district. A copy is on file in the Planning & Development Office for review. If you have any questions or comments, contact our office at 266-4635.
- The above is located within or near the limits of your neighborhood organization. A copy is on file in the Planning & Development Office for review. If you have any questions or comments, contact our office at 266-4635.
- A resolution will be before the Common Council within a few weeks regarding this matter.

RETURN COMMENT TO: PLANNING UNIT, DEPARTMENT OF PLANNING & DEVELOPMENT

NO COMMENTS / YOUR COMMENTS:

No Preliminary Comments

[Signature]