



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

November 28, 2011

Douglas Pahl
Aro Eberle Architects
116 King Street, Suite 202
Madison, Wisconsin 53703

RE: Approval of a demolition permit and conditional use to allow a former convenience store to be demolished and a new gas station, car wash, and convenience store with restaurant tenant space to be constructed at 1101 N. Sherman Avenue (Farooq Shahzad).

Dear Mr. Pahl;

At its November 21, 2011 meeting, the Plan Commission found the standards met and **approved** your client's demolition permit and conditional use for a new gas station, car wash, and convenience store at 1101 N. Sherman Avenue. In order to receive final approval of the demolition permit and conditional use and for demolition or building permits to be issued, the following conditions shall be met:

Please contact Janet Dailey of the City Engineering Division at 261-9688 if you have questions regarding the following nine (9) items:

1. Any damage to the pavement shall be restored in accordance with the City's pavement patching criteria.
2. The applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
3. All work in the public right of way shall be performed by a City-licensed contractor.
4. The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
5. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to: control 40% TSS (20 micron particle) off of new paved surfaces, and provide oil & grease control from the first 1/2" of runoff from parking areas.
6. The applicant shall submit, prior to plan signoff, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number: building footprints; internal walkway areas; internal site parking areas; other miscellaneous impervious areas lot lines; lot/ plat lines, dimensions and labels; right-of-way lines; street names, stormwater management facilities and; detail drawings associated with stormwater management facilities (including if applicable planting plans).
7. The applicant shall submit, prior to plan sign-off, digital PDF files to the City Engineering Division. The digital copies shall be to scale, shall have a scale bar on the plan set, and shall contain the following items: building footprints; internal walkway areas; internal site parking areas; lot lines and right-of-way lines; street names, stormwater management facilities and; detail drawings associated with stormwater management facilities (including if applicable planting plans).

8. The applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management File including: SLAMM DAT files; RECARGA files; TR-55/HYDROCAD/etc., and; sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
9. Prior to final approval of the conditional use and demolition permit applications, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1) \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2) \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner.

Please contact Bryan Walker of the Traffic Engineering Division at 267-8754 if you have any questions regarding the following four (4) items:

10. The applicant shall indicate the type of City approved bicycle racks to be installed and locations. The bike rack should be located by the entrances to the buildings.
11. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the 2-foot overhang, and a scaled drawing at 1" = 20'.
12. The intersection shall be so designed so as not to violate the City's sight-triangle preservation requirements, which state that on a corner lot no structure, screening, or embankment of any kind shall be erected, placed, maintained or grown between the heights of 30 inches and 10 feet above the curb level or its equivalent within the triangle space formed by the two intersecting street lines or their projections and a line joining points on such street lines located a minimum of 25 feet from the street intersection in order to provide adequate vehicular vision clearance.
13. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact Patrick Anderson of the City's Zoning Office at 266-5978 if you have any questions regarding the following six (6) items:

14. Provide a reuse/recycling plan, to be reviewed and approved by the City Recycling Coordinator prior to a demolition permit being issued. Sec 28.12(12)(e) of the Zoning Ordinance requires the submittal of documentation demonstrating compliance with the approved reuse and recycling plan. Please note, the owner must submit documentation of recycling and reuse within 60 days of completion of demolition.
15. Parking requirements for persons with disabilities must comply with MGO Section 28.11(3)6.(m) which includes all applicable State accessible requirements, including but not limited to:
 - a.) Provide a minimum of 2 accessible stalls striped per State requirements. A minimum of one of the stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent.
 - b.) Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.
 - c.) Show the accessible path from the stalls to the buildings. The stalls shall be as near the accessible entrance as possible. Show ramps, curbs, or wheel stops where required.
16. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with MGO Section 31. Sign permits must be issued by the Zoning Section of the Department of Planning and Community & Economic Development prior to sign installation.

17. Bike parking shall comply with MGO Section 28.11. Provide 2 bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. Note: A bike-parking stall is 2 feet by 6 feet with a 5-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.
18. Lighting is not required. However, if lighting is provided, it shall comply with City of Madison outdoor lighting standards, section 10.085. Lighting will be limited to .10 watts per square foot. (See City of Madison Lighting Ordinance).
19. Within 10 feet of a driveway crossing a street lot line, any landscaping/screening shall not exceed 2 feet in height for vision clearance. No landscape elements shall be maintained between the heights of 30 inches and 10 feet above the curb level within the 25 feet vision triangle of a street corner.

Please contact my office at 261-9632 if you have questions about the following four (4) items:

20. Revise the project plans for Planning Division approval prior to final approval of the conditional use and issuance of demolition or building permits as follows:
 - a.) show the location of any propane sales and exchange cages;
 - b.) show the location of the underground fuel pumps on Sheet C102;
 - c.) show the planting of shrubs and perennials in the strip located between the fuel service area and N. Sherman Avenue sidewalk and the planting of additional shrubs or perennials along the northern property line;
 - d.) provide detailed elevations of the proposed canopy, including the height as measured from the bottom of the structure to grade.
21. The outdoor storage and sale of windshield wash, mulch, firewood, salt and other such materials shall not be permitted at any location on the subject site, including in the parking lot, on walkways adjacent to the convenience store or in the area of the pump islandsr.
22. No outdoor amplified advertisements or music shall be permitted.
23. The hours of operation shall be 6:00 a.m. to 11:00 p.m. daily. Modifications to these hours of operation shall be allowed only following the approval of a minor alteration to the conditional use by the Director of the Planning Division and the recommendation of the district alder.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

No interior, exterior or structural demolition or wrecking activities or remodeling activities (including material reclamation activities by the applicant or a third party) shall commence nor any wrecking or building permits be issued by the City until the applicant has met all of the conditions of approval stated in this letter.

Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right of way. Permission for such activities must be obtained from the City Forester, 266-4816.

Please now follow the procedures listed below for obtaining permits for your project:

1. Please revise your plans per the above conditions and submit **eight (8) copies** of a complete, fully dimensioned and to-scale plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off.
2. Provide a reuse/recycling plan, to be reviewed and approved by the City Recycling Coordinator prior to a demolition permit being issued. Sec 28.12(12)(e) of the Zoning Ordinance requires the submittal of

documentation demonstrating compliance with the approved reuse and recycling plan. Please note, the owner must submit documentation of recycling and reuse within 60 days of completion of demolition.

3. The Madison Water Utility shall be notified to remove the water meter(s) prior to demolition.
4. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval.
5. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the issuance of said building permit. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks
 Planner

cc: Janet Dailey, City Engineering Division
 Bryan Walker, Traffic Engineering Division
 Pat Anderson, Asst. Zoning Administrator
 Bill Sullivan, Madison Fire Department
 Dennis Cawley, Madison Water Utility

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

Signature of Property Owner (If Not Applicant)

| For Official Use Only, Re: Final Plan Routing | | | |
|---|--------------------------|-------------------------------------|-----------------------------|
| <input checked="" type="checkbox"/> | Planning Div. (T. Parks) | <input checked="" type="checkbox"/> | Engineering Mapping Sec. |
| <input checked="" type="checkbox"/> | Zoning Administrator | <input type="checkbox"/> | Parks Division |
| <input checked="" type="checkbox"/> | City Engineering | <input type="checkbox"/> | Urban Design Commission |
| <input checked="" type="checkbox"/> | Traffic Engineering | <input checked="" type="checkbox"/> | Recycling Coord. (R&R Plan) |
| <input checked="" type="checkbox"/> | Fire Department | <input type="checkbox"/> | Other: |