

**PLANNING DIVISION REPORT
DEPARTMENT OF PLANNING AND COMMUNITY
AND ECONOMIC DEVELOPMENT**

April 7, 2008

RE: I.D. #09778, Conditional Use Application – 609 E. Gorham Street

1. Requested Action: Approval of a conditional use to convert a former 17-bed rooming house into a six-unit apartment building.
2. Applicable Regulations: Section 28.12 (11) provides the guidelines and regulations for the approval of conditional uses.
3. Report Drafted By: Kevin Firchow, AICP, Planner

GENERAL INFORMATION

1. Applicant, Contact, and Property Owner: Michael Matty; Renaissance Property Group; 1 Sherman Terrace; Madison, WI 53704
2. Development Schedule: The applicant estimates project completion on May 1, 2008.
3. Location: An approximately 8,712 square foot parcel located at 609 E. Gorham Street near its intersection with N. Blair Street, across from James Madison Park. Aldermanic District 2; Madison Metropolitan School District.
4. Existing Conditions: The subject building is a vacant 17-bed rooming house. The property is zoned R5 (General Residence District) and is within the Fourth Lake Ridge National Register Historic District.
5. Surrounding Land Use and Zoning: The subject property is located among several small (2-6 unit) apartment buildings and single-family residences zoned R5 (General Residence District).
6. Adopted Land Use Plan: The City of Madison Comprehensive Plan recommends “medium density residential” uses (MDR) for this site. This recommendation includes a density range of 16-40 units per acre. The recently adopted Tenney Lapham Neighborhood Plan more specifically recommends a density range of 16-25 units per acre for this area.
7. Environmental Corridor Status: The property is not located within a mapped environmental corridor.
8. Public Utilities & Services: The property is served by a full range of urban services.

STANDARDS FOR REVIEW

This application is subject to the conditional use standards of Section 28.12 (11).

ANALYSIS, EVALUATION, AND CONCLUSION

The applicant requests conditional use approval to convert a former 17-bed rooming house into a six-unit apartment building. The proposed physical alternations include a significant interior remodeling and historic restoration of the building's facade. As a proposed multi-unit apartment building in R5 zoning, this request is subject to the conditional use review and the standards of Section 28.12(11).

The subject building is a two-story, 5,148 square foot structure. The building is currently vacant and was most recently used as a 17-bedroom rooming house. The property is located among a line of similar small apartment buildings and single-family homes across from James Madison Park. Adjacent properties include three and six unit apartment buildings. Based on the parcel size, a six-unit structure would be consistent with density requirements for R5 zoning.

The remodeled building would include one (1) studio apartment, two (2) one-bedroom units, two (2) one-bedroom units with dens, and one (1) one-bedroom loft apartment. Two of these units will be accessible. The applicant notes that the overall bed count will be reduced from 17 to six. Units would be accessed through internal hallways with amenities including in-unit washers, dryers, and dishwashers.

Several physical alterations to the building are proposed. Interior improvements include reconfiguration of spaces along with new electrical service, plumbing, and the installation of energy efficient appliances. Exterior changes include a new roof, windows, paint, and restoration of the front porch. The property is within the Fourth Lake Ridge National Register Historic District. The City Preservation Planner has reviewed the applicant's plans and has no objections.

The site plan indicates there will be seven vehicle-parking stalls with one being accessible. The applicant notes there will be at least ten bicycle-parking stalls. Additionally, it appears that the plan exceeds the zoning requirements for usable open space with approximately 1,200 square feet provided. The site plan does not indicate the location of the building's dumpster or associated screening, though the applicant indicates that management staff collects all garbage and recyclables from all units and either pulls it to street or deposit trash in a central dumpster at another site placing too much on the curb and we are able to collect trash more often in order to limit the amount of garbage curbside. Staff recommends this information be included in the plans submitted for final sign-off.

The project has a calculated density of 30 units per acre and is consistent with the

Comprehensive Plan's recommendation for 16-40 units per acre. While reducing the overall density of the building, the proposed project remains slightly higher than the 16-25 units per acre density recommended for this area in the recently adopted Tenney Lapham Neighborhood Plan. As a renovation project, staff does not believe that this small difference in recommended density is a substantial issue, noting that the proposed project addresses other neighborhood plan recommendations such as maintaining and restoring the neighborhood's historic housing stock. The conversion would also provide consistency with the density and dwelling unit type found on surrounding properties. Staff believe that the project can meet applicable conditional use standards.

RECOMMENDATION

The Planning Division recommends that the Plan Commission find that the conditional use standards are met and **approve** the conversion of a 17-bed rooming house into a six-unit apartment building at 609 E. Gorham Street, subject to input at the public hearing and the following conditions:

1. Comments from reviewing agencies.
2. That the applicant specify how trash and recycling for the apartment building will be managed on the final site plans. If the onsite trash and recycling storage is proposed, the applicant shall identify the location(s) of dumpsters and screening or enclosures per Planning Division approval.



Department of Public Works
City Engineering Division

608 266 4751

Larry D. Nelson, P.E.
City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
608 264 9275 FAX
1 866 704 2315 Textnet

Deputy City Engineer
Robert F. Phillips, P.E.

Principal Engineers
Michael R. Dailey, P.E.
Christina M. Bachmann, P.E.
John S. Fahrney, P.E.
Gregory T. Fries, P.E.

Facilities & Sustainability
Jeanne E. Hoffman, Manager
James C. Whitney, A.I.A.

Operations Manager
Kathleen M. Cryan

Hydrogeologist
Joseph L. DeMorett, P.G.

GIS Manager
David A. Davis, R.L.S.

Financial Officer
Steven B. Danner-Rivers

DATE: March 27, 2008
TO: Plan Commission
FROM: Larry D. Nelson, P.E., City Engineer
SUBJECT: 609 East Gorham Street Conditional Use

The City Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. The following new addresses which have been approved shall be used and posted per Madison General Ordinances for this site:

Garden Level Apartment w/ Kitchen Unit No. 0011- 609 E. Gorham St. #1
Garden Level Apartment w/ Kitchen Unit No. 0021- 609 E. Gorham St. #2
First Floor Apartment w/ Kitchen Unit No. 1012- 609 E. Gorham St. #101
First Floor Apartment w/ Kitchen Unit No. 1021- 609 E. Gorham St. #102
Second Floor Apartment w/ Kitchen Unit No. 2015- 609 E. Gorham St. #201
Second Floor Apartment w/ Kitchen Unit No. 2023- 609 E. Gorham St. #202

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

Engineering Division Review of Planned Community Developments, Planned Unit Developments and Conditional Use Applications.

Name: 609 East Gorham Street Conditional Use

General

- 1.1 The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
- 1.2 The site plan shall identify lot and block numbers of recorded Certified Survey Map or Plat.
- 1.3 The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing and proposed utility locations and landscaping.

9



- 1.4 The site plan shall identify the difference between existing and proposed impervious areas.
- 1.5 The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
- 1.6 Submit a PDF of all floor plans to Lori Zenchenko lzenchenko@cityofmadison.com so that a preliminary interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during, or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshall.
- 1.7 The site plan shall include a full and complete legal description of the site or property being subjected to this application.
- 1.8 The Developer is required to pay Impact Fees for the _____ Impact Fee District for Lot(s) _____ of the _____ Plat/CSM. The current rate is \$ _____ /1000SF for a total of \$ _____. The Developer shall select one of the following two options for payment of these fees:
 - 1) Impact Fees shall be paid in full prior to Engineering sign-off of the plat/csm.
 - 2) The Developer has elected to defer the payments until such time as the building permits are applied for, in which case the owner(s) shall have fourteen (14) days after receiving the invoices to pay the outstanding impact fees. The following shall be required prior to plat sign off;
 - a) The Developer shall supply an Excel spreadsheet with lot numbers, lot areas, and number of dwelling units per lot. The Developer shall supply a CADD file of the proposed FINAL plat, in a format compatible with Microstation J. This information shall be required to calculate the Impact Fees, which will then be recorded at the Register of Deeds against each lot in the subdivision..
 - b) All information shall transmitted to Janet Dailey by e-mail at Jdailey@cityofmadison.com, or on a CD to:

Janet Dailey
City of Madison Engineering Division
210 Martin Luther King Jr. Blvd
Room 115
Madison, WI 53703
 - c) A minimum of three (3) weeks shall be required for staff to calculate the Impact Fees and record the documents prior to plat sign-off.

The Developer shall put the following note on the face of the plat:

ALL THE LOTS WITHIN THIS SUBDIVISION ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE WITHIN FOURTEEN DAYS OF THE ISSUANCE OF BUILDING PERMIT(S).

Right of Way / Easements

- 2.1 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____,
- 2.2 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.3 The Applicant shall Dedicate a Permanent Limited Easement for grading and sloping _____ feet wide along _____
- 2.4 The City Engineer has reviewed the need for pedestrian and bicycle connections through the development and finds that no connections are required.
- 2.5 The Applicant shall Dedicate a Permanent Limited Easement for a pedestrian / bicycle easement _____ feet wide from _____ to _____.
- 2.6 The Developer shall provide a private easement for public pedestrian and bicycle use through the property running from _____ to _____.
- 2.7 The developer shall be responsible for the ongoing construction and maintenance of a path within the easement. The maintenance responsibilities shall include, but not be limited to, paving, repaving, repairing, marking and plowing. The developer shall work with the City of Madison Real Estate Staff to administer this easement. Applicable fees shall apply.
- 2.8 The Public Sanitary Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
 - a. The property owner reserves the right to use and occupy the Public Sanitary Sewer Easement Area(s) in a

9

manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sanitary sewer facilities.

- b. No above-ground improvements shall be located in the Public Sanitary Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public sanitary sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
- c. Plantings and landscaping within the Public Sanitary Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Sanitary Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Sanitary Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

2.9 The Public Sidewalk Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:

- a. The property owner reserves the right to use and occupy the Public Sidewalk Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sidewalk improvements.
- b. No above-ground improvements will be allowed in the Public Sidewalk Easement Area(s) by the property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
- c. Plantings and landscaping within the Public Sidewalk Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Sidewalk Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Sidewalk Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

2.10 The Public Storm Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:

- a. The property owner reserves the right to use and occupy the Public Storm Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public storm sewer facilities.
- b. No above-ground improvements shall be located in the Public Storm Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public storm sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
- c. Plantings and landscaping within the Public Storm Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Storm Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.
The Public Storm Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

2.11 The Public Water Main Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:

- a. The property owner reserves the right to use and occupy the Public Water Main Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public water main facilities.
- b. No above-ground improvements will be allowed in the Public Water Main Easement Area(s) by the property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
- c. Plantings and landscaping within the Public Water Main Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Water Main Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Water Main Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

Streets and Sidewalks

3.1 The Applicant shall execute a waiver of notice and hearing on the assessments for the improvement of [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.

3.2 **Value of sidewalk installation over \$5000.** The Applicant shall Construct Sidewalk to a plan approved by the City Engineer along _____.

9

- 3.3 **Value of sidewalk installation under \$5000.** The Applicant shall install public sidewalk along _____. The Applicant shall obtain a Street Excavation Permit for the sidewalk work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. All work must be completed within six months or the succeeding June 1, whichever is later. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.4 The Applicant shall execute a waiver of their right to notice and hearings on the assessments for the installation of sidewalk along [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.5 The Applicant shall grade the property line along ____ to a grade established by the City Engineer. The grading shall be suitable to allow the installation of sidewalk in the future without the need to grade beyond the property line. The Applicant shall obtain a Street Excavation permit prior to the City Engineer signing off on this development. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.6 The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
- 3.7 **Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation.** The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.8 The Applicant shall make improvements to _____ in order to facilitate ingress and egress to the development. The improvement shall include a (Describe what the work involves or strike this part of the comment.) _____
- 3.9 The Applicant shall make improvements to _____. The improvements shall consist of _____.
- 3.10 The approval of this Conditional Use does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
- 3.11 The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
- 3.12 The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
- 3.13 The Applicant shall obtain a privilege in streets agreement for any encroachments inside the public right of way. The approval of this development does not constitute or guarantee approval of the encroachments.
- 3.14 The Applicant shall provide the City Engineer with the proposed soil retention system to accommodate the restoration. The soil retention system must be stamped by a Professional Engineer. The City Engineer may reject or require modifications to the retention system.
- 3.15 The Applicant shall complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate shall be approved by the City. The Construction Engineer shall be notified prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced.
- 3.16 All work in the public right-of-way shall be performed by a City licensed contractor.
- 3.17 Installation of "Private" street signage in accordance with 10.34 MGO is required.
- 3.18. All street tree locations and tree species within the right of way shall be reviewed and approved by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl, of the City Parks Department - dkahl@cityofmadison.com or 266-4816.

Storm Water Management

- 4.1 The site plans shall be revised to show the location of all rain gutter down spout discharges.
- 4.2 Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public

storm sewer.

- 4.3 The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
- 4.4 The applicant shall show storm water "overflow" paths that will safely route runoff when the storm sewer is at capacity.
- 4.5 The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
- 4.6 The City of Madison is an approved agent of the Department of Commerce. This proposal contains a commercial building and as such, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
- 4.7 This development includes multiple building permits within a single lot. The City Engineer and/or the Director of the Inspection Unit may require individual control plans and measures for each building.
- 4.8 If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds.
- 4.9 Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - Detain the 2 & 10-year storm events.
 - Detain the 2, 10, & 100-year storm events.
 - Control 40% TSS (20 micron particle) off of new paved surfaces
 - Control 80% TSS (5 micron particle) off of new paved surfaces
 - Provide infiltration in accordance with Chapter 37 of the Madison General Ordinances
 - Provide substantial thermal control.
 - Provide oil & grease control from the first 1/2" of runoff from parking areas.
 - Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by Chapter 37 of the Madison General Ordinances.

Stormwater management plans shall be submitted and approved by City Engineering prior to signoff.

- 4.10 The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
- 4.11 A portion of this project comes under the jurisdiction of the US Army Corp of Engineers and WDNR for wetland or flood plain issues. A permit for those matters shall be required prior to construction on any of the lots currently within the jurisdictional flood plain.
- 4.12 The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) All Underlying Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words "unplatted"
 - h) Lot/Plat dimensions
 - i) Street names

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

- 4.13 NR-151 of the Wisconsin Administrative Code will be effective on October 1, 2004. Future phases of this project shall comply with NR 151 in effect when work commences. Specifically, any phases not covered by a Notice of

9

Intent (NOI) received from the WDNR under NR-216 prior to October 1, 2004 shall be responsible for compliance with all requirements of NR-151 Subchapter III. As most of the requirements of NR-151 are currently implemented in Chapter 37 of the Madison General Ordinances, the most significant additional requirement shall be that of infiltration.

NR-151 requires infiltration in accord with the following criteria. For the type of development, the site shall comply with one of the three (3) options provided below:

Residential developments shall infiltrate 90% of the predevelopment infiltration amount, 25% of the runoff from the 2-year post development storm or dedicated a maximum of 1% of the site area to active infiltration practices.

Commercial development shall infiltrate 60% of the predevelopment infiltration amount, 10% of the runoff from the 2-year post development storm or dedicate a maximum of 2% of the site area to active infiltration practices.

- 4.14 The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set.
- PDF submittals shall contain the following information:
- a) Building footprints.
 - b) Internal walkway areas.
 - c) Internal site parking areas.
 - d) Lot lines and right-of-way lines.
 - e) Street names.
 - f) Stormwater Management Facilities.
 - g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).
- 4.15 The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
- a) SLAMM DAT files.
 - b) RECARGA files.
 - c) TR-55/HYDROCAD/Etc...
 - d) Sediment loading calculations
- If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
- 4.16 The area adjacent to this proposed development has a known flooding risk. All entrances shall be 2-feet above the adjacent sidewalk elevation or 1-foot above the 100-year regional flood elevation (whichever is greater). This includes garage entrances.

Utilities General

- 5.1 The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.2 The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.3 All proposed and existing utilities including gas, electric, phone, steam, chilled water, etc shall be shown on the plan.
- 5.4 The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.5 The site plans shall be revised to show the location of existing utilities, including depth, type, and size in the adjacent right-of-way.
- 5.6 The developer shall provide information on how the Department of Commerce's requirements regarding treatment of storm water runoff, from parking structures, shall satisfied prior to discharge to the public sewer system. Additionally, information shall be provided on which system (storm or sanitary) the pipe shall be connected to.

Sanitary Sewer

- 6.1 Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

- 6.2 All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Dailey (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff.
- 6.3 Each unit of a duplex building shall be served by a separate and independent sanitary sewer lateral.
- 6.4 The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.

9



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

March 27, 2008

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: **609 East Gorham Street – Conditional Use – Convert Former Rooming House into 6- Unit Apartment Building**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. A condition of approval shall be that no residential parking permits shall be issued for 609 East Gorham Street, this would be consistent with other projects in the area. In addition, the applicant shall inform all tenants of this facility of the requirement in their apartment leases. In addition, the applicant shall submit for East Gorham Street a copy of the lease noting the above condition in the lease when submitting plans for City approval.

PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. The applicant shall indicate the type of bicycle racks to be installed outside.
3. The applicant should provide an area for visitor outside moped parking spaces and access. Moped standard parking spaces recommend 4 ft in width and 6 ft in length with a 6 ft access aisle.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

4. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either

side, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.

5. The applicant shall reconstruct the driveway approach to align or match the drive aisle to the parking lot.
6. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
7. Per ordinance, the small car stalls shall not exceed 25% of the total number of Medium and Large Vehicles and Small Vehicles stalls for the facility. The site plan shall show small car parking spaces identified and properly controlled with a sign "Small Cars Only" per each space, when plans are submitted for approval.
8. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Michael Matty
Fax: 608-301-0001
Email:

DCD: DJM: dm

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: April 7, 2008

To: Plan Commission

From: Patrick Anderson, Assistant Zoning Administrator

Subject: 609 East Gorham Street

Present Zoning District: R-5

Proposed Use: Conversion of former rooming house into a 6-unit apartment building.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE**

GENERAL OR STANDARD REVIEW COMMENTS

1. Meet all applicable State accessible requirements, including but not limited to:
 - a. Show signage at the head of the stalls.
 - b. Show the accessible path from the stalls to the building.

2. Proposed bike parking occupies an area identified as open space. Clearly show bike parking as separated form open space area. Provide six (6) bike parking stalls in a safe and convenient location on an impervious surface, to be shown on the final plan. The bike racks shall be securely anchored to the ground or building to prevent the racks from moving. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area.

ZONING CRITERIA

Bulk Requirements	Required	Proposed
Lot Area	6,000 sq. ft.	8,711 sq. ft.
Lot Are Per D.U.	5,700 sq. ft. total	Adequate
Lot width	50'	66'
Usable open space	960 sq. ft.	1,214 sq. ft.
Front yard	20'	14'-8" (existing)
Side yards	Min. 6' (total 15')	9'-8" (19'-4")
Rear yard	30'	68'±
Building height	3 stories/40'	2 stories plus loft/27' av. mean

609 East Gorham Street
 April 7, 2008
 Page 2

Site Design	Required	Proposed
Number parking stalls	7	7
Accessible stalls	1 min. Van Accessible	1 (1)
Number bike parking stalls	6	TBD (2)
Landscaping	No	
Lighting	No	

Other Critical Zoning Items	
Urban Design	No
Utility easements	None shown
Barrier free (ILHR 69)	Yes

With the above conditions, the proposed project **does** comply with all of the above requirements.



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295
Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: April 3, 2008
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **609 E. Gorham St.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

All fire and life safety codes for multifamily dwelling units apply to this new building use.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan