

Bass, Kelly

Subject: FW: File 48211 - comments

-----Original Message-----

From: Tom Hirsch [REDACTED]
Sent: Monday, August 07, 2017 9:27 AM
To: Scanlon, Amy
Subject: File 48211 - comments

I live across the street from the proposed improvements and, generally, am in support of them.

I suggest the demountable metal stairs be replaced with a 1:20 ramp with a 5x5 landing in order to have persons with disabilities use the same entrance as everyone else.

I also suggest the 2'3" offset on the South wall for the addition be increased to allow garbage containers to be accessed from the alley (and be fenced).

I wish the business every success for the sake of the neighborhood.

Thomas Hirsch, FAIA
[REDACTED] North Allen Street
MADISON WI 53726 [REDACTED]

[REDACTED]

"Architecture Matters Everyday
& Everyday Architecture Matters"