

SUMMARY OF PUBLIC WORK STANDARD SPECIFICATION REVISIONS – 2019

STANDARD SPECIFICATIONS

102.12 Equal Rights Benefit

This section is deleted.

103.3 Execution of Contract and Bond

Revised language form duplicate to triplicate.

109.9 Liquidated Damages

Increased LDs. This is the first adjustment since 2011.

110.2 Partial Payments

The first demographic records are due when twenty five (25) percent of the contract total has been paid or by the second pay request, whichever comes first. Payment **may** be held until these records are submitted. The word 'shall' was replaced with the word 'may'

202.2(f)

Adding language for turf and non-turf topsoils.

203.2 (c) Abandoning Structure and Pipes

Added: The floor of the structure shall have a minimum of five (5) three (3) inch holes punched or drilled through.

205 Adjustment of Castings

Adjusting structures - increase to 1ft for resurfacing

207.3

Revised seed mix (detention, infiltration, etc)

207.3(d) Mulching

Revised to include wood fiber and remove emulsified asphalt

301.5 Placing and Finishing

Deleted language that concrete with rebar can't be placed below 36F.

Article 403.16 Adjust Valve Casting

Typo.

503.2 Materials

Added pipe bursting pipe materials:

HDPE - High Density Polyethylene – smooth walled (pipe bursting)

Fusible C900 – material is more like HDPE, not rigid (pipe bursting)

503.2 (a)

Corrected typo SDSR-26 to SDR-26

504.2(H)

Corrected typo SDSR-26 to SDR-26

408.1 Materials For Pavement Chip Sealing

Typo

503.2(c) Corrugated-Wall Polypropylene (CWPP) Sewer Pipe and Fittings.

Deleted: Triple Wall and Fittings for Polypropylene Pipe (CWPP 30" diameter-36" diameter)

504.2 Materials

Type II: Pavement Storm

Add language to better define where can it be used including turf, in terraces, under curb, min 2ft cover (to top of basecourse) to the lowest point of the pipe run. Max size is 36". For use in new subdivisions only.

505.3(a) Box Culverts Revise 1. And 2. As follows:

1. The sub-grade for the boxes shall have WDOT TYPE HR filter fabric placed on all exposed sub-grade areas prior to placement of the bedding stone for the boxes.
2. One (1) foot of three (3) inch clear stone shall then be placed on the geotextile fabric as bedding stone.

507.2(b) Sewer Access Structures

Added Casting: R-1550 Hydro Vent

507.2(e) Special Castings

Added Stormwater curb opening casting for 4" curb heads: R-3262-3

702.1 Materials: General

Clarify protection requirements for water materials stored on site to protect from contamination.

702.3.1 Ductile Iron Pipe

Require any cad welded bonding straps to be coated in approved rubberized corrosion resistance product.

702.4 Fittings & Accessories

Include additional approved coupling/connection materials (Hymax Grip, Romac Alpha).

702.4.5 Repair Sleeves

Include additional repair sleeve (Hymax Versa).

703.1 Construction Methods: General

Provide trench-foot conversion for utility trench patch measurements of water main installations. Reiterate that the Utility does not own or maintain service laterals beyond the curb stop or within 8-FT of the right-of-way line, and subsequently will not be responsible for locating these facilities.

703.7 Connecting to Existing Water Mains

Provide additional clarification regarding cut-in connections. Pipe/fittings installed along the run leg of the connection are not to be included as separate payment for water main items. Valves will be paid separately, and added fittings will be paid per standard set pricing formulas.

703.10.2 Joint Restraint

Any 4-IN or larger water main or service lateral stub greater than 20-FT will require joint restraint. No pipe-pipe joints permitted within 10-FT of a valve connection.

703.12 Copper Service Laterals

Remove requirement to direct-tap 1.5-IN and 2-IN copper laterals, require use of approved stainless steel saddles per 702.

Allow corp tap installations to range from 45-deg to 60-deg to aid copper sweep transition.

703.15.1 Conductivity Testing

Require any cad welded bonding straps to be coated in approved rubberized corrosion resistance product.

703.18 Water Utility Construction Services

Reiterate that the Utility does not own or maintain service laterals beyond the curb stop or within 8-FT of the right-of-way line, and subsequently will not be responsible for locating these facilities.

SDD 5.4.4 RIPRAP AT APRON END WALLS

Added note 5) to clarify that RCP concrete cutoff wall only when called for and when called for it shall be included in endwall cost.

SDD 5.7.7 TYPE H INLET

Added language that the inside adjustment rings shall not be sealed with mortar. The material falls off and into flow lines.

SDD 5.7.15 SAS CHIMNET AND CASTING

Added language that the inside adjustment rings shall not be sealed with mortar. The material falls off and into flow lines.

SDD 5.7.40 LATERAL BACKFLOW PREVENTER

New Item

SDD 5.7.41 LATERAL CLEANOUT

New Item

SDD 7.04 TYPICAL HYDRANT INSTALLATION

Set valve box ½-IN below finished grade, rather than within a tolerance range of ¼-IN to ½-IN.

SDD 7.06 WATER VALVE BOX ALIGNMENT

Set valve box ½-IN below finished grade, rather than within a tolerance range of ¼-IN to ½-IN.

7.09 - LOCATION OF WATER SERVICES

Depict lateral ownership transition points.

SDD 7.10 SERVICE LATERAL INSTALLATION

Allow corp tap installations to range from 45-deg to 60-deg to aid copper sweep transition. Depict lateral ownership transition points.

SDD 7.16 JOINT RESTRAINT LENGTHS FOR VERTICAL BENDS

Revise to reflect restraint requirements associated with offset sweep fittings per SDD 7.22.

SDD 7.20 STANDARD HDPE TRACER WIRE VALVE BOX

Set valve box ½-IN below finished grade, rather than within a tolerance range of ¼-IN to ½-IN.

SDD 7.21 CASING SPACERS

Revised for spelling/grammar.

SDD 7.22 OFFSETTING EX WM UNDER UTILITY CONFLICTS

Revised for spelling/grammar.

SDD 7.28 – 7.42 WATER UTILITY METER INSTALLATION DETAILS (MULTIPLE)

Revise standard meter installation details for meter clearance and straight-pipe requirements.

Owner/Plumber to furnish specified meter couplings, flanges, bolts, gaskets etc.

Clarify meter location requirements in relation to entry point of building.

Improve clarity and consistency, revise spelling/grammar throughout entire meter detail set.

DELETED

NONE