



12/23/2014 Water Utility Board Meeting
Unit Well 31 Facility Design Project

Well 31 Proposed Facility Design and Energy Use/Operational Evaluations

Presentation and Reports Prepared By:

Al Larson, PE, BCEE | Principal Engineer, Madison Water Utility
Adam Wiederhoeft, PE | Engineer III, Madison Water Utility
Randy Sanford, PE | Project Manager, Short Elliot Hendrickson, Inc.

Review of the November Water Board Meeting:

- Presented the recommended Well 31 design concept for final design and construction.
 - Two concepts:
 - Option 1 – Detached Reservoir
 - Option 2 – Attached Reservoir
 - Public Hearing on the proposed facility designs.
- Information requested by the Water Board:
 - Energy evaluations for the proposed Fe & Mn treatment system & pumping operations.
 - Associated operational & maintenance costs.
 - Evaluation of other energy saving opportunities:
 - Incorporating a 2nd (upper aquifer) supply well.
 - Flow bypass to reduce treatment (meet WQ goals).
 - Energy analysis from ongoing UW Grad Project



Recommended Facility Design Concept - Review

- Consider steel vs. concrete tanks.
 - Concrete preferred, in building, size, durability.
 - Comparable capital costs, lower lifetime cost
- Estimated Construction Costs:
 - Option 1 - \$5,470,000
 - Option 2 - \$6,730,000
 - MWU Budget: \$5,700,000
- Evaluation Matrix:

Pumping Facility Decision Matrix				
(Scale 1 – 3: 1 = Least Desirable, 3 = Most Desirable)				
Scenario	Option 1	Option 1A	Option 2	Option 2A
Aesthetics	2	2	2	2
Operation and Maintenance	1	2	2	1
Capital & Construction Costs	3	3	1	1
1.5 MG Life Cycle Cost	2	3	1	1
Total Score	8	10	6	5

↑ (Most Desirable Facility)

- Recommended concept is Option 1A – regardless of energy/operational scenario



Option 1 - Detached Tank



Option 2 - Attached Tank

Energy and Operational Analysis Scenarios

We evaluated energy needs and associated operating costs for four proposed pumping/treatment scenarios developed at Well 31.

Energy Evaluation Scenarios Considered:

1. Pump & treat from lower aquifer at 2,200 GPM.
2. Pump 2,200 GPM from lower aquifer and treat only the portion of water required to meet MWU's water quality goal of 0.10 mg/L for iron.
3. Drill a new upper aquifer well and pump at 640 GPM without treatment; pump & treat from the lower aquifer at 1,560 GPM (max 2,200 GPM supply).
4. Drill a new upper aquifer well and pump at 640 GPM without treatment; pump & blend from the lower aquifer at 320 GPM to meet WQ goal for iron.

Associated Costs:

- Energy
- Operational & maintenance
- Impact on capital/construction cost

Scenario 1 – Pump & Treat From Deep Well

Pump 2,200 GPM from deep well, treat 100% of flow, baseline scenario.
Total production of 700,000 gallons/day.

Energy Analysis:

- High lift pumping (*Constant - equal for all scenarios considered*)
 - 230,000 kWh/yr - Annual energy cost of \$17,000/yr
- Deep Well pumping + treatment for Scenario 1
 - 470,000 kWh/yr - Annual energy cost of \$36,000/yr

Operational & Maintenance Costs:

- \$44,000/year

Estimated Annual operating cost:

- O&M + High Lift Pumping + Well & Treatment Pumping = \$97,000/yr

Capital/Construction Impacts:

- No impact
- Construction cost estimate for Option 1 + Scenario 1 = \$5.47M.

Scenario 2 – Pump From Deep Well & Treat Only the Portion Needed to Meet Water Quality Goals

Pump 2,200 GPM from deep well, treat 73% of flow and blend with untreated supply to meet WQ goal for iron (0.10 mg/L). Total production of 700,000 gallons/day.

Energy Analysis:

- High lift pumping (*Constant - equal for all scenarios considered*)
 - 230,000 kWh/yr - Annual energy cost of \$17,000/yr
- Deep Well pumping + partial treatment for Scenario 2
 - 451,000 kWh/yr - Annual energy cost of \$34,000/yr (-\$2,000/yr)

Operational & Maintenance Costs:

- \$52,000/year (*blending inspections, increased water main flushing*) (+\$8,000/yr)

Estimated Annual operating cost:

- O&M + High Lift Pumping + Well & Treatment Pumping = \$103,000/yr (+\$6,000/yr)

Capital/Construction Impacts:

- No impact
- Construction cost estimate for Option 1 + Scenario 2 = \$5.47M.

Scenario 3 – Drill Shallow Well & Pump Untreated, Pump & Treat Deep Well to Reach 2,200 GPM Supply

Shallow well supply of 640 GPM, untreated w/ 1,560 GPM deep well supply, treated. Total production of 700,000 gallons/day, combined 2,200 GPM supply capacity.

Energy Analysis:

- High lift pumping (*Constant - equal for all scenarios considered*)
 - 230,000 kWh/yr - Annual energy cost of \$17,000/yr
- Two Well pumping + deep well treatment for Scenario 3
 - 315,000 kWh/yr - Annual energy cost of \$24,000/yr (-\$12,000/yr)

Operational & Maintenance Costs:

- \$54,000/year (*two wells for daily inspection, most equipment*) (+\$10,000/yr)

Estimated Annual operating cost:

- O&M + High Lift Pumping + Well & Treatment Pumping = \$95,000/yr (-\$2,000/yr)

Capital/Construction Impacts:

- **(+\$330,000)** (*smaller filter bank, but requires additional well*)
- Construction cost estimate for Option 1 + Scenario 3 = \$5.8M.

Scenario 4 – Drill Shallow Well & Pump Untreated, Pump & Blend Deep Well to Meet WQ Goals

Shallow well supply of 640 GPM, untreated w/ 320 GPM deep well supply, untreated. Total production of 700,000 gallons/day, combined 960 GPM supply capacity.

Scenario Analysis:

- High lift pumping (*Constant - equal for all scenarios considered*)
 - 230,000 kWh/yr - Annual energy cost of \$17,000/yr
- Two Well pumping + deep well treatment for Scenario 3
 - 221,000 kWh/yr - Annual energy cost of \$17,000/yr (-\$19,000/yr)

Operational & Maintenance Costs:

- \$53,000/year (*two wells for daily inspection, increased flushing*) (+\$9,000/yr)

Estimated Annual operating cost:

- O&M + High Lift Pumping + Well & Treatment Pumping = \$87,000/yr (-\$10,000/yr)

Scenario Not Considered for Project

- Max day demands not met (2.3-2.7 MGD)
- Blending ratio to eliminate treatment not feasible
- Water quality, shallow well contamination risks

Recommended Operational Scenario

Well 31 Operational Scenario Decision Matrix			
(Scale 1 – 3: 1 = Least Desirable, 3 = Most Desirable)			
Alternative	Scenario 1: Pump 2,200 gpm from Deep Aquifer in Unit Well 31	Scenario 2: Pump 2,200 gpm from Deep Aquifer in Unit Well 31 and Treat a Portion to meet MWU standards of 0.1 mg/L Iron	Scenario 3: Pump and Treat 1,560 gpm from Deep Aquifer in Existing Well 31 and Mix with New Shallow Well
Energy Use	2	2	3
Operation & Maintenance	3	1	2
Capital Costs	3	3	1
Reliability	3	2	2
Water Quality	3	2	3
Operational Complexity	3	2	1
Distribution System Impacts	3	2	3
Totals	20	14	15



(Most Desirable Pumping Scenario)

Additional Considerations / Q&A

Total Cost of Fe & Mn treatment:

- Daily inspections, maintenance, energy use, backwash waste disposal
- Total filter production: 255.5 MGD (700K gallons/day)
- Annual estimated cost of \$19,660/yr

Grad Project Evaluations and Energy Opportunities:

- Hydraulic modeling of PZ4 w/ Wells 9 & 31 to determine energy savings
- 80% VFD speed at Well 31 could mitigate \$16,000/yr vs. without VFD
- Additional opportunities – Off-peak, flow distribution, HGL adjustments

Shallow Aquifer Considerations at Well 31 Location:

- Low specific capacity and limited depth of upper aquifer at Well 31
- Water quality reservations due to known groundwater contamination

Discussion and Q&A