



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

June 20, 2013

Aaron Martinek
A-Team Construction Unlimited, Inc.
5555 Odana Road
Madison, Wisconsin 53719

RE: Approval of a conditional use to allow construction of an accessory building containing an accessory dwelling unit at 939 E. Dayton Street (Maria Stephan).

Dear Mr. Martinek;

At its June 17, 2013 meeting, the Plan Commission found the standards met and **approved** your conditional use request for an accessory building containing an accessory dwelling unit at 939 E. Dayton Street. The following conditions of approval shall be satisfied prior to issuance of building permits for the proposed accessory building:

Please contact Janet Dailey of the City Engineering Division at 261-9688 if you have questions regarding the following eight (8) items:

1. Coordinate an address plan with Engineering-Mapping. In accordance with 10.34 MGO, Street Numbers, submit a PDF of each floorplan to Lori Zenchenko (lzenchenko@cityofmadison.com) at Engineering-Mapping so that a preliminary interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshal.
2. This lot appears to discharge stormwater to an enclosed depression area. Provide additional information on the amount of fill to this area, drainage plans, and means of mitigating the new impervious areas.
3. The applicant shall replace all sidewalk and curb and gutter abutting the property, which is damaged by the construction, or any sidewalk and curb and gutter that the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
4. All work in the public right of way shall be performed by a City-licensed contractor.
5. All damage to the pavement on E. Dayton Street adjacent to this development shall be restored in accordance with the City's Pavement Patching Criteria.

6. The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
7. The applicant shall submit, prior to plan sign-off, digital PDF files to the City Engineering Division. The digital copies shall be to scale, shall have a scale bar on the plan set, and shall contain the following items: building footprints; internal walkway areas; internal site parking areas; lot lines and right-of-way lines; street names, stormwater management facilities and; detail drawings associated with stormwater management facilities (including if applicable planting plans).
8. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.

Please contact Pat Anderson, Assistant Zoning Administrator, at 266-5978 if you have any questions regarding the following item:

9. The proposed accessory building shall meet all building codes as well as maintain compliance with the requirements for accessory dwelling units in Section 28.151 of the Zoning Code.

Please contact Dennis Cawley of the Madison Water Utility at 261-9243 if you have any questions regarding the following two (2) items:

10. This property is located in Wellhead Protection District WP-24. The proposed use is permitted in this district. Any proposed change in use shall be reviewed by the Water Utility General Manager or his designee.
11. All operating private wells shall be identified and permitted and all unused private wells shall be abandoned by the Water Utility in accordance with MGO Section 13.21.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following item:

12. Due to the limited access to the structure for fire ground operations, the Madison Fire Department recommends the installation of a residential fire sprinkler system in accordance with NFPA 13D and SPS 382.40(3)(e).

Please contact Kay Rutledge of the Parks Division at 266-4714 if you have any questions regarding the following two (2) items:

13. The developer shall pay \$2,353.40 in park impact fees for the new multi-family unit proposed. The fee is based on 2013 impact fee rates of \$1,708.00 per multi-family unit in lieu of parkland dedication, and \$645.40 per multi-family unit for park development fees. The developer must select a method for payment of the park fees due before signoff on the plans and pay the fee prior to issuance of building permits. This development is within the Tenney-Law-James Madison park impact fee district (SI26).
14. Approval of plans for this for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816.

Please contact my office at 261-9632 if you have any questions about the following condition added by the Plan Commission:

- 15. That the siding of the proposed accessory building be wood, fiber cement or engineered wood, and that the size of the siding on the accessory building match the size of siding on the principal residence.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

- 1. Please revise your plans per the above conditions and submit **eight (8) copies** of a complete, fully dimensioned, and to-scale set of plans, the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval prior to the issuance of permits.
- 2. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval.
- 3. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the issuance of said building permit. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks
Planner

cc: Janet Dailey, City Engineering Division
Kay Rutledge, Parks Division
Pat Anderson, Asst. Zoning Administrator
Dennis Cawley, Madison Water Utility
Bill Sullivan, Madison Fire Department

<p>I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.</p> <hr/> <p><i>Signature of Applicant</i></p> <hr/> <p><i>Signature of Property Owner (If Not Applicant)</i></p>

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (T. Parks)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: