

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 **2021**

Financial Management

1. Provider of Financial Information Name: <input type="text" value="Steve Danner-Rivers"/> Telephone: <input type="text" value="(608) 261-9689"/> (XXX) XXX-XXXX E-Mail Address (optional): <input type="text" value="sdannerrivers@cityofmadison.com"/>		
2. Treatment Works Operating Revenues 2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ? ● Yes (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ No (40 points) If No, please explain: <input type="text"/> 2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: <input type="text" value="2022"/> ● 0-2 years ago (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ 3 or more years ago (20 points) <input type="checkbox"/> <input type="checkbox"/> ○ N/A (private facility) 2.3 Did you have a special account (e.g., CFWP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system? ● Yes (0 points) ○ No (40 points)		0
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]		
3. Equipment Replacement Funds 3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: <input type="text" value="2021"/> ● 1-2 years ago (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ 3 or more years ago (20 points) <input type="checkbox"/> <input type="checkbox"/> ○ N/A If N/A, please explain: <input type="text"/>		
3.2 Equipment Replacement Fund Activity		
3.2.1 Ending Balance Reported on Last Year's CMAR	\$ <input type="text" value="1,218,862.13"/>	
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$ <input type="text" value="0.00"/>	
3.2.3 Adjusted January 1st Beginning Balance	\$ <input type="text" value="1,218,862.13"/>	
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$ <input type="text" value="1,289,000.00"/>	
	+	

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 **2021**

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) -

\$ 277,748.23

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 2,230,113.90

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

Controls Upgrade at Arbor Hills, Carroll & Veith Lift Stations
Pump Replacement at Fayette, Gettle, Hoboken & Waunona Lift Stations
Design for rehab of Harper, Thurber & Truax Lift Stations

0

3.3 What amount should be in your Replacement Fund?

\$ 0.00

Please note: If you had a CFWP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Sewer Impact Fee Districts: This program is for the extension of sanitary sewer service to developing areas of the City requiring sewer infrastructure installation. The program is funded entirely by Impact Fees, and review for planned projects is conducted annually as dictated by demand for development. Amount shown is the estimate for 2022-2023.	2,700,000	2022
2	Sewer Reconstruction: This project involves the replacement of older, problematic sewers in coordination with the City's Street Reconstruction and Pavement Management Program or as 'stand alone' projects. Typically this provides for the replacement of clay sewers that are difficult to maintain, nearing the end of their service life, have significant repair costs or are undersized. Also, the Sewer Utility encourages residents to replace the portion of their sewer lateral that lies within the public right-of-way by offering to fund 75% of the cost. Six-inch mains under streets that are being reconstructed will be replaced because they do not meet current codes. Sewers beneath streets being resurfaced are evaluated for replacement on a case-by-case basis. Amount shown is the estimate for 2022-2027.	67,538,000	2022

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 **2021**

3	Trenchless Sewer Rehabilitations: This program rehabilitates failing sewers that meet certain criteria but do not necessitate the need for a complete replacement by means of open cutting. New technology allows the lining of existing sewer mains using cameras and remote controlled tools. Some are also rehabilitated (or lined) to address inflow and infiltration problems, where clear water flow enters the sewer system, reducing pipe capacity and increasing treatment costs. The amount budgeted will repair approximately seven miles of sewer main at a number of strategically selected locations, based on citywide need. This item may also include replacement of inaccessible sewers by a 'direct bore' method, which is a relatively new technology for replacement of gravity sewer mains. Backyard sewer mains are a focus. Amount shown is the estimate for 2022-2027.	10,714,000	2022
4	Citywide Pumping Stations-Emergency Power Stationary Generators: This program funds the installation of emergency power stationary generators at the City's pumping stations. The goal of the program is to ensure continuous service in the event of a power loss. Amount shown is for 2022-2027.	355,000	2022

5. Financial Management General Comments

Annually, the City of Madison adopts a Capital Budget which funds equipment replacement and infrastructure improvements, listed in a project format. Each project is reviewed and the funding amount for the next budget year is determined. In addition, the budget details future year estimates for the five subsequent years for each project.

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	43,644	233
February	54,825	315
March	56,716	116
April	49,780	37
May	42,358	21
June	35,971	22
July	37,240	29
August	38,932	27
September	35,072	29
October	38,188	37
November	43,975	77
December	44,639	245
Total	521,340	1,188
Average	43,445	99

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 2021

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Describe and Comment:

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

The City plans to replace four City lift stations in 2022-2023. On October 31, 2022, with the attachment of the Town of Madison, the City will be adding 3 additional lift stations. All three of these current Town lift stations are planned for replacement by the City between 2024 and 2026. The new pumps and equipment will be more energy efficient than the old equipment.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 2021

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Goals & Objectives

A. DNR Required

The City of Madison's CMOM program is designed to ensure that the following general standards as articulated in NR 210.23 are met:

1. The sewage collection system is properly managed, operated, and maintained at all times.
2. The sewage collection system provides adequate capacity to convey all peak design flows.
3. All feasible steps are taken to eliminate excessive infiltration and inflow as defined in s. NR 110.03 (13c), cease sanitary sewer overflows and sewage treatment facility overflows and mitigate the impact of such overflows on waters of the state, the environment, and public health.

4. A process is in place to notify the public and other directly affected parties of any incidents of overflows from the sewerage system.

5. Annual reports are submitted in accordance with the provisions of ch. NR 208.

B. MSU Specific

The City of Madison's goals for the operation and maintenance of its wastewater collection system are:

- Convey wastewater to the Nine Springs Wastewater Treatment Plant with minimum inflow, infiltration and exfiltration.
- Prevent public health hazards.
- Reduce inconvenience and damage by responsibly handling service interruptions.
- Eliminate claims and legal fees related to backup by providing immediate, concerned and efficient service to all emergency calls.
- Protect municipal investment by increasing the useful life and capacities of the system and parts.
- Use operating funds efficiently.
- Perform all activities safely and avoid injury.

Did you accomplish them?

- Yes
- No

If No, explain:

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 2021

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public
- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Chapter 35 of the Madison General Ordinances The Public Sewage System

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2020-04-14

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance
- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training

- Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

City of Madison Standard Specifications for Public Works Construction

- Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures
- Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]
- Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 2021

I/I Analysis- The City has 3 areas (Hargrove/Johns Street, Truax Airport, and Midtown Pumping Station) where we have observed high pump run times during wet weather events. Pump run time and flow monitoring data combined CCTV inspection have been used to identify issues in these area and develop strategies for reducing I/I. Point repairs, open-cut and trenchless are used to remedy isolated defects. Replacement and manhole-to-manhole lining are used to address mains with numerous defects.

Since the initial 2012 study 66,995 LF of mains have been replaced or lined in the Hargrove/Johns area. Private sewer laterals will also be replaced as part of these projects.

Studies were conducted in the Truax Airport Lift Station in 2004 and 2015. Since then 14,385 of sewer main has been replaced or lined. In addition, 19 structures were lined.

The Mid-Town basin which is less than 20 years old continues to experience higher pump run times during rain events. We have raised, wrapped manholes, grouted holes showing signs of I/I in manholes located off pavement. CCTV has not identified the source of I/I in the main.

In 2021, the City experienced 2 major rain events on the west side exceeding 2 inches (6/18/2021 - 2.05 inches and the 9/13/2021 - 2.11 inches). Following the 6/18/2021 rain event the Midtown lift station flow was 122% of normal flow (average flow 261,298 gpd; 318,240 gpd during rain event). Following the 9/13/21 rain event flow was 134% of normal. The east side, did not have as significant of rain events: 6/18(1.44"), 6/25(1.15") and 9/13/21(1.15") but saw greater flow spikes in the Truax basin. On June 18th, flow at the Hargrove/Johns area lift station was 1.64 MGD (123% over average flow). The Truax lift station had 1.69 MGD (369% over average flow) on June 26th (6/25 1.15" storm, 6/26 0.58"storm).

SSES – The City regularly televises sanitary sewer mains to evaluate performance and plan for improvements to system based upon pipe defects(broken, fractured pipe, root obstructions, sags) or capacity concerns (pipe appears to be running at high levels).

SECAP - While the City is not required to have a formal SECAP plan, we have been closely monitoring the downtown redevelopment monitoring our capacity needs and upsizing sewer interceptors where it is needed. The City did a study in 2015 of the sewer capacity needs in the near east side and the campus area where there has been a significant high density residential growth. In 2016, as a result of development, the City installed a diversion sewer on Bassett Street to take flow off of the Frances Street sewer. In 2018. 2019 and 2020, the City installed 2 flow monitors downtown in the UW campus area: one Frances St. and one on Langdon/ Lake Street. As a result of the sewer flow diversion, the Frances Street sewer continues to appear to have residual capacity (3.86 cfs residual of the total 6.15 cfs capacity). We re-confirmed this in 2021 finding that we have 4.53 cfs residual of the total 6.15 cfs capacity.

Lift Station Evaluation Report- the City's Lift Stations are maintained and operated by the Madison Metropolitan Sewerage District. MMSD provides the City updates if there are pump run time spikes and or if there are problems with operation of the stations. The City also meets annually with MMSD to identify which stations have been problematic through the year. They also notify the City which stations are in need of upgrades whether it being upgrading pumps, electrical upgrades or complete pumping station renovation. The City will be adding 3 lift stations October 31, 2022 with the Town of Madison Attachment.

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	57.67	% of system/year
Root removal	0.12	% of system/year

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 **2021**

Flow monitoring	<input type="text" value="4"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="12.85"/>	% of system/year
Manhole inspections	<input type="text" value="2.02"/>	% of system/year
Lift station O&M	<input type="text" value="67.4"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="0.91"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="1.38"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services
River or water crossings	<input type="text" value="35.43"/>	% of pipe crossings evaluated or maintained
Please include additional comments about your sanitary sewer collection system below:		
<input type="text"/>		

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="22.82"/>	Total actual amount of precipitation last year in inches
<input type="text" value="34.48"/>	Annual average precipitation (for your location)
<input type="text" value="799.31"/>	Miles of sanitary sewer
<input type="text" value="30"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="12"/>	Number of basement backup occurrences
<input type="text" value="37"/>	Number of complaints
<input type="text" value="22.403"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.02"/>	Basement backups (number/sewer mile)
<input type="text" value="0.05"/>	Complaints (number/sewer mile)
<input type="text" value="0.0"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text" value="0.0"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 **2021**

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes
- No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

In 2021, the City of Madison did not experience significant I/I where we had impacts to properties. The 2021 storm events were not as significant storm events as we have had in the recent past. The largest storm event was on September 13th (2.11 inches) on the west side, and June 18th (1.44 inches on East Side (airport)). However, we do continue to observe increase in pump run times in the 3 basins during rain events. Truax has the greatest increased pumping volumes as a result of rainfall. The additional wastewater flow was not a problem for the City's collection system. We did not experience sewer backups or SSOs as a result of the 2021 rain events.

5.4 What is being done to address infiltration/inflow in your collection system?

The City continues to monitor problem areas in the collection system where we have observed Infiltration/ Inflow (I/I). The primary method to correct I/I has been the City's aggressive Cured in Place Lining program (approximately 9 miles of pipe lined per year). The other method to address I/I has been replacing sewer mains and laterals with street reconstruction projects. Manholes installed in high groundwater areas with construction projects are wrapped at the joints to prevent seepage of groundwater into the sanitary sewer. All sanitary manholes installed near street low points include internal chimney seals to prevent water from entering the sanitary sewer through the manhole's adjustment rings. The City had a City wide manhole lining project in 2019 (bid in 2018) to also address I/I (53 manholes) but very limited manhole rehabilitation work in 2021.

Beyond construction projects, clearwater sources such as roof drain and sump pump connections are eliminated as they are discovered with our studies, smoke testing, basement inspections, and through televising.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Madison Sewage Collection System

Last Updated: Reporting For:
5/14/2022 **2021**

Grading Summary

WPDES No: 0047341

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			4	16
GRADE POINT AVERAGE (GPA) = 4.00				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)