



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Agenda - Approved

BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

Tuesday, November 18, 2014

12:15 PM

215 Martin Luther King, Jr. Blvd.
Room LL-110 (Madison Municipal Building)

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below immediately.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese inmediatamente al número de teléfono que figura a continuación.

Yog tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntauv, cov ntaub ntauv ua lwm yam los sis lwm cov kev pab kom siv tau qhov kev pab, kev ua num los sis kev pab cuam no, thov hu rau tus xov tooj hauv qab no tam sim no.

CALL TO ORDER / ROLL CALL

APPROVAL OF MINUTES

October 21, 2014: <http://madison.legistar.com/Calendar.aspx>

PUBLIC COMMENT

Three minutes allotted per individual.

DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

PETITION FOR VARIANCE

1. [36196](#) 2701 S. Stoughton Road (C-11-85-2014)
Steve Roloff of R.A. Smith National appealing IBC 507.4. The rule requires that unlimited area building be separated by 60 feet from other buildings. The Variance requested is to allow an existing building to remain that is less than 60 feet away. Both buildings are fully sprinkled. The Variance is supported by the Madison Fire Department.

Attachments: [2701 S Stoughton Rd.pdf](#)

ADJOURNMENT