



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Agenda - Amended

BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

Tuesday, November 22, 2011

12:15 PM

215 Martin Luther King, Jr. Blvd.
Room LL-110 (Madison Municipal Building)

** PLEASE NOTE THIS MEETING HAS BEEN RESCHEDULED TO NOVEMBER 22, 2011
**

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below at least three business days prior to the meeting.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese al número de teléfono que figura a continuación tres días hábiles como mínimo antes de la reunión.

Yog hais tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntawv ua lwm hom ntawv los sis lwm cov kev pab kom siv tau cov kev pab, cov kev ua ub no (activity) los sis qhov kev pab cuam, thov hu rau tus xov tooj hauv qab yam tsawg peb hnuv ua hauj lwm ua ntej yuav tuaj sib tham.

Building Inspection Division, 608-266-4551.

CALL TO ORDER / ROLL CALL

ELECTION OF CHAIR/VICE CHAIR

APPROVAL OF MINUTES

October 18, 2011: <http://legistar.cityofmadison.com/calendar/#current>

PUBLIC COMMENT

Three minutes allotted per individual.

DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

PETITION FOR VARIANCE

1. [24477](#) 901 Woodrow Street (C-11-63-2011)
Jody Shaw of Potter Lawson appealing NFPA 13:8.15.7.1. The rule requires that overlays/soffits which are over 4 feet wide and constructed from combustible materials shall be sprinklered. The Variance requested is to

waive the sprinklers as the exterior soffit is 25 feet in the air. The Madison Fire Department supports the Variance provided the exterior building materials are non-combustible and the soffit is 3/4" exterior sheathing, 20 feet above grade.

Attachments: [901 Woodrow St.pdf](#)

UNFINISHED BUSINESS

2. [24043](#) SUBSTITUTE Creating Section 34.06 and amending Section 1.08(3)(a) of the Madison General Ordinances to prohibit cooking in a careless manner and establishing a bail deposit in violation thereof.

Attachments: [Version 1](#)

ADJOURNMENT