

BPW Meeting January 18, 2012:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

4. N. Frances Street Reconstruction

A City Engineering Erosion Control/Stormwater Management permit has been obtained for this project for grading over 4,000 square feet. A DNR Chapter 30 permit was also obtained for shoreline work. **(Corey Stelljes, City Engineering)**

5. Rosa Road Resurfacing

A City Engineering Erosion Control/Stormwater Management permit is required for grading over 4,000 square feet. **(Max Conway, City Engineering)**

6. Ingersoll/Rutledge Reconstruction

A City Engineering Erosion Control/Stormwater Management permit and a DNR Notice of Intent (for land disturbance over an acre) are required. **(Elia Acosta, City Engineering)**

Prepared By: *Dennis Steinhorst*

Date: *1/13/12*