

Madison Water Utility
Status of Unit Wells Offline for Repairs or Upgrades
6/30/2025

Region	Unit Well	Lost Supply (GPM)	Date Offline	Expected Online	Status of Repair/Replacement
A/B	15	1,400	03/2019	08/2025	Installation of PFAS treatment is on-going; see Capital Projects report
	31	2,200	02/2025	06/2025	Installation of pump in-progress as of 7/16
C	19	2,200	10/2024	08/2025	Installation of iron, manganese, and radium filter is on-going; station operational in mid-August, filters expected to go on-line later

GPM = gallons per minute; 1,000 gpm = 1.44 MGD (million gallons per day)