

BPW Meeting August 18, 2010:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

**4. North Fair Oaks Reconstruction**

This project will disturb over an acre, and so will require a WRAPP from the DNR and a City stormwater/erosion control permit. (LeAnne Hannan, City Engineering)

**11. Debra Lane/Wheeler Road Drainage Assessment District**

This project will disturb over 4,000 square feet but less than an acre and so will only require a City stormwater/erosion control permit. (Corey Stelljes, City Engineering)

**26. Cross Street & Wyota Ave Storm Sewer**

This project will disturb over 4,000 square feet but less than an acre and so will only require a City stormwater/erosion control permit. (Max Conway, City Engineering)

Prepared By: Denesia Steinbrant

Date: 8-18-10