



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4635
www.cityofmadison.com

January 24, 2024

Kevin Burow
Knothe & Bruce Architects
8401 Greenway Boulevard, Suite 900
Middleton, Wisconsin 53562

RE: Consideration of a demolition permit to demolish a commercial building at 15 Ellis Potter Court; and Consideration of a conditional use in the Suburban Employment (SE) District for a multi-family dwelling; and consideration of a conditional use in the SE District for dwelling units in a mixed-use building, all to allow construction of a three-story, 54-unit apartment building; two-story, 11-unit townhouse building; and accessory garage at 1-15 Ellis Potter Court and 6110 Schroeder Road [LNDUSE-2023-00089; IDs [81077](#) and [81078](#)]

Dear Kevin;

At its January 22, 2024 meeting, the Plan Commission **approved** your client's demolition permit and conditional use requests for the project located at 1-15 Ellis Potter Court and 6110 Schroeder Road, subject to the conditions in the following sections, which shall be satisfied prior to issuance of any City permits related to the project:

Please contact Timothy Troester of the City Engineering Division—Main Office at (608) 267-1995 if you have questions regarding the following seventeen (17) items:

1. Proposed development may require offsite sanitary sewer improvements being built by the developer through a developer's agreement as a condition for plan approval. Applicant shall submit project flow calculations to Mark Moder mmoder@cityofmadison.com.
2. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
3. Construct sidewalk, terrace, curb and gutter and pavement to a plan as approved by City Engineer
4. This development is subject to impact fees for the Upper Badger Mill Creek stormwater Impact Fee District. All impact fees are due and payable at the time building permits are issued (MGO Ch 20). Add the following note on the face of the plans: LOTS / BUILDINGS WITHIN THIS DEVELOPMENT ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED.

5. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
6. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
7. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
8. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
9. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
10. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>.

The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.

11. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
12. Revise the plans to show a proposed private internal drainage system on the site. Include the depths and locations of structures and the type of pipe to be used. (POLICY AND MGO 10.29)
13. This area is within a watershed study for flood mitigation and has a known flooding risk. The minimum opening elevations for structures proposed by this application shall have a low entrance elevation that is 1042 or higher. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.

14. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
15. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

16. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

This site is a mix of new and redevelopment and the SWMP will address both conditions.

Rate Control New Development: Detain the 2, 5, 10, 100, & 200 - year storm events, matching post development rates to predevelopment rates and using the design storms identified in Madison General Ordinances Chapter 37.

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10- year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

Infiltration: Provide infiltration of 90% of the pre-development infiltration volume.

TSS New Development: Reduce TSS by 80% (control the 5-micron particle) off of newly developed areas compared to no controls.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

Thermal Control: Provide substantial thermal control to reduce runoff temperature in cold water community or trout stream watersheds.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

17. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Jeff Quamme of the City Engineering Division–Mapping Section, at (608) 266-4097 if you have questions regarding the following seven (7) items:

18. Any portion(s) of the public utility easement per CSM 3534 that is intended to be released shall be released by separate document prepared by City Office of Real Estate Services. Contact Jeff Quamme of Engineering Mapping (jrquamme@cityofmadison.com, 608-266-4097) to coordinate the Real Estate project, and associated information and fees required. Developer / Owner / Consultant are collectively responsible to provide recorded releases from the other utilities serving the area prior to the City of Madison releasing its rights.
19. This proposal is from Horizon Development. The CSM owners signature is BR Real Estate LLC who is the current owner of the lands.

20. The addresses of 1 Ellis Potter Ct and 15 Ellis Potter Ct will be retired and archived with the demolition of the office building and the recording of the proposed CSM. The future building addresses will be determined with the creation of the addressing plan. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
21. It shall be confirmed if the proposed retaining walls along the east side of this site require access over any adjacent lands for the construction, maintenance or support. If any are required over the adjacent lands, provide the appropriate recorded agreement / easement prior to final site plan sign off.
22. Consultant / Owner / Developer are collectively responsible to coordinate the movement and / or easement necessary in conjunction with the communications line along the east line of this site not subject to an easement of record.
23. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction or early start permit.
24. Submit a site plan and a complete set of building Floor Plans (for each individual building) in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate sheet/page for the development of an interior and building addressing plan for the proposed multi-building complex. Each building page should include a key locator and north arrow. Also, include a unit matrix for the apartment buildings.

The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the Verification submittal stage of this LNDUSE with Zoning. The final approved stamped Addressing Plan shall be included in said Site Plan Verification application materials or a revised plan shall provided for additional review and approval by Engineering.

Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department.

For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following thirteen (13) items:

25. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a five (5)-foot wide sidewalk, eight (8)-foot terrace, and additional one (1) foot for maintenance along Ellis Potter Court.

26. The applicant shall be responsible for the construction of a traffic island, marked continental crosswalk, pedestrian ramps, and an RRFB to facilitate pedestrian crossings of Schroeder Road.
27. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
28. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
29. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
30. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
31. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
32. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
33. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
34. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) – Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
35. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheelchair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.

36. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
37. Applicant shall submit for review a waste removal plan. This shall include vehicular turning movements.

Please contact Trent Schultz of the Parking Division at (608) 246-5806 if you have any questions regarding the following item:

38. The applicant shall submit a Transportation Demand Management (TDM) Plan to tdm@cityofmadison.com. The TDM Plan is required per MGO 16.03. Applicable fees will be assessed after the TDM Plan is reviewed by staff.

Please contact Jenny Kirchgatter of the Zoning Division at (608) 266-4429 if you have any questions regarding the following eleven (11) items:

39. Section 28.185(9)(b) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9)(b) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission approval.
40. Provide electric vehicle stalls per Section 28.141(8)(e) Electric Vehicle Charging Station Requirements. A minimum of 10% of the residential parking stalls (10 stalls) must be electric vehicle ready, and a minimum of 2% of the stalls (2 stalls) must be electric vehicle installed. Identify the locations of the electric vehicle ready and installed stalls on the plans.
41. Bicycle parking for the residential dwelling units shall comply with the requirements of MGO Sections 28.141(4)(g) and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 70 resident bicycle stalls are required plus a minimum of 6 short-term guest stalls. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.
42. Bicycle parking for the commercial tenant shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). Provide a minimum of two (2) short-term bicycle parking stalls located in a convenient and visible area on a paved or pervious surface. Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance. Note: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Provide a detail of the proposed bike rack.

43. Distribute some of the short-term resident guest bicycle stalls adjacent to Ellis Potter Ct and the residential lobby entrance on Schroeder Rd.
44. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
45. Verify the location of the refuse disposal area for the townhouse building. All developments, except single family and two family developments, shall provide a refuse disposal area.
46. Submit detailed floor plans and roof plans for the mixed-use building and the townhouse building. Submit the second floor plan for the townhouse building.
47. Verify whether bird-safe glass will be required in compliance with bird-safe glass requirements Section 28.129. For building façades where the first sixty (60) feet from grade are comprised of less than fifty percent (50%) glass, at least eighty-five percent (85%) of the glass on glass areas fifty (50) square feet or over must be treated. Of all glass areas over fifty (50) square feet, any glass within fifteen (15) feet of a building corner must be treated.
48. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
49. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Matt Hamilton of the Madison Fire Department at (608) 266-4457 if you have any questions regarding the following two (2) items:

50. A fire alarm system and/or automatic fire suppression systems are/may be required. Ensure contractors submit applications for work permits along with construction documents for all fire protection and/or life safety systems as specified in MGO 34.02, to the Madison Fire Department for approval prior to installation.
51. Fire lanes shall be unobstructed; there are obstructions shown on the fire lane, remove all obstructions. Examples of obstructions: including but not limited to; parking stalls, loading zones, changes in elevation, power poles, trees, bushes, fences or posts.

Please contact Ann Freiwald of the Parks Division at (608) 243-2848 if you have any questions regarding the following item:

52. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the _West_ Park-Infrastructure Impact Fee district. Please reference ID 24001 when contacting Parks about this project.

Please contact Brandon Sly of the Parks Division–Forestry Section at (608) 266-4816 if you have any questions regarding the following seven (7) items:

53. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
54. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
55. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
56. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
57. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.

58. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.
59. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following two (2) items:

60. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days' notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.
61. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Please contact Tim Sobota, Metro Transit, at (608) 261-4289 if you have any questions regarding the following two items:

62. Metro Transit operates daily all-day transit service along Schroeder Road adjacent this property - with trips at least every 60 minutes (every 30 minutes or less on weekdays).
63. Metro Transit would initially estimate the following counts of potentially eligible trips towards US Green Building Council/LEED Quality Access to Transit points: 33 Weekday & 17 Weekend (average). Please contact Metro Transit if additional analysis would be of interest.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

No interior, exterior or structural demolition or wrecking activities or remodeling activities (including material reclamation activities by the applicant or a third party) shall commence nor any demolition permits be issued until the applicant has met all of the conditions of approval stated in this letter.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; [site plan review fee pursuant to Section 28.206](#) of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at SPRApplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email SPRApplications@cityofmadison.com regarding questions or if you need alternative filing options. The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. The [site plan review fee pursuant to Section 28.206](#) can be mailed in, dropped in the drop box at the Madison Municipal Building, or you can make an appointment at the Zoning counter to pay the fee. Checks should be made out to "City Treasurer." If you mail in the check or use the drop box, please include the application form with the project address and contact information. Zoning staff typically suggest using the drop box or making an appointment with the Zoning counter to pay the fee as they are the quickest.

Mailing Address: City of Madison Building Inspection. P.O. Box 2984. Madison, WI 53701-2984

Drop Box Location: Madison Municipal Building, Doty Street Entrance. 215 Martin Luther King Jr Blvd. Madison, WI 53701-2984

Zoning Counter Appointment: <https://www.cityofmadison.com/dpced/bi/schedule-a-counter-appointment/3423/>

3. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use and demolition permit approval. [Signature block on last page]
4. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
5. Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, (608) 267-4908.
6. A demolition or removal permit is valid for one (2) years from the date of the Plan Commission.
7. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the

conditional use standards. This approval shall become null and void one (2) years after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 12 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your demolition permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

Signature of Property Owner (if not the applicant)

cc: Timothy Troester, City Engineering Division
Jeff Quamme, City Engineering Division–Mapping Section
Sean Malloy, Traffic Engineering Division
Trent Schultz, Parking Division
Jenny Kirchgatter, Zoning Administrator
Matt Hamilton, Fire Department
Ann Freiwald, Parks Division
Brandon Sly, Forestry Division
Jeff Belshaw, Water Utility
Tim Sobota, Metro Transit
Bryan Johnson, Streets Division
Jessica Vaughn, Urban Design Commission

LNDUSE-2023-00089

For Official Use Only, Re: Final Plan Routing

☒	Planning Div. (Wells)	☒	Engineering Mapping Sec.
☒	Zoning Administrator	☒	Parks Division
☒	City Engineering	☒	Urban Design Commission
☒	Traffic Engineering	☒	Recycling Coord. (R&R)
☒	Fire Department	☒	Water Utility
☒	Metro Transit	☒	Other: Forestry