



Department of Planning & Community & Economic Development

Planning Division

Katherine Cornwell, Director

Madison Municipal Building, Suite LL-100

215 Martin Luther King, Jr. Boulevard

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

Fax (608) 267-8739

www.cityofmadison.com

March 25, 2014

Matt Tills
Tills Architecture
2501 Balden Street
Madison, WI 53713

RE: Approval of a Conditional Use to establish a restaurant with an outdoor eating area at **829 East Washington Avenue**

Dear Mr. Tills:

At its March 24, 2014 meeting, the Plan Commission, meeting in regular session, approved your client's request to establish a restaurant with an outdoor eating area at 829 East Washington Avenue. In order to receive final approval of the conditional use and for permits to be issued, the following conditions must be met:

Please contact Janet Dailey, Engineering Division at 261-9688 if you have questions regarding the following six (6) items:

1. Show all easements of record on the site plan. City Engineering staff is aware of a 10, right of way to MG&E along the rear of this property per Doc. No. 3374205.
2. The site plan shall identify lot and block numbers of recorded Certified Survey Map or Plat.
3. The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing and proposed utility locations and landscaping.
4. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
5. The site plan shall include a full and complete legal description of the site or property being subjected to this application.
6. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set (POLICY and MGO 37.09(2)). PDF submittals shall contain the following information:
 - a) Building footprints.
 - b) Internal walkway areas.

- c) Internal site parking areas.
- d) Lot lines and right-of-way lines.
- e) Street names.
- f) Stormwater Management Facilities.
- g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

Please contact Eric Halvorson, Traffic Engineering at 266-6527 if you have questions regarding the following four (4) items:

- 7. The applicant shall submit one contiguous plan for approval. The plan drawing shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
- 8. The developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
- 9. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
- 10. All parking facility design shall conform to MGO standards, as set in section 10.08(6).

Please contact Patrick Anderson, Assistant Zoning Administrator at 266-5978 if you have questions regarding the following five (5) items:

- 11. Meet applicable building/fire codes. The outdoor capacity shall be established. Occupancy is established by the Building Inspection Unit. Contact Mike VanErem at 266-4559 to help facilitate this process.
- 12. Bike parking shall comply with City of Madison General Ordinances Table 28I-3 (General Regulations). Provide the minimum bike parking stalls for said uses. Bicycle parking design and location shall comply with Sec. 28.141 (11) of the City of Madison General Ordinances. Provide details on final plans, a bike-parking stall is two feet by six feet with a five-foot access area.
- 13. Shall comply with supplemental regulations for outdoor eating areas associated with food and beverage establishments section 28.151 of the City of Madison General Ordinances.
- 14. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances prior to sign installations.

15. If outdoor lighting is provided, it must comply with City of Madison General Ordinances Section 10.085 outdoor lighting standards.

Please contact Bill Sullivan, Madison Fire Department at 261-9658 if you have questions regarding the following item:

16. The Madison Fire Department does not object to this proposal provided the project complies with all applicable fire codes and ordinances.

Please contact Kay Rutledge, Parks Division at 266-4816 if you have questions regarding the following two (2) items:

17. Existing street trees shall be protected. Please include the following note on the site plan:
Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266-4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction -
<http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part1.pdf>
Please reference ID# 14111 when contacting Parks about this project.
18. Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816.

Please contact my office at 267-1150 if you have questions regarding the following item:

19. The revised internal courtyard (with reduced capacity) and façade drawings were provided on March 19, 2013 and provided to the Plan Commission. These revised sheets have not been reviewed by City Agencies. Approval of the revised sheets by the Plan Commission is subject to additional comments by reviewing agencies on their review of this supplemental information.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:

1. Please revise your plans per the above conditions and submit ten (10) copies of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.

2. This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use, demolition or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 267-1150.

Sincerely,

Kevin Firchow, AICP
 Planner

cc: Janet Dailey, City Engineering Division
 Eric Halvorson, Traffic Engineering Division
 Bill Sullivan, Fire Department
 Patrick Anderson, Zoning

I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional use.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Firchow)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: