

BPW Meeting November 2, 2011:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

5. West Lakelawn Place Assessment District

This project will require an Erosion Control permit from the City of Madison and weekly self-inspection but does not require a WDNR permit, as it does not exceed one acre of land disturbance. **(Corey Stelljes, Engineering)**

Prepared By: Genesis Stelljes

Date: 11/2/11