



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Agenda - Amended

BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

Tuesday, May 17, 2016

12:15 PM

215 Martin Luther King, Jr. Blvd.
Room LL-110 (Madison Municipal Building)

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below immediately.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese inmediatamente al número de teléfono que figura a continuación.

Yog tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntaub ntawv ua lwm yam los sis lwm cov kev pab kom siv tau qhov kev pab, kev ua num los sis kev pab cuam no, thov hu rau tus xov tooj hauv qab no tam sim no.

Building Inspections, (608) 266-4551

CALL TO ORDER / ROLL CALL

APPROVAL OF MINUTES

April 19, 2016: <http://madison.legistar.com/Calendar.aspx>

PUBLIC COMMENT

DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

PETITION FOR VARIANCE

- 1 [42908](#) 22 S Carroll St (C-05-21-2016)
Destree Design Architects appealing 2009 IBC Section 3004. The rule requires that elevator hoistways be vented. The 2015 Fire Code does not require venting. The variance requested is to use the current version of the code. The Madison Fire Department supports the variance

Attachments: [22 S Carroll St.pdf](#)

NEW BUSINESS

- 2 [42475](#) Amending Section 17.04, 17.11 creating Section 17.13 and renumbering

Section 17.13 to Section 17.14 of the Madison General Ordinances to require the removal of unused antenna systems from buildings and increase the penalty for violation thereof.

ADJOURNMENT