



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Meeting Minutes - Approved BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

Tuesday, May 17, 2016

12:15 PM

215 Martin Luther King, Jr. Blvd.
Room LL-110 (Madison Municipal Building)

CALL TO ORDER / ROLL CALL

Glueck called the meeting to order at 12:15.

Staff present: Harry Sulzer, Bill Sullivan

Present: 6 - James I. Glueck; Richard J. Link; Sam J. Breidenbach; Craig E. Brown;
Louis J. Olson and Randall V. Baldwin

Excused: 2 - John P. Starkweather and Rick W. Hext

APPROVAL OF MINUTES

A motion was made by Link to approve the April 19, 2016 minutes, seconded by Breidenbach. The motion passed by voice vote/other.

PUBLIC COMMENT

DISCLOSURES AND RECUSALS

PETITION FOR VARIANCE

- 1 [42908](#) 22 S Carroll St (C-05-21-2016)
Destree Design Architects appealing 2009 IBC Section 3004. The rule requires that elevator hoistways be vented. The 2015 Fire Code does not require venting. The variance requested is to use the current version of the code. The Madison Fire Department supports the variance

Attachments: [22 S Carroll St.pdf](#)

The vents are a hazzard and create a chimney effect by pulling fire into the shaft.

Breidenbach moved, Baldwin seconded to approve the variance. The motion passed unanimously by voice vote/other.

NEW BUSINESS

- 2 [42475](#) Amending Section 17.04, 17.11 creating Section 17.13 and renumbering Section 17.13 to Section 17.14 of the Madison General Ordinances to require the removal of unused antenna systems from buildings and increase the penalty for violation thereof.

Breidenbach moved, Brown seconded to recommend adoption of the changes. The motion passed unanimously by voice vote/other.

ADJOURNMENT

The meeting adjourned at 12:30