MADISON WATER UTILITY

Watch List Summary - October 2025

Number of Contaminants Above 50% of a Drinking Water Regulation (MCL) or Guideline (SMCL)

| ACTIVE WELLS | 50% - 80% MCL | 80% - 100% MCL | >MCL | Contaminant: Action Plan |
|--------------|---------------|----------------|------|---------------------------------------|
| Well 07 | 1 | | | Radium: Monitor |
| Well 18 | 1 | | | VOC (PCE): Monitor |
| Well 24 | 1 | | | Radium: Monitor |
| Well 27 | | 1 | | Radium: Vertical Flow Profile Planned |
| Well 28 | 1 | | | Radium: Monitor |
| Well 30 | 1 | | | Radium: Monitor |

| ACTIVE WELLS | 50% - 80% SMCL | 80% - 100% SMCL | >SMCL | Contaminant: Action Plan |
|--------------|----------------|-----------------|-------|---------------------------------------------------------------------|
| Well 06 | 1 | | | Sodium: Monitor |
| Well 14 | | 1 | 1 | Sodium : Investigation & Well Remediation Complete; Chloride |
| Well 16 | 1 | | | Sodium: Monitor |
| Well 17 | 1 | | | Manganese: Monitor |
| Well 18 | 1 | | | Manganese: Monitor |
| Well 24 | 1 | 1 | | Iron and Manganese: Monitor |
| Well 27 | 2 | | | Manganese: Monitor |
| Well 28 | 1 | | | Iron: Monitor |
| Well 30 | 1 | | | Iron: Monitor |

ACTIVE WELLS

Limited or No Water Quality Impact (Contaminants Below 50% MCL or SMCL)

Well 09, Well 11, Well 12, Well 13, Well 20, Well 25, Well 26, Well 29, Well 31

INACTIVE WELLS

Temporarily Out of Service Due to Water Quality Issue

| Well 08 | 1 | | 2 | Iron and Manganese; Radium |
|---------|---|---|---|-----------------------------------------------------------------|
| Well 19 | 2 | 1 | | Iron, Manganese & Radium: Treatment Plant Under Construction |

TOTAL 17 4 3

KEY:

MCL = Maximum Contaminant Level: enforceable, health-based standard

SMCL = Secondary MCL: non-enforceable guideline based on aesthetics (taste, odor, or appearance)

[^] Assessment is after any treatment and at point of entry to distribution system; based on 2025 test results