




**Neighborhood Preservation & Inspection Division**  
 215 Martin Luther King, Jr. Boulevard  
 P.O. Box 2984  
 Madison, WI 53701-2984

**POSITION STATEMENT:**  
 To be completed by Fire Marshall

NAME OF OWNER Cedric Hodo	BUILDING OCCUPANCY OR USE Group E Education	AGENT, ARCHITECT OR ENGINEERING FIRM Eppstein Uhen Architects
COMPANY Madison Metropolitan School District	TENANT NAME, IF ANY West High School	NO. & STREET 309 W Johnson Street, Suite 202
NO. & STREET 4711 Pflaum Road	BUILDING LOCATION, NO. & STREET 30 Ash Street	CITY, STATE, ZIP CODE Madison, WI 53703
CITY, STATE, ZIP CODE Madison, WI 53718	CITY, COUNTY Madison, DANE	PHONE 414-298-2240
1. I have read the petition for variance of rule: IBC 903.3.1.1.1.		
2. I RECOMMEND (check appropriate box): <input type="checkbox"/> Denial <input type="checkbox"/> Approval <input checked="" type="checkbox"/> Conditional Approval <input type="checkbox"/> No Comment*		
3. Explanation for Recommendation:  Fire sprinkler omission is only applicable to the area directly over the swimming pool itself. Any changes to how the swimming pools is used may require the addition of fire sprinklers.		
*If desired, Fire Departments may indicate "No Comment" on non-fire safety issues such as sanitary, energy conservation, structural, barrier free environments, etc.		
4. <input type="checkbox"/> I find no conflict with local rules and regulations. <input type="checkbox"/> I find that the petition is in conflict with local rules and regulations.		
Explanation		
Signature of Fire Chief 		Date January 11, 2022

Please complete and submit promptly to the Neighborhood Preservation & Inspection Division at the address shown above.