



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

****BY E-MAIL ONLY****

November 4, 2022

Marc Schellpfeffer
CaS4 Architecture, LLC
4414 Regent St, Suite 102
Madison, WI 53705

RE: Consideration of a demolition permit to demolish three residential buildings located at 117, 123 and 125 North Butler Street; consideration of a zoning map amendment to change the zoning for 117, 119, 123 and 125 North Butler Street from DR-1 (Downtown Residential 1) District to DR-2 (Downtown Residential 2) District; consideration of a conditional use in the DR-2 District for a multi-family dwelling with more than eight (8) dwelling units; and consideration of a Certified Survey Map (CSM) to create one lot for the proposed multi-family building (ID [73363](#), [73643](#), [73364](#), & [73373](#), LNDUSE-2022-00079)

Dear Marc Schellpfeffer:

On October 24, 2022, the Plan Commission found the standards met and **conditionally approved** your demolition permit and conditional use for 117-125 North Butler Street. On November 1, 2022, the Common Council found the standards met and **conditionally approved** your certified survey map and zoning map amendment for 117-125 North Butler Street. In order to receive final approval of the conditional use and for any other permits that may need to be issued for your project, the following conditions shall be met:

Land Use Request – Zoning Map Amendment, Demolition Permit, Conditional Uses

Please contact Lisa McNabola of the Planning Division at (608) 243-0554 if you have any questions regarding the following one (1) item:

1. No HVAC “wall-pack” penetrations/louvers are shown on the street-facing facades. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing walls is not included in this approval and will require approval of an alteration to this conditional use should they be approved at a later time.
2. Per the zoning conditions the applicant shall eliminate the composite lap siding from the ground floor elevations. Wood and fiber cement panels shall not be used on the ground story except between the sidewalk and the bottom of storefront windows or as an accent material. The Planning Division shall approve the updated building elevations.

3. That the demolition of 117 N Butler Street and 123 N Butler Street not occur for at least 60 days following approval, so as to allow time for interested parties to consider possibilities for relocating one or more structures. Should relocation occur, the applicant is encouraged to contribute the estimated cost of demolition toward the relocation expenses.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following eleven (11) items:

4. Remove the pergola from the rooftop terrace. The maximum building height is four (4) stories. The pergola structure exceeds the 4 story maximum height limit.
5. Eliminate the composite lap siding from the ground floor elevations. Wood and fiber cement panels shall not be used on the ground story except between the sidewalk and the bottom of storefront windows or as an accent material.
6. Section 28.185(9) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
7. Update the Usable Open Space exhibit to remove the areas within the side yard setback that are less than 8 feet wide and the at-grade areas less than 200 sq. ft. in area. Usable open space located at ground level shall be in a compact area of not less than two hundred (200) square feet, with no dimension less than eight (8) feet and no slope grade greater than ten percent (10%). Usable open space shall be located outside of the required front yard setback. Usable open space shall not include areas occupied by buildings, driveways, drive aisles, off-street parking, paving and sidewalks, except that paved paths no wider than five (5) feet and pervious pavement may be included as usable open space.
8. Parking requirements for persons with disabilities must comply with MGO Section 28.141(4)(e) which includes all applicable State accessible requirements. The van accessible stall shall be striped per State requirements. A van accessible stall is a minimum of 8 feet wide with an 8 foot wide striped access area adjacent.
9. Provide electric vehicle stalls per Section 28.141(8)(e) Electric Vehicle Charging Station Requirements. A minimum of 10% of the residential parking stalls (2 stalls) must be electric vehicle ready. Identify the locations of the electric vehicle ready stalls on the plans.
10. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.

11. Provide details demonstrating compliance with bird-safe glass requirements Section 28.129. For building façades where the first sixty (60) feet from grade are comprised of less than fifty percent (50%) glass, at least eighty-five percent (85%) of the glass on glass areas fifty (50) square feet or over must be treated. Of all glass areas over fifty (50) square feet, any glass within fifteen (15) feet of a building corner must be treated. All glass railings must be treated. Identify which glass areas are 50 sq. ft. or greater and which glass areas will be treated. Provide a detail of the specific treatment product that will be used.
12. Provide details showing that the street-facing façade meets the door and window opening requirements of Section 28.071(3)(e). For street-facing facades with ground story residential uses, ground story openings shall comprise a minimum of fifteen percent (15%) of the façade area. Upper story openings shall comprise a minimum of fifteen (15%) of the façade area per story.
13. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
14. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Tim Troester of the Engineering Division at (608) 267-1995 if you have any questions regarding the following fifteen (15) items:

15. All storm sewer discharge shall be directed to the ROW not to the back yard and onto other private property.

16. Obtain a permit to Excavate in the Right-of-Way for completing the improvements in the public Right-of-Way. The permit application is available on the City Engineering Division website at <http://www.cityofmadison.com/engineering/Permits.cfm>. As a condition of the permit a deposit to cover estimated City expenses will be required.
17. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
18. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
19. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.

20. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
21. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
22. This site appears to disturb less than one (1) acre of land. No submittal to the WDNR, CARPC or Department of Safety and Professional Services (DSPS) is required as the City of Madison Building Inspection Department is an approved agent for DSPS.
23. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
24. Revise the plans to show a proposed private internal drainage system on the site. Include the depths and locations of structures and the type of pipe to be used. (POLICY AND MGO 10.29)
25. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
26. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
27. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE and therefore will be regulated to meet a higher standard.
28. This project will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval. The permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>. Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>
29. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm

Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10- year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

Please contact Bradley Hofmann of the Forestry Division at (608) 267-4908 if you have any questions regarding the following eight (8) items:

30. All An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apperatus and street tree plan sets. The inventory shall include the following: location, size (diamater at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
31. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
32. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.
33. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.
34. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
35. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.

36. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
37. The Developer shall post a security deposit prior to the start of the development to be collected by City Engineering as part of the Developers Agreement. In the event that street trees are damaged during the construction process, City Forestry will draw from this deposit for damages incurred.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following fifteen (15) items:

38. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
39. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
40. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
41. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
42. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
43. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
44. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at

Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.

45. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
46. All parking ramps as the approach the public Right-of-Way shall not have a slope to exceed 5% for 20 feet; this is to ensure drivers have adequate vision of the Right-of-Way. If applicant believes public safety can be maintained they shall apply for a waiver, approval or denial of the waiver shall be the determination of the City Traffic Engineer.
47. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
48. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
49. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
50. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
51. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
52. The proposed driveway may not encroach across the northerly property line, including the 5' driveway flares. The location of the driveway in relation to the existing property line shall be shown and noted on the plan.

Please contact William Sullivan of the Fire Department at (608) 886-4691 if you have any questions regarding the following three (3) items:

53. Provide aerial access lanes for buildings over 30-ft in height.
54. MFD does not support grills located in close proximity to combustible construction, including overhead pergolas without fire sprinkler protection.

55. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Jeff Larson at jtlarson@cityofmadison.com or (608) 266- 5946.

Please contact Ann Freiwald of the Parks Division at (608) 243-2848 if you have any questions regarding the following one (1) item:

56. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the North Park-Infrastructure Impact Fee district. Please reference ID# 22031 when contacting Parks about this project.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following two (2) items:

57. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.
58. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Please contact Julius Smith of the Engineering Division – Mapping Section at (608) 264-9276 if you have any questions regarding the following four (4) items:

59. The address of the proposed apartment is 121 N Butler St.
60. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
61. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction or early start permit.
62. Submit a site plan and a complete building Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate

sheet/page for the development of a complete interior addressing plan. Also, include a unit matrix for apartment buildings.

The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the verification submittal stage of this LNDUSE with Zoning. The final approved stamped Addressing Plan shall be included in said Site Plan Verification application materials or a revised plan shall be provided for additional review and approval by Engineering.

Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department.

For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

The following agencies reviewed the request and recommended no conditions of approval: Metro Transit

Land Division Request

Please contact Julius Smith of the Engineering Division – Mapping Section at (608) 264-9276 if you have any questions regarding the following nine (9) items:

63. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction or early start permit.

64. Madison Revise the note regarding the Access Easement per Doc. No. 1674243 adding text that the easement is extinguished per the Doctrine of Title Merger with common ownership of the benefitting lands.

65. Remove Note 1 on sheet 2. There are not any underlying drainage easements of record.

66. Wisconsin Administrative Code A-E 7.08 identifies when Public Land System (PLS) tie sheets must be filed with the Dane County Surveyor's office. The Developer's Surveyor and/or Applicant must submit copies of required tie sheets or monument condition reports (with current tie sheet attached) for all monuments, including center of sections of record, used in this survey, to Jeff Quamme, City Engineering (jrquamme@cityofmadison.com)

67. Prior to Engineering final sign-off by main office for Plats or Certified Survey Maps (CSM), the final Plat or CSM in pdf format must be submitted by email transmittal to Engineering Land Records Coordinator Jeff Quamme (jrquamme@cityofmadison.com) for final technical review and approval. This submittal must occur a minimum of two working days prior to final Engineering Division sign-off.

68. In note 8 on sheet 2 there is text that is very thin to greyscale that needs to be changed to be bolder.

69. The Owner's Certificates have text "dedication and mapping" that should be revised to read "dedicated and mapped".
70. The legal description under the Surveyor's Certificate shall after commencing at the section corner it shall proceed to the monumented meander corner and then continue from there. Also the course of N46-04-04E shall be revised to N46-04-03E to match the map. Lastly provide calls to the northeasterly lines of the lots and to the right of way of N. Butler Street when following those lines.
71. Submit to Jeff Quamme, prior to Engineering sign-off of the subject plat, one (1) digital CADD drawing in a format compatible with AutoCAD. The digital CADD file(s) shall be referenced to the Dane County Coordinate System and shall contain, at minimum, the list of items stated below, each on a separate layer/level name. The line work, preferably closed polylines for lot lines, shall be void of gaps and overlaps and match the final recorded plat:
 - a. Right-of-Way lines (public and private)
 - b. Lot lines
 - c. Lot numbers
 - d. Lot/Plat dimensions
 - e. Street names
 - f. Easement lines (i.e. all shown on the plat including wetland & floodplain boundaries.)

NOTE: This Transmittal is a separate requirement from the required Engineering Streets Section for design purposes. The Developer/Surveyor shall submit new updated final plat, electronic data for any changes subsequent to any submittal.

Please contact Tim Troester of the Engineering Division at (608) 267-1995 if you have any questions regarding the following two (2) items:

72. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
73. A minimum of two (2) working days prior to requesting City Engineering signoff on the plat/csm contact either Tim Troester (West) at 261-1995 (ttroester@cityofmadison.com) or Brenda Stanley (East) at 608-261-9127 (bstanley@cityofmadison.com) to obtain the final stormwater utility charges that are due and payable prior to sub-division of the properties. The stormwater utility charges (as all utility charges) are due for the previous months of service and must be cleared prior to the land division (and subsequent obsolesces of the existing parcel). (POLICY)

Please contact Ann Freiwald of the Parks Division at (608) 243-2848 if you have any questions regarding the following three (3) items:

74. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the North Park-Infrastructure Impact Fee district. Please reference ID# 22031 when contacting Parks

75. The following note should be included on the CSM: "LOTS WITHIN THIS SUBDIVISION ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED."

76. The Parks Division shall be required to sign off on this CSM.

The following agencies reviewed the request and recommended no conditions of approval: Fire Department, Forestry Division, Metro Transit

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.


Please now follow the procedures listed below for obtaining your demolition permit:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.

2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0554 or lmcnabola@cityofmadison.com.

Sincerely,



Lisa McNabola
Planner

cc: Jenny Kirchgatter, Asst. Zoning Administrator
Julius Smith, Mapping Section
Tim Troester, Engineering Division
Sean Malloy, Traffic Engineering
Jeff Belshaw, Water Utility
William Sullivan, Fire Department
Ann Freiwald, Parks Division
Bradley Hofmann, Forestry Section

I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional uses.

Signature of Applicant

Signature of Property Owner (if not the applicant)

LNDUSE-2022-00079			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div.	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry Section