



NOTE: Available fire flow based on the demand at hour 85 of a Maximum 10-Day scenario and is equivalent to Maximum Day demand.

Legend			
Pipe Diameter	Fire Flow Criteria	Junction Fire flow Category	Other Symbols
8 inch or less	0 gpm	Available Flow > Criteria	■ Floating Storage
10 - 14 inch	1,000 gpm	Available Flow 75% - 99% Criteria	● Booster Pump Station
16 inch and greater	2,000 gpm	Available Flow 50% - 74% Criteria	▲ Well
	2,500 gpm	Available Flow < 50% Criteria	--- Pressure Zone Boundary
	3,500 gpm		— Streets

0 0.5 1 Miles

Figure B12
2015 East Side
Maximum Day
Fire Flow Availability