



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

215 Martin Luther King Jr. Boulevard

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

Fax (608) 267-8739

www.cityofmadison.com

April 23, 2019

Brad Koning
Sketchworks Architecture, LLC
7780 Elmwood Avenue
Middleton, WI 53562

RE: Legistar #54406; Accela ID: 'LNDUSE-2019-00006' -- Approval of a Conditional Use to construct a multi-tenant commercial building in a planned multi-use site within Urban Design District #5 at 4706 East Washington Avenue.

Dear Mr. Koning:

At its April 22, 2019 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your conditional use request to construct a multi-tenant commercial building in a planned multi-use site within Urban Design District #5 at **4706 East Washington Avenue**, subject to the conditions below. In order to receive final approval of the conditional use, and for any permits to be issued for your project, the following conditions shall be met:

Please contact Brenda Stanley of the Engineering Division at (608) 261-9127 if you have any questions regarding the following thirteen (13) items:

1. This site shall be required to direct its runoff to the public ROW. No drainage onto adjacent private property shall be allowed without a recorded private easement.
2. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO16.23(9)(d)(4))
3. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
4. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE. The project will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR in order to comply with TMDL limits.
5. The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal

can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number: a) Building Footprints b) Internal Walkway Areas c) Internal Site Parking Areas d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.) e) Right-of-Way lines (public and private) f) Lot lines or parcel lines if unplatted g) Lot numbers or the words unplatted h) Lot/Plat dimensions i) Street names j) Private on-site sanitary sewer utilities (including all connections to public sanitary) k) Private on-site storm sewer utilities (including all connections to public storm) All other levels (contours, elevations, etc) are not to be included with this file submittal. NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

6. The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2)) PDF submittals shall contain the following information: a) Building Footprints b) Internal Walkway Areas c) Internal Site Parking Areas d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.) e) Right-of-Way lines (public and private) f) Lot lines or parcel lines if unplatted g) Lot numbers or the words unplatted h) Lot/Plat dimensions i) Street names j) Stormwater Management Facilities k) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).
7. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including: a) SLAMM DAT files b) RECARGA files c) TR-55/HYDROCAD/Etc d) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. (POLICY and MGO 37.09(2))
8. Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project. Include copies of all stormwater, utility, and detail plan sheets that contain stormwater practices on 8.5x14 size paper in the draft document. These drawings do not need to be to scale as they are for informational purposes only. Once City Engineering staff have reviewed the draft document and approved it with any required revisions submit a signed and notarized original copy to City Engineering. Include a check for \$30.00 made out to Dane County Register of Deeds for the recording fee. City Engineering will forward the document and fee for recording at the time of issuance of the stormwater management permit. Draft document can be emailed to Tim Troester (west) at ttroester@cityofmadison.com, or Daniel Olivares at DAOlivares@cityofmadison.com final document and fee should be submitted to City.
9. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION)

10. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to Reduce TSS by 80% off of the proposed development when compared with the existing site.
11. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to provide infiltration in accordance with Chapter 37 of the Madison General Ordinances.
12. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to detain the 2, 10, & 100 -year storm events, matching post development rates to predevelopment rates.
13. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. (MGO 16.23(9)(d)(6)) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

Please contact Jeffery Quamme of the Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following three (3) items:

14. Provide the recorded copy of the Joint Access Easement/Agreement for the joint driveway access over the adjacent property to the southwest located at 4630 E. Washington Avenue.
15. Provide the recorded copy of the Private Storm Water Management, stairs and retaining wall Easement/Agreement for the proposed stormwater management facilities, stair improvements and retaining wall located and over the lot line on the site located at 4630 E. Washington Avenue.
16. Tenant space labeled as 103 has an address of 4702 E Washington Ave. Tenant space labeled as 102 has an address of 4704 E Washington Ave. The larger Tenant space labeled as 101 has an address of 4706 E Washington Ave. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following nine (9) items:

17. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
18. The Developer shall post a security deposit prior to the start of development. In the event that

modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.

19. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
20. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
21. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
22. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
23. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
24. "Stop" signs shall be installed at a height of seven (7) feet at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
25. Developer shall provide a recorded copy of any joint driveway ingress/egress and crossing easements and shall be noted on face of plan.

Please contact Jenny Kirchgatter, the Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following seven (7) items:

26. Show the east side yard setback distance on the site plan.
27. As each tenant space is leased, the entire development must reflect compliance in the required number of bicycle parking spaces, to be reviewed prior to obtaining zoning approval for each use. Submit a detail of the proposed bike rack.
28. Submit an overall landscape plan for 4630 and 4706 E Washington Ave. There are inconsistencies between the existing site at 4630 E Washington Ave and the approved landscape plan for the site. The landscape plan and landscape worksheet shall be stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
29. Provide details showing that the primary street façade meets the door and window opening requirements of Section 28.060(2)(d). For nonresidential uses at ground floor level, windows and doors or other openings shall comprise at least sixty percent (60%) of the length and at least forty percent (40%) of the area of the ground floor of the primary street facade. At least fifty percent (50%)

of windows on the primary street facade shall have the lower sill within three (3) feet of grade. Glass on windows and doors shall be clear or slightly tinted, allowing views into and out of the interior. Spandrel glass that mimics the appearance of windows may be used for up to twenty percent (20%) of the required area of the openings.

30. On the rooftop plan, show the location of any proposed rooftop mechanical equipment and screening. Provide a detail or profile demonstrating that rooftop mechanical equipment will not be visible to view above the height of the parapets. All rooftop equipment shall be screened from view from adjacent streets and public rights-of-way per Sections 28.060(2)(f) and 28.142(9)(d). Screens shall be of durable, permanent materials that are compatible with the primary building materials.
31. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
32. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Bill Sullivan at (608) 261-9658 if you have any questions regarding the following item:

33. Based on the preliminary architectural plans, a restaurant or other assembly use would not be permitted.

Please contact Adam Wiederhoeft at (608) 266-9121 if you have any questions regarding the following two (2) items:

34. The proposed development may require the installation of a fire protection/automatic sprinkler system depending on occupancy/intended use (see also Madison Fire Department review comments); subsequently, a higher capacity water service lateral may be required to meet required flow rates. If a new water service will be required, contact Madison Water Utility Engineering Section to evaluate service connection options, confirmation of water meter size, or any applicable customer account revisions.
35. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact Janine Glaeser, the Urban Design Commission Secretary at (608) 267-8740 if you have any questions regarding the following two (2) items:

36. Encourage the applicant to prohibit tenants from blocking windows per the glazing requirements in MGO §28.060(2)(d).
37. Add a stairway on East Washington Avenue, widen the stairs on the western side of the building, and use oak trees in the rear rather than serviceberry trees.

Please contact my office at (608) 243-0554 if you have any questions regarding the following item:

38. The proposed building shall conform to the design standards for door and window openings per MGO §28.060(2)(d).

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:

1. Please revise your plans per the above conditions and submit **eight (8) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, 215 Martin Luther King Jr. Boulevard. **This submittal shall all also include one complete digital plan set in PDF format.** The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if I may be of any further assistance,

please do not hesitate to contact my office at (608) 243-0554.

Sincerely,



Sydney Prusak
Planner

cc: Brenda Stanley, Engineering
Jeffery Quamme, Engineering Mapping
Sean Malloy, Traffic Engineering
Jenny Kirchgatter, Zoning
Bill Sullivan, Fire Department
Adam Wiederhoeft, Water Utility
Janine Glaeser, Urban Design Commission

I hereby acknowledge that I understand and will comply with the above conditions of approval for the conditional use permit.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
☒	Planning Div. (Prusak)	☒	Engineering Mapping Sec.
☒	Zoning Administrator	☐	Parks Division
☒	City Engineering	☒	Urban Design Commission
☒	Traffic Engineering	☐	Recycling Coord. (R&R)
☒	Fire Department	☐	Metro Transit
☒	Water Utility		