

# Streatery Extension of Premises

Fee: Waived

Class A: ☐ Beer, ☐ Liquor, ☐ Cider

Class B: ☒ Beer, ☒ Liquor,

☐ Class C Wine

City of Madison Clerk

210 MLK Jr Blvd, Room 103

Madison, WI 53703

[licensing@cityofmadison.com](mailto:licensing@cityofmadison.com)

608-266-4601

(Agenda Item Number)

(Legistar file number)

(License number)

(Alder District #)

(Police Sector)

Office Use Only

Streatery extension of premises is available for existing licensed premises only. Extensions will not be granted for vertical drinking or beer garden additions. Application must be submitted to the Clerk's office. Staff will review the application and if it is complete and approved by Zoning and/or the street vending coordinator, provisionally approve and forward to the Alcohol License Review Committee for final approval recommendation. Any licensed establishment applying to extend their premises onto City property must provide a certificate of insurance for liquor liability including a separate additional insured endorsement naming the City of Madison with this application.

Are you requesting this temporary extension of licensed premises, in compliance with Emergency Order Resolution Legistar #60695 (Madison Streatery Program), adopted by the Common Council on June 16, 2020?: ☒ Yes ☐ No

Required detailed floor plans of extension area **included**: ☐ Yes

Required approval of expanded eating area obtained from Street Vending Coordinator or Zoning Administrator **included**: ☒ Yes, date approved: 6/19/2020

Street Occupancy Permit obtained from Traffic Engineering: ☐ Yes ☐ No ☒ N/A

Does lease/deed cover area request for temporary extension?: ☒ Yes ☐ No

If no, **must attach** letter from landlord or property owner authorizing use of the property.

## Licensed Premises Information

This application modifies existing alcohol license number: 64643-64558

Business dba Name: DOTTY DUMPLING'S POWRY

Licensed Address: 317 N. FRANCES, MADISON, WI 53703

Liquor/Beer Agent Name: RACHAEL ZERNER

30 % Alcohol, 70 % Food, - % Other Alder, District #: VERVEER, 4 Police Sector: CENTRAL

## Corporate Information

Business Legal Name (as on WI State Sellers Permit): DOTTY DUMPLING'S POWRY LTD.

Business Mailing Address: 317 N. FRANCES ST., MADISON, WI 53703


Business Contact Name, Position: RACHAEL ZERNER - OWNER

Business Phone: (608) 259-0000 Business Email: RACHAEL@DOTTYDUMPLINGSDOWRY.COM

-Continue on Back-

**Extension Details**Current Capacity (indoor): 118Current Capacity (outdoor): 0Proposed Capacity (outdoor): 50

Description of Proposed Changes: CONSTRUCTION OF TEMPORARY FENCING FOR OUTDOOR PATIO  
FOR FULL-SERVICE. INTEND TO OFFER SOME ON-PREMISE BEVERAGE OPTIONS.

**Signature**  
Authorized Signature of Agent or Establishment Owner6/24/2020  
Date**Clerk's Office checklist for complete applications**

- ☐ Floor Plans
- ☐ Copy of approval from Street Vending/Zoning
- ☐ Copy of Street Occupancy Permit included *if applicable*
- ☐ Letter from landlord/property owner authorizing temporary extension of lease area *if applicable*
- ☐ Certificate of Insurance for liquor liability with City of Madison named *if extending on city property*

**Upon Application Submission, the Clerk's Office issued to the application:**

- ☐ Orange sign    ☐ Orange business card
- ☐ "License Renewals & Changes" brochure with next steps issued





## City of Madison Site Plan Verification

**PROJECT:** LNDSPR-2020-00057

**Address:** 317 N Frances ST

**Current Revision #:** 0

**Submitted by:** Dotty Dumpling's Dowry

**Contact:** Ryan Zerwer  
(608) 338-5403  
ryan@dotteddumplingsdowry.com

**Project Type:** Permitted Use Site Plan Review

**Description:** Temporary Outdoor Seating for Restaurant-tavern, valid until October 25, 2020

**Status:** Approved

**Revision History:** [0](#)

Review	Status	Reviewer	Reviewed
Fire Review	Approved	<a href="#">William Sullivan</a>	Jun 19 2020
Traffic Engineering Review	Approved	<a href="#">Timothy Stella</a>	Jun 12 2020
Zoning Review	Approved	<a href="#">Matthew Tucker</a>	Jun 19 2020

### FIRE

**Supplement Accepted**

**Comment Date:** 06/10/2020

Provide a detail of the seating arrangement, the location of any exit doors, and the exit path out to the public way. 72-inch aisles provided between tables and a minimum of 24-inch clear width between table seating and adjoining fence. A minimum 36-inch clear path shall be maintained between the 72-inch aisles and the 36-inch exits.

**Note**

**Comment Date:** 06/19/2020

The maximum occupant load of the outdoor seating shall not exceed 50 people.

### TRAFFIC ENGINEERING

**Supplement Accepted**

**Comment Date:** 06/11/2020

Email a revised electronic copy of the site plan, .pdf preferred, to Tim Stella - [tstella@cityofmadison.com](mailto:tstella@cityofmadison.com)

**Supplement Accepted**

**Comment Date:** 06/11/2020

Applicant shall place either type 3 reflective barricades, reflective barrels/drums or jersey barriers to secure the seating area and show and note this on the plan.

**Supplement Accepted**

**Comment Date:** 06/11/2020

Applicant shall show and note on the plan the type of fence/barrier around the seating area.

**Supplement Accepted**

**Comment Date:** 06/11/2020

Applicant shall show approximate location of tables/chairs on the plan.