

BPW Meeting July 24, 2013:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

26. Owen Park Drainage Stabilization

This project will require a Notice of Intent and a Chapter 30 Permit from DNR for disturbing over and acre and for stabilization of the channel, respectively. A City Erosion Control & Stormwater Management permit is also required. (Sally Swenson, City Engineering)

Prepared By: Gina Steinbrun

Date: 7-19-13