

Attachment B

**Madison Water Utility
Unit Well Cumulative Capacity Utilization
7/31/2023**

Region	Unit Well	YTD Production (MG)	YTD Utilization (%)	Remaining Drawdown to Pump (ft)
A	7	316	47.0%	90
	8	0	na	na
	11	354	55.5%	27
	13	288	36.0%	127
	25	162	26.5%	41
	29	324	48.2%	163
	All	1,444	42.6%	
B	9	206	41.1%	37
	31	162	24.2%	127
	All	368	31.4%	
C	6	499	62.8%	69
	12	368	53.2%	40
	14	56	7.5%	64
	17	143	20.5%	45
	18	361	59.1%	47
	19	284	39.6%	27
	20	313	50.0%	18
	24	214	34.3%	123
	27	210	38.7%	34
	30	272	37.1%	62
	All	2,720	40.1%	
D	16	349	49.8%	54
	26	287	41.8%	58
	28	297	43.2%	28
	All	933	44.9%	
Entire System		5,465	40.7%	