

*BPW Meeting February 18, 2015*

*Review of Projects by Engineering Environmental Staff for Impacts to Water Resources*

1. **Larkin Street, Glenway Street, Hillcrest Drive, Zwerg Drive and Ross Street Utilities with Resurfacing Assessment District - 2015**  
This project will disturb more than an acre and will require a City Engineering Erosion Control Permit and a WDNR NOI permit. **(LeAnne Hannan, City Engineering)**
2. **North Charter Street and Spring Street Reconstruction Assessment District - 2015**  
This project will disturb more than an acre and will require a City Engineering Erosion Control Permit and a WDNR NOI permit. **(Glen Yoerger, City Engineering)**
3. **Utility Replacement with Resurfacing – 2015 Assessment District**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(Eric Dundee, City Engineering)**
12. **Hanson Road Resurfacing**  
This project will not disturb more than 4,000 sf and will not require any permits. **(Steve Sonntag, City Engineering)**

Prepared By: Phil Dault

Date: 2/18/2015