



Department of Planning & Community & Economic Development

## Planning Division

Heather Stouder, Director

---

Madison Municipal Building, Suite 017  
215 Martin Luther King Jr. Boulevard  
Madison, Wisconsin 53703  
Phone: (608) 266-4635  
[www.cityofmadison.com](http://www.cityofmadison.com)

June 15, 2020

Jacob Morrison  
1933 Keyes Avenue  
Madison, WI 53711

RE: Consideration of a conditional use to construct an accessory building containing an accessory dwelling unit (ADU) in the TR-C3 (Traditional Residential – Consistent District) at 1933 Keyes Avenue. (LNDUSE-2020-00048; ID [60346](#))

Dear Mr. Morrison;

At its June 8, 2020 meeting, the Plan Commission found the standards met and **conditionally approved** the Conditional Use for 1933 Keyes Avenue. The conditions of approval in the following sections shall be satisfied prior to issuance of building permits for the project.

**Please contact Timothy Troester of the City Engineering Division at (608) 267-1995 if you have questions regarding the following two (2) items:**

1. Applicant shall either provide a separate sewer lateral to the proposed accessory dwelling unit (A.D.U.) or connect into the sewer lateral serving the primary residence. Applicant shall 1) revise plan to either note that the lateral for the A.D.U. will be connected to the existing lateral serving the existing home or 2) provide a plan to install a separate sanitary sewer lateral for the A.D.U.
2. If a new lateral is chosen, obtain a permit to Excavate in the Right-of-Way for completing the improvements in the public Right-of-Way. The permit application is available on the City Engineering Division website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

**Please contact Jeff Quamme of the City Engineering–Mapping Section at (608) 266-4097 if you have any questions regarding the following three (3) items:**

3. Identify on the plans the lot and block numbers of recorded Certified Survey Map or Plat.
4. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.
5. The address of the ADU is 1931 Keyes Ave. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

**Please contact Jenny Kirchgatter of the Zoning Division at (608) 266-4429 if you have any questions regarding the following item:**

6. The Accessory Dwelling Unit shall comply with the supplemental regulations Section 28.151. Prior to issuance of a building permit for the Accessory Dwelling Unit, the property owner shall execute a restrictive covenant providing that the Accessory Dwelling Unit may only be used when the property is owner-occupied. The form of the restrictive covenant shall be approved by the Zoning Administrator and City Attorney's Office and shall be recorded with the Dane County Register of Deeds.

**Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following item:**

7. Madison Fire Department recommends the installation of a residential fire sprinkler system in accordance with NFPA 13D. Additional information is available at the Home Fire Sprinkler Coalition website: <https://homefiresprinkler.org/building-residential-fire-sprinklers>

**Please contact Sarah Lerner of the Parks Division at (608) 261-4281 if you have questions regarding the following item:**

8. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the Central Park-Infrastructure Impact Fee district. Please reference ID# 20015 when contacting Parks about this project.

**Please contact Brad Hofmann of the Forestry Division at (608) 267-4908 if you have questions regarding the following seven (7) items:**

9. An existing inventory of street trees located within the right of way shall be included on the landscape, site, demo, and utility plans. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
10. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the plan set.
11. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry (266-4816) prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the plan set.

12. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at 266-4816. Penalties and remediation shall be required. Add as a note on the plan set.
13. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on the plan set.
14. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on the plan set.
15. Street tree pruning shall be coordinated with Madison Forestry at a minimum of two weeks prior to the start of construction for this project. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on the plan set.

**Please contact Adam Wiederhoeft of the Madison Water Utility at (608) 266-9121 if you have any questions regarding the following three (3) items:**

16. Applicant shall either provide a separate water lateral to the proposed accessory dwelling unit(A.D.U.) or connect into the water lateral serving the primary residence. Applicant shall revise the plan to indicate how the A.D.U. will be served with a water service.
17. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.
18. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

**Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.**

**Please now follow the procedures listed below for obtaining permits for your project:**

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at [zoning@cityofmadison.com](mailto:zoning@cityofmadison.com). (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email [zoning@cityofmadison.com](mailto:zoning@cityofmadison.com) regarding questions or if you need alternative filing options) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]
3. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void two (2) years after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six (6) months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to twelve (12) months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permit, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells  
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.	
_____	
<i>Signature of Applicant</i>	
_____	
<i>Signature of Property Owner (if not the applicant)</i>	

- cc: Tim Troester, City Engineering Division  
Jeff Quamme, City Engineering Division-  
Mapping Section  
Jenny Kirchgatter, Zoning Administrator  
Bill Sullivan, Madison Fire Department  
Sarah Lerner, Parks Division  
Brad Hofmann, Forestry Division  
Adam Wiederhoeft, Madison Water Utility

<b>LNDUSE-2020-00048</b>			
<b>For Official Use Only, Re: Final Plan Routing</b>			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry