



Department of Planning & Community & Economic Development

Planning Division

Meagan Tuttle, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

****BY E-MAIL ONLY****

September 24, 2024

Greg Held
Knothe & Bruce Architects
8401 Greenway Boulevard, Suite 900
Middleton, WI 53562

RE: Consideration of a demolition permit to demolish a one-story financial institution; and consideration of a conditional use in the CC-T (Commercial-Corridor Transitional) District for a multi-family dwelling with greater than thirty-six (36) units to construct a four-story residential building with 105 units at 2001 Londonderry Drive. (ID [84449](#) & [84450](#), LNDUSE-2024-00058)

On September 23, 2024, the Plan Commission found the standards met and **conditionally approved** your demolition permit and conditional use for 2001 Londonderry Drive. In order to receive final approval of the demolition permit and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact Lisa McNabola of the Planning Division at (608) 243-0554 if you have any questions regarding the following five (5) items:

1. No HVAC “wall-pack” penetrations/louvers are shown on the street-facing facades. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing street walls is not included in this approval and will require approval of an alteration to this conditional use should they be proposed at a later time.
2. Approval of the proposed development is contingent on verification that the building complies with the minimum 20-foot building setback and the principal building entrance requirements in the Transit Oriented Development Overlay District (see recommended conditions of approval #40 and #41). Design modifications that are necessary to comply with those conditions shall be considered under the conditional use alterations process per MGO Section 21.183(8). Scope of changes will determine whether this is a minor or major alteration.

3. The proposed development is contingent on approval of a special exception to adjust a platted 42-foot building setback line by the City of Madison and Wisconsin Department of Transportation (see recommended condition of approval #58). Additional modifications or approvals may be necessary should those approvals not be granted. Such modifications shall be considered under the conditional use alterations process per MGO Section 21.183(8). Staff further note that recommended conditions of approval 4-9 have been recommended to address these design concerns. Scope of changes will determine whether this is a minor or major alteration.
4. The landscape plan shall be revised. The intent of the revisions is to break up the building mass adjacent to the principal building entrance and ramp. The landscape plan shall include columnar evergreen shrubs, or a suitable alternative determined to provide adequate year-round visual interest along the exposed building base, and a combination of deciduous and evergreen shrubs along the ramp where feasible. Revisions may be approved administratively by the Planning Division Director (or designee).
5. The applicant has submitted revised plans dated September 18, 2024. These plans have not been reviewed by all reviewing agencies and may be subject to additional review for ordinance adherence.

Please contact Brenda Stanley of the Engineering Division at (608) 261-9127 if you have any questions regarding the following seventeen (17) items:

6. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
7. Construct sidewalk, terrace, curb and gutter and pavement to a plan as approved by City Engineer.
8. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
9. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
10. Obtain a permit to plug each existing storm sewer. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 37.05(7))
11. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.

12. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
13. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
14. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>.

The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.

15. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
16. Revise the plans to show a proposed private internal drainage system on the site. Include the depths and locations of structures and the type of pipe to be used. (POLICY AND MGO 10.29)
17. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
18. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
19. The applicant shall show storm water "overflow" paths that will safely route runoff during the 100-year 24-hour design storm when the storm sewer is at capacity. Public Stormwater shall be contained to public right of way, easements or public lands for the 100-year 24-hr design storm for new development. (POLICY)

20. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering 608-266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

21. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10- year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

100-year Overflow: The applicant shall demonstrate that water can leave the site and reach the public ROW without impacting structures during a 100-year event storm. This analysis shall include reviewing overflow elevations and unintended storage occurring on site when the storm system has reached capacity.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

22. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Luke Peters of the Traffic Engineering Division at (608) 266-6543 if you have any questions regarding the following nineteen (19) items:

23. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a minimum five (5)-foot wide sidewalk, eight (8)-foot terrace, and additional one (1) foot for maintenance, where applicable, along their site's frontage of Londonderry Drive and Packers Avenue/Northport Drive/Darwin Road.

24. The applicant shall work with Traffic Engineering on providing ADA pedestrian walkway to the Packers Avenue/Northport Drive/Darwin Road sidewalk. To provide more direct access to the Metro bus stops on Packers Avenue.

25. Note: This site presents difficult constructability issues; access to neighboring sites must be maintained at all times, protected walkways will be constructed and maintained as soon as possible and little to no access to the Public Right-of-Way on Packers Avenue/Northport Drive/Darwin Road will be granted for construction purposes. Provide a detailed construction plan to Traffic Engineering for review prior to final signoff.

26. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

27. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
28. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
29. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
30. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
31. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
32. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
33. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
34. All parking ramps as they approach the public Right-of-Way shall not have a slope to exceed 5% for 20 feet; this is to ensure drivers have adequate vision of the Right-of-Way. If applicant believes public safety can be maintained they shall apply for a waiver, approval or denial of the waiver shall be the determination of the City Traffic Engineer.
35. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
36. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.

37. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
38. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
39. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
40. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
41. Applicant shall submit for review a waste removal plan. This shall include vehicular turning movements.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following nine (9) items:

42. Provide an exhibit and calculation showing that at least 30% of the primary street (Northport Drive) façade and 30% of the secondary street (Darwin Road) facade are setback no more than 20 feet from the property lines. On a corner lot, at least thirty percent (30%) of street-facing building facades shall be setback no more than twenty (20) feet from the primary street and no more than twenty (20) feet from the secondary street more or less perpendicular to the primary street.
43. Show the building setback measured from the principal entrance doors facing Northport Dr to the front property line. Principal building entrances on all new buildings shall be oriented to their primary abutting street and be located within the 20 foot maximum setback. Entrances shall be barrier-free, clearly visible and identifiable from the street, and delineated with elements such as roof overhangs, recessed entries, landscaping or similar design features.

44. Section 28.185(9)(b) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9)(b) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission approval.
45. Bicycle parking for the residential dwelling units shall comply with the requirements of MGO Sections 28.141(4)(g) and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 105 resident bicycle stalls are required plus a minimum of 10 short-term

guest stalls. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. Show the dimensions of the bicycle stalls and the access aisles on the basement floor plan. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.

46. Add a landscape planting island to the east row of surface parking adjacent to the building. A planting island shall be located at least every twelve (12) contiguous stalls with no break.
47. Provide details showing that the primary street façade meets the door and window opening requirements of Section 28.060(2)(d). For residential uses at ground level, a minimum of fifteen percent (15%) of the ground level of residential facades or side and rear facades not fronting a public street shall consist of windows and door openings. On upper stories, window or balcony openings shall occupy a minimum of fifteen percent (15%) of the upper-story wall area.
48. Provide details demonstrating compliance with bird-safe glass requirements Section 28.129. For building façades where the first sixty (60) feet from grade are comprised of less than fifty percent (50%) glass, at least eighty-five percent (85%) of the glass on glass areas fifty (50) square feet or over must be treated. Of all glass areas over fifty (50) square feet, any glass within fifteen (15) feet of a building corner must be treated. Identify which glass areas are 50 sq. ft. or greater and which glass areas will be treated. Provide a detail of the specific treatment product that will be used.
49. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
50. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Matt Hamilton of the Fire Department at (608) 266-4457 if you have any questions regarding the following two (2) items:

51. Provide an aerial apparatus fire lane that is at least 26-feet wide, with the near edge of the fire lane located between 15-ft and 30-feet of the structure, and parallel to 25% of the building perimeter. Revise aerial access lane to comply or initiate discussions to provide an equivalency.
52. Distances for fire hose lays shall be measured along the path of the hose lay. Revise layout to provide accurate hose layout in relation to building and site features.

Please contact Kathleen Kane of the Parks Division at (608) 261-9671 if you have any questions regarding the following one (1) item:

53. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new

residential development associated with this project. This development is within the North Park-Infrastructure Impact Fee district. Please reference ID# 24042 when contacting Parks about this project.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following two (2) items:

54. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.
55. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Please contact Timothy Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following four (4) items:

56. To facilitate City transit planning efforts, the applicant shall identify the accessible pedestrian connection between the building entrance(s) and the existing public sidewalk along the Northport Drive and Darwin Road public rights-of-way.
57. The applicant shall include the location of any of these transit amenities on the final documents filed with their redevelopment permit application, so that Metro Transit may review the design.
58. Metro Transit operates daily all-day transit service along Northport Drive adjacent this property - with trips at least every 30 minutes (every 15 minutes or less during the day on weekdays and Saturdays). Metro Transit operates additional daily all-day transit service along Darwin Road and Dryden Drive near this property - with trips at least every 75 minutes.
59. Metro Transit would initially estimate the following counts of potentially eligible trips towards US Green Building Council/LEED Quality Access to Transit points: 111 Weekday & 78 Weekend (average). Please contact Metro Transit if additional analysis would be of interest.

Please contact Jeffrey Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following nine (9) items:

60. The proposed project requires the partial or entire special exception to adjust the setback line as per the Plat of Bruns Second Addition to permit the building location as proposed. The Wisconsin DOT and City of Madison must both provide any special exception for any part of the setback. Provide the confirmation of DOT's acknowledgement and agreement to provide a special exception along with an exhibit and description of the area to be adjusted to Jeff Quamme to set up a real estate project and to run a resolution to modify the setback. NOTE: If any setback remains in force that includes the proposed storm sewer, applicant shall also obtain acknowledgement from the DOT for the private storm sewer to be within the setback. DOT enforced setbacks do not allow for private improvements within the setback.
61. Traffic Engineering is requiring the widening of the terrace along Packers Ave / Northport Dr right of way. Grant a Public Sidewalk or Dedicate the lands to the City to accomplish this requirement. Contact Jeff Quamme to coordinate the required Real Estate Project to accomplish the easement or dedication as required.
62. Confirm Provide acknowledgement and permission from MG&E for the proposed storm sewer and parking lot improvements within their right of way per Doc No. 2158171 as this conflicts with the rights for underground electric and other fiber improvements. Also the developer / contractor shall be aware that there are fiber facilities owned by MUFN (Metropolitan Unified Fiber Network) near and adjacent to this site wrapping around and serving the adjacent clinic building.
63. Remove the new Elm overstory tree near the entrance proposed within the Sanitary Sewer and / or utility easements. It may be replaced with a shrub or other non tree planting.
64. The site plan shall clearly show the resultant building setback after any partial release of the setback.
65. Remove the Darwin Street names from the plans. That entire area is Packers Ave.
66. The address of 2001 Londonderry Dr will be retired and archived with the demolition of the existing building. Remove all references to 2001 Londonderry Dr for the new apartment building. The address of the new apartment building is 2003 Londonderry Dr.
67. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
68. Submit a site plan and a complete building Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate sheet/page for the development of a complete interior addressing plan. Also, include a unit matrix for apartment buildings the shows the total number of apartment per floor.

The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the verification submittal stage of this LNDUSE with Zoning. The final approved Addressing Plan shall be included in said Site

Plan Verification application materials or a revised plan shall provided for additional review and approval by Engineering.

Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department.

For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

Please contact Trent Schultz of the Parking Utility at (608) 246-5806 if you have any questions regarding the following one (1) item:

69. The TDM Plan is required per MGO 16.03. Applicable fees will be assessed after the TDM Plan is reviewed by staff.

Please now follow the procedures listed below for obtaining your demolition permit:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

Please now follow the procedures listed below for obtaining your conditional use:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.

3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The conditional use approval is valid for two (2) years from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0554 or lmcnabola@cityofmadison.com.

Sincerely,



Lisa McNabola
 Planner

cc: Jenny Kirchgatter, Zoning
 Matt Hamilton, Fire Department
 Jeff Quamme, Engineering - Mapping Section
 Tim Sobota, Metro Transit
 Luke Peters, Traffic Engineering
 Trent Schultz, Parking Utility
 Jeff Belshaw, Water Utility
 Brenda Stanley, Engineering
 Kathleen Kane, Parks Division

I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional uses.

Signature of Applicant

Signature of Property Owner (if not the applicant)

| LNDUSE-2024-00058 | | | |
|---|----------------------|-------------------------------------|--------------------------|
| For Official Use Only, Re: Final Plan Routing | | | |
| <input checked="" type="checkbox"/> | Planning Div. | <input checked="" type="checkbox"/> | Engineering Mapping Sec. |
| <input checked="" type="checkbox"/> | Zoning Administrator | <input checked="" type="checkbox"/> | Parks Division |
| <input checked="" type="checkbox"/> | City Engineering | <input type="checkbox"/> | Urban Design Commission |
| <input checked="" type="checkbox"/> | Traffic Engineering | <input checked="" type="checkbox"/> | Recycling Coord. (R&R) |
| <input checked="" type="checkbox"/> | Fire Department | <input checked="" type="checkbox"/> | Water Utility |
| <input checked="" type="checkbox"/> | Metro Transit | <input checked="" type="checkbox"/> | Other: Parking |