



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

January 14, 2020

Kevin Burow
Knothe & Bruce Architects, LLC
7601 University Ave #201
Middleton, WI 53562

RE: Legistar #58485; Accela 'LNDUSE-2019-00117' -- Approval of conditional use to construct a three-story mixed-use building with commercial space and 11 apartments **5802 Raymond Road**.

Dear Mr. Burow,

At its January 13, 2020 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your conditional use to construct a three-story mixed-use building with 2,400 square feet of commercial space on the ground floor and 11 apartments at **5802 Raymond Road**. In order to receive final approval of the conditional use and for any permits that may need to be issued for your project, the following conditions shall be met:

Please contact Jacob Moskowitz, Assistant Zoning Administrator, at 266-4560 if you have any questions regarding the following three (3) items:

1. Provide the minimum required number of bicycle parking spaces distributed as both Short Term and Long Term bicycle parking for the residential and commercial uses, as required per Sections 28.141(4) and 28.141(11). A minimum of 14 resident bicycle parking spaces are required plus 1 guest stall. A minimum of 90% of the resident stalls shall be designed as long-term parking, and the guest stalls shall be short-term parking. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. A minimum of 2 short-term bicycle stalls shall be required for the commercial uses. Identify and dimension the bicycle stalls, including the access aisles, on the final plans. Provide a detail of the bicycle rack design.
2. Submit a detail of the trash enclosure. The trash enclosure shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet.
3. Pursuant to Sec. 28.142(3) Landscape Plan and Design Standards: Landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared and stamped by a registered landscape architect.

Please contact Tim Troester of the Engineering Division, at 261-1995 if you have any questions regarding the following eighteen (18) items:

4. Based on WDNR BRRS record #03-131-72898, the property contains residual contamination. Proof of coordination with the Wisconsin DNR is required to address residual contamination. Coordinate with Brynn Bemis (608.267.1986, bbemis@cityofmadison.com).
5. Show storm sewer easement lines on all plan sheets.
6. The applicant is required to televise the storm sewer is required prior to any improvements within the easement and prior to approval of a consent to occupy the easement. Upon completion of the improvements the applicant shall be required to televise the storm sewer again and remedy any damages at their cost, if incurred, as part of the consent to occupy agreement.
7. No trees will be allowed within the storm sewer easement.
8. The channel/grading behind the retaining wall to the east and north is not well defined. If necessary the applicant shall obtain approval to grade on the adjacent properties.
9. This site was a previous service station and likely contains residual contamination. Liners will be required for the stormwater management (bio retention and raingardens).
10. Obtain a permit to Excavate in the Right-of-Way for completing the improvements in the public Right-of-Way. The permit application is available on the City Engineering Division website at <http://www.cityofmadison.com/engineering/Permits.cfm>. As a condition of the permit, surety to guarantee the construction of the improvements and a deposit to cover estimated City expenses will be required.
11. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
12. Obtain a permit to Excavate in the Right-of-Way for the connection and/or installation of utilities required to serve this project and shall comply with all the conditions of the permit. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO 10.05(6)), MGO 35.02(4)(c)(2)), and MGO 37.05(7))
13. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
14. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
15. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
16. Revise the site plan to show all existing public sanitary sewer facilities in the project area as

well as the size, invert elevation, and alignment of the proposed service. (POLICY)

17. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE and therefore will be regulated to meet a higher standard.
18. This project will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval. The permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.
19. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive upwindow.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

20. Submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division that is to scale and represents final construction with any private storm and sanitary sewer utilities.
21. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Jeff Quamme of the Engineering Division – Mapping Section, at 266-4097 if you have any questions regarding the following three (3) items:

22. Upon approval of the proposed Bio-retention basin, bike racks, ramp and trees proposed within the City of Madison Easement for storm sewer per Doc No. 1093115, a Consent to Occupy Easement document shall be drafted and recorded by City of Madison Office of Real Estate Services defining responsibilities and requirements in conjunction with the proposed improvements. Coordinate with Jeff Quamme at jrquamme@cityofmadison.com
23. Provide the recorded Private Water Service Easement for the connection to the northwest over the adjacent private lands connecting to the public watermain. The recorded copy shall be provided prior to final sign off of the site plan.
24. Submit a Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan for each floor on a separate sheet for the development of a complete interior addressing plan. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) prior to the application submittal for the final Site Plan Approval with Zoning. The approved Addressing Plan shall be included in the final application.

For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved. The final revised Addressing Plan shall be submitted by the applicant to Zoning to be attached to the final filed approved site plans.

Please contact Sean Malloy of the Traffic Engineering Division, at 266-5987 if you have any questions regarding the following thirteen (13) items:

25. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
26. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
27. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.

28. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
29. The applicant(s) shall maintain a 5 foot wide, Americans with Disabilities Act (ADA) compliant, pedestrian walkway for the duration of the project on all street frontages classified as a collector or higher. The applicant shall also maintain a 5 foot wide bicycle lane for the duration of the project on all street frontages with existing bicycle facilities. Exceptions to this requirement may be granted by Traffic Engineering on a limited term basis if and when the applicant can show a public safety concern and they also provide a clear date when the pedestrian/bicycle facilities are to be restored. All closures shall be designed by the applicant, in accordance with the Manual on Uniform Traffic Control Devices (MUTCD), to be submitted and approved by Traffic Engineering.
30. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
31. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
32. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
33. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
34. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
35. Dimensions of the driveways shall be noted on the plan including the width of driveway and width of driveway flares or curb cut.
36. Secure parking facility. This is usually done with continuous six (6) inch curb, timbers, preformed wheel stops, guardrail erected at a height of eighteen (18) inches or fencing of sufficient strength to act as a vehicle bumper.
37. Note: This site presents difficult constructability issues; access to neighboring sites must be maintained at all times, protected walkways will be constructed and maintained as soon as possible and little to no access to the Public Right-of-Way on Raymond Road will be granted for construction purposes. Provide a detailed construction plan to Traffic Engineering for review by the Traffic Control Specialist (Mike Duhr) prior to final signoff.

Please contact Kate Kane of the Parks Division, at 261-9671 if you have any questions regarding the following three (3) items:

38. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the West Park-Infrastructure Impact Fee district. Please reference ID# 19053 when contacting Parks about this project.
39. Pursuant to the authority established under Wis. Stat. § 66.0617(7), and in the interests of promoting the development of low-cost housing in the City, low-cost housing is exempt from park impact fees beginning January 1, 2017. This exemption only applies to those dwelling units or bedrooms within a development that are determined to be low-cost housing. This exemption does not extend to the land dedication requirements set forth under Sec. 16.23(8)(f), MGO, nor any other impact fees that may apply to a development.
40. Park impact fees will be exempt for developments that meet the “low-cost housing” requirements, as defined as rental or owner-occupied housing units that are affordable as that term is defined in Sec. 4.22(2), MGO, and which meet the deed restriction requirements of Sec. 4.22(7). The determination whether a proposed development will create low-cost housing, and how much low-cost housing it will create, shall be made by the Community Development Division. Please contact Community Development Division if you have questions on the Low Cost Housing Exemption.

Please contact Brad Hofmann of the Forestry Division, at 267-4908 if you have any questions regarding the following one (1) item:

41. Additional street trees are needed for this project. All street tree planting locations and trees species within the right of way shall be determined by City Forestry. Please submit a site plan (in PDF format) to Brad Hofmann – bhofmann@cityofmadison.com or (608) 266-4816. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction –

Please contact Jeff Belshaw of the Water Utility, at 261-9835 if you have any questions regarding the following one (1) item:

42. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility’s Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact Tim Sobota of Metro Transit, at 261-4289 if you have any questions regarding the following four (4) items:

43. In coordination with any public works improvements, the applicant shall maintain or replace the concrete boarding pad surface at the existing Metro bus stop on the north side of Raymond Road, west of Leland Drive (#8712).
44. The applicant shall install and maintain a bench or other seating amenity in the adjacent property landscape plan, ideally taking advantage of any building overhang or canopy to provide the seating amenity some shelter from the elements. The applicant may alternatively elect to install and maintain a passenger waiting shelter, with bench seating, if the applicant believes this upgraded amenity feature would be more compatible with the building entrances that are shown directly adjacent the existing bus stop loading zone area.
45. The applicant shall include the location of these transit amenities on the final documents filed with their permit application so that Metro Transit may review the design.
46. Metro Transit currently operates daily transit service along Raymond Road through the Leland Drive intersection. Bus stop ID #8712 is adjacent the proposed project site along the north side of Raymond Road, with the bus stop zone encompassing the area from the existing bus stop sign pole east through to the Leland Drive intersection.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:


1. Please revise your plans per the above conditions and submit **nine (9) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, **215 Martin Luther King, Jr. Blvd.** This submittal shall all also include one complete digital plan set in PDF format. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
4. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or

additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.

- The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
 Planner

<p>I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional use.</p> <hr style="border: 0; border-top: 1px solid black; margin-bottom: 5px;"/> <p style="text-align: center;"><i>Signature of Applicant</i></p> <hr style="border: 0; border-top: 1px solid black; margin-bottom: 5px;"/> <p style="text-align: center;"><i>Signature of Property Owner (if not the applicant)</i></p>
--

- cc: Jacob Moskowitz, Asst. Zoning Administrator
 Tim Troester, Engineering Division
 Jeff Quamme, Engineering Division – Mapping Section
 Sean Malloy, Traffic Engineering Division
 Kate Kane, Parks Division
 Brad Hofmann, Forestry Division
 Jeff Belshaw, Water Utility
 Tim Sobota, Metro Transit

LNDUSE-2019-00117			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input checked="" type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry