

BPW Meeting April 21, 2010:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

9. **Hillcrest Upland Greenway & Sanitary Lateral Assessment District**
This project will require a Chapter 30 permit for work in a navigable waterway and WRAPP (formerly NOI), for land disturbance over an acre, from the DNR, a permit from the ACOE, and a City Erosion Control and Stormwater Management permit. (Lisa Coleman, City Engineering)

10. **Kedzie Street/North Lawn Ave Reconstruction**
This is an expansion of another project. The full project will disturb over an acre, which will require a WRAPP from the DNR and a City Erosion Control and Stormwater Permit. Both permit applications have already been submitted. (Jim Wolfe, City Engineering)

11. **Riverside Drive Reconstruction**
This project will disturb over 4,000 square feet, which will require a City Engineering Erosion Control and Stormwater Permit. (Janet Dailey, City Engineering)

30. **Allied Drive Redevelopment**
This project will disturb over an acre, which will require a WRAPP from the DNR. (Chris Petykowski, City Engineering)

Prepared By: Genesis Bichard

Date: 4/21/10