



- UTILITY NOTES:**
- All site utilities shall conform to the City of Madison Standard Specifications for Public Works Construction, latest edition.
 - The locations of existing utility installations as shown on this drawing were obtained from the records of municipal, local utility records and DigSafe hotline locations. The accuracy of these records or the locations by DigSafe Hotline cannot be certified or guaranteed. There may be other underground utility installations within the project area that are not shown.
 - Contractor shall provide 6.5' of cover for the new water service.
 - Storm sewer shall be installed with water tight joints.
 - Sanitary sewer mains and laterals shall be PVC, SDR-35.
 - Inlets #1 - #8 and #14 - #17 shall be 2x3' precast inlets with Neenah casting R-3067, Type R grate.
 - Inlet #9 shall be a 2x2' precast inlet with Neenah R-1878-BTG frame and grate.
 - All sanitary manholes and catchbasins shall be 48" diameter precast manholes with Neenah casting R-1550 Type II non-slaking frame and lid.
 - All utilities serving the proposed building shall be stubbed 5 feet outside of the building and marked using a 4" x 4" hardwood post.
 - Prior to connecting to existing storm sewer or sanitary sewer the contractor shall verify the existing inverts and notify project superintendent if discrepancies are found from plan grades.
 - Contractor to coordinate with the respective companies for gas, electric, telephone, cable extensions and/or abandonments.
 - Prior to storm sewer construction, the Utility Contractor shall obtain a connection and excavation permit from the City.
 - All proposed storm sewer, sanitary sewer and water services are private except where labeled as public.
 - Pavement catch shall match the requirements of the City of Madison Type A pavement design shown in Standard Detail 4.02 of the Standard Specifications for Public Works Construction.

LEGEND

	PROPOSED SANITARY SEWER
	PROPOSED WATER SERVICE
	PROPOSED STORM SEWER
	PROPOSED CATCHBASIN OR MANHOLE
	PROPOSED INLET

SCALE: 1" = 30'
 (PAGE SIZE: 30x42)
 DATE: 09-19-12
 REVISED:
 11-13-12
 01-29-13

DRAWN BY: BJS

FN: 12-05-124

Sheet Number:
C103