

## 2011 Unit Well Capacity

Well	Capacity GPM	Total Daily Capacity MGD	Total Yearly Capacity Mil Gal Year	Actual Pumpage Mil Gal Year	% Utilization		DW Run Hours	DW Rest Hours	% At Rest	% DW Running
6	2,687	3.9	1,412.2	238.9	16.9%		1,475.7	7,284.3	83.2%	16.8%
7	1,591	2.3	836.5	323.3	38.7%		3,148.5	5,611.5	64.1%	35.9%
8	1,888	2.7	992.4	56.9	5.7%		1,233.2	7,526.8	85.9%	14.1%
9	1,778	2.6	934.5	445.8	47.7%		4,196.8	4,563.2	52.1%	47.9%
11	2,043	2.9	1,073.7	535.0	49.8%		4,280.5	4,479.5	51.1%	48.9%
12	2,591	3.7	1,361.6	586.4	43.1%		4,110.3	4,649.7	53.1%	46.9%
13	2,306	3.3	1,211.9	763.8	63.0%		5,540.4	3,219.6	36.8%	63.2%
14	2,306	3.3	1,211.8	883.2	72.9%		5,969.1	2,790.9	31.9%	68.1%
15	2,199	3.2	1,155.8	811.1	70.2%		6,164.3	2,595.7	29.6%	70.4%
16	2,522	3.6	1,325.4	422.1	31.8%		2,869.3	5,890.7	67.2%	32.8%
17	2,411	3.5	1,267.3	426.1	33.6%		2,947.2	5,812.8	66.4%	33.6%
18	1,906	2.7	1,001.7	511.8	51.1%		4,479.6	4,280.4	48.9%	51.1%
19	2,376	3.4	1,249.1	755.0	60.4%		5,441.6	3,318.4	37.9%	62.1%
20	2,006	2.9	1,054.4	593.8	56.3%		5,081.5	3,678.5	42.0%	58.0%
23	1,173	1.7	616.5	131.0	21.2%		1,946.7	6,813.3	77.8%	22.2%
24	1,843	2.7	968.7	331.3	34.2%		3,278.5	5,481.5	62.6%	37.4%
25	1,864	2.7	979.7	437.9	44.7%		3,783.0	4,977.0	56.8%	43.2%
26	2,186	3.1	1,148.8	594.8	51.8%		4,604.0	4,156.0	47.4%	52.6%
27	1,974	2.8	1,037.3	132.3	12.8%		1,134.3	7,625.7	87.1%	12.9%
28	2,357	3.4	1,239.1	345.5	27.9%		2,537.8	6,222.2	71.0%	29.0%
29	1,140	1.6	599.2	502.4	83.8%		7,978.2	781.8	8.9%	91.1%
30	2,431	3.5	1,277.6	635.6	49.8%		4,351.0	4,409.0	50.3%	49.7%