Madison Water Utility Status of Unit Wells Offline for Repairs or Upgrades 10/15/2025

| Region | Unit Well | Lost Supply (GPM) | Date Offline | Expected Online | Status of Repair/Replacement |
|--------|-----------|----------------------|-----------------|--------------------|---|
| A/B | 13 | 2,200 | 09/2025 | 12/2025 | Replacement equipment has been ordered |
| С | 19 | 2,200 | 10/2024 | 11/2025 | Chemical feed equipment install is on-going; DNR startup inspection is complete |

GPM = gallons per minute; 1,000 gpm = 1.44 MGD (million gallons per day)