

BPW Meeting March 18, 2015

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

5. **Burning Wood Way, Comanche Way, Menomonie Court, Burning Wood Court, and Fourth Street Utility Replacement with Resurfacing Assessment District - 2015**  
This project will disturb more than an acre and will require a City Engineering Erosion Control Permit and a WDNR NOI permit and a WDNR Chapter 30 Permit. **(Eric Dundee, City Engineering)**
6. **Cross Street Assessment District - 2015**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(LeAnne Hannan, City Engineering)**
7. **Bear Claw Way, Cobalt Street and Wilrich Street Assessment District – 2015**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(Lisa Coleman, City Engineering)**
8. **Madison Street and Oakland Avenue Resurfacing Assessment District - 2015**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(LeAnne Hannan and Corey Stelljes, City Engineering)**
9. **Block 1 Wingra Park Alley Reconstruction Assessment District - 2015**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(LeAnne Hannan and Corey Stelljes, City Engineering)**
10. **Hoepker Road Assessment District-2015**  
This project will disturb more than an acre and will require a City Engineering Erosion Control Permit and a WDNR NOI permit. **(Jim Wolfe, City Engineering)**
23. **Lake Edge Park Shelter**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(Tom Maglio, Parks)**
24. **Restoration/Landscaping 2015**  
This project will not disturb more than an acre and so will only require a City Engineering Erosion Control Permit. **(Sally Swenson, City Engineering)**

Prepared By: Phil Galt

Date: 3/17/2015

