



Department of Planning & Community & Economic Development

Planning Division

Meagan Tuttle, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

****BY E-MAIL ONLY****

May 1, 2025

David Zielsdorf

Aldo Partners

507 Bruce Street, Suite 103

Verona, WI 53593

RE: Consideration of a demolition permit to demolish a single-family building at 2530 Dahle Street. (ID [87720](#), LNDUSE-2025-00032)

Cody,

On April 28, 2025, the Plan Commission found the standards met and **conditionally approved** your demolition permit for 2604 Waunona Way. In order to receive final approval of the demolition permit and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact Lisa McNabola of the Planning Division at (608) 243-0554 if you have any questions regarding the following one (1) item:

1. The property at 2604 Waunona Way is located within the boundary of the Waunona Burial Site (DA-1403, BDA-0609). As such, any ground-disturbing work will need to secure a Request to Disturb permit from the Wisconsin Historical Society. <https://www.wisconsinhistory.org/Records/Article/CS3129>. As part of securing the required Request to Disturb from the Wisconsin Historical Society, also copy the submittal to the Ho-Chunk National Tribal Historic Preservation Office. Contact at The Ho-Chunk Nation's National Tribal Historic Preservation Office: William Quackenbush. P. O. Box 667, Black River Falls, WI 54615. Phone: 715-284-7181. Email: bill.quackenbush@ho-chunk.com.

The following information is provided for the reference of the applicant as many lakefront properties are associated with locations of Native effigy mounds and archaeological sites. Burial Sites Preservation (§ 157.70): (2r) Site Disturbance Prohibited. Except as provided under subs (4) and (5) and State Statute 157.111 and 157.112, no person may intentionally cause or permit the disturbance of a burial site or catalogued land contiguous to a cataloged burial site. (3) Report of Disturbed Burial Sites. (a) Except as provided under s. 979.01, a person shall immediately notify the Wisconsin Historical Society (608-264-6502) if the person knows or has reasonable grounds to believe that a burial site or the cataloged land contiguous to a cataloged burial site is being disturbed or may be disturbed contrary to the requirements of subs. (4) and (5).

Many lakefront properties are associated with locations of Native American effigy mounds and archeological sites. This site is known to be very close to those associated with archeological and historic resources. The Burial Sites Preservation statute requires that the property owner contact the Wisconsin Historical Society to discuss the location of the proposed project and any possible disturbance of an archaeological or historic resource before the work commences. During the construction work, if a burial site disturbance occurs, the work shall stop immediately until the Wisconsin Historical Society is able to assess the site.

Please contact Brenda Stanley of the Engineering Division at (608) 261-9127 if you have any questions regarding the following one (1) item:

2. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))

Please contact Jenny Kirchgatter, Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following three (3) items:

3. Section 28.185(9)(b) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9)(b) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission approval.
4. Provide a demolition plan identifying the principal building, structures, paved areas, and landscaping to be removed.
5. Approval of the demolition will require the removal of the principal building and any structures and paved areas as identified in the demolition plan. Disturbed areas shall be graded and seeded or sod planted to minimize erosion.

Please contact Bradley Hofmann of the Forestry Section at (608) 267-4908 if you have any questions regarding the following seven (7) items:

6. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
7. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the

development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.

8. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.
9. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.
10. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
11. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
12. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:

13. Submit a site plan indicating if a new water service will need to be installed or if the plan is to utilize the existing water service.

Please contact Jeffrey Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following one (1) item:

14. Provide a Demolition Plan denoting all structures, improvements and pavements to be removed and to remain. Also include the new pavements and improvements and pavements as part of the approved ADU to be constructed.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your demolition permit:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee (\$100) shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 12 months from the expiration date.

If you have any questions regarding obtaining your demolition permit or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please contact my office at 243-0554 or lmcnabola@cityofmadison.com.

Sincerely,



Lisa McNabola
Planner

LNDUSE-2025-00032			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div.	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry