



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4635
www.cityofmadison.com

****BY E-MAIL ONLY****

February 10, 2023

Marc Ott
JLA Architects
800 W Broadway, Suite 200
Madison, WI 53713

RE: Consideration of a Zoning Map Amendment request to change the zoning of property located at 6604 Odana Road from CC (Commercial Center) District to CC-T (Commercial Center-Transitional) District; Consideration of a demolition permit to demolish a theater at 6604 Odana Road; and Consideration of a conditional use in the [Proposed] Commercial Corridor-Transitional (CC-T) District for a mixed-use building containing greater than 60 dwelling units, consideration of a conditional use in the CC-T District for a building exceeding five stories and 78 feet in height, and consideration of a conditional use for a major amendment to a planned multi-use site with 40,000 square feet or more of floor area of which 25,000 square feet or more is designed as retail, a hotel or motel; all to allow the construction of a six-story mixed-use building containing approximately 2,200 square feet of commercial space and 87 apartments at 6604 Odana Road. (LNDUSE-2022-00101; IDs [74624](#), [74259](#) and [74260](#))

Dear Marc;

On February 7, 2023, the Common Council found the standards met and **conditionally approved** your client's request to rezone 6604 Odana Road from CC to CC-T. On January 23, 2023, the Plan Commission found the standards met and **approved** your client's demolition permit and conditional use requests for 6604 Odana Road. Prior to issuance of demolition or building permits for your project, the conditions of approval in the following sections shall be satisfied:

Please contact Tim Troester of the City Engineering Division at (608) 267-1995 if you have any questions regarding the following sixteen (16) items:

1. Applicant shall provide projected wastewater flow calculations for the proposed development. Offsite sanitary sewer improvements may be required to be done by the developer as a condition for development. Applicant shall submit projected wastewater calculations to Mark Moder, (608) 261-9250, mmoder@cityofmadison.com
2. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))

3. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
4. Obtain a permit to plug each existing storm sewer. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 37.05(7))
5. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
6. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
7. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
8. This site appears to disturb less than one (1) acre of land. No submittal to the WDNR, CARPC or Department of Safety and Professional Services (DSPS) is required as the City of Madison Building Inspection Department is an approved agent for DSPS.
9. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
10. Revise the plans to identify the location of the public storm sewer (proposed or existing) that will serve the development show the connection of the private internal drainage system to the public storm sewer. (POLICY AND MGO OVER 10,000 SF OF IMPERVIOUS AREA 10.29 and 37.05(7)(b))
11. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
12. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.

13. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

This project will require a concrete management plan and a construction dewatering plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit. (POLICY)

This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering 608-266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

14. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10- year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

15. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).
16. The proposed parcels within this development (and/or adjacent to) are dependent on each other for overland and subsurface storm water drainage. A private Storm Sewer/Drainage Easement/Agreement for all parcels within (and/or adjacent to) this development shall be drafted, executed and recorded prior to building permit issuance.

Please contact Jeff Quamme of the City Engineering–Mapping Section at (608) 266-4097 if you have any questions regarding the following four (4) items:

17. The common accesses between this and adjoining sites are in conformance with the access rights set forth in Document No. 4364994. The applicant / owner may wish to amend the agreement to clarify that this site (Lot 3 of Certified Survey Map No 12279 is responsible for the bio-retention system to be constructed as part of this development.
18. There is a 10' wide Private Water Lateral Easement on the east side of this site that appears to be within or near the building to be constructed and under the proposed bio retention basin. Applicant shall confirm the existence and location of any water lateral and amend or release the easement as necessary.
19. The base address of the apartments is 512 S Yellowstone Dr. The address of the proposed retail is 516 S Yellowstone Dr. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
20. Submit a site plan and a complete building Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate sheet/page for the development of a complete interior addressing plan. Also, include a unit matrix for apartment buildings.

The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the verification submittal stage of this LNDUSE with Zoning.

The final approved stamped Addressing Plan shall be included in said Site Plan Verification application materials or a revised plan shall provided for additional review and approval by Engineering.

Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department.

For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following thirteen (13) items:

21. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
22. The developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
23. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
24. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
25. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
26. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
27. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
28. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) – Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
29. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.

30. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
31. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
32. The applicant shall prepare a TDMP (Traffic Demand Management Plan) to be reviewed and approved by the City Traffic Engineer. MGO (28.183(6)(a)(6)
33. Developer shall provide a recorded copy of any joint driveway ingress/egress and crossing easements and shall be noted on face of plan.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator at (608) 266-4429 if you have questions about the following fourteen (14) items:

34. Section 28.185(9) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission's approval.
35. Submit an overall site plan showing the entire planned multi-use site including 6650 Odana Road and 6509 Normandy Lane.
36. This project is part of a planned multi-use site. Per Section 28.137(2)(a), a planned multi-use site shall have a plan and reciprocal land use agreement approved by the Traffic Engineer, City Engineer and Director of Planning and Community and Economic Development recorded in the office of the Dane County Register of Deeds.
37. On the site plan, show the building setback distances measured to the property lines.
38. Provide a calculation and plan detail for lot coverage with the final submittal. The lot coverage maximum is 85%. Lot coverage is defined as the total area of all buildings, measured at grade, all accessory structures including patios, etc., and all paved areas as a percentage of the total area of the lot, with the following exceptions: sidewalks or paved paths no wider than five (5) feet, pervious pavement, green roofs and decks. If the existing site currently exceeds 85% maximum lot coverage, proposed site improvements may not further increase lot coverage above the maximum.

39. Bicycle parking for the commercial tenant space shall comply with the requirements of MGO Sections 28.141(4)(g) and 28.141(11) and will be reviewed prior to obtaining zoning approval for the use. Provide a minimum of two (2) short-term bicycle parking stalls located in a convenient and visible area on a paved or pervious surface. Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance.
40. Bicycle parking for the residential dwelling units shall comply with the requirements of MGO Sections 28.141(4)(g) and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 87 resident bicycle stalls are required plus a minimum of 9 short-term guest stalls. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.
41. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
42. Provide adequate development frontage landscaping per Section 28.142(5) Development Frontage Landscaping. One (1) overstory deciduous tree and five (5) shrubs shall be planted for each thirty (30) lineal feet of lot frontage. Two (2) ornamental trees or two (2) evergreen trees may be used in place of one (1) overstory deciduous tree. Existing trees and plantings located between the parking lot and public sidewalk may count toward the required amount of frontage landscaping.
43. Show the entrance/s for the commercial tenant space on the first floor plan and elevations. All new buildings shall have a functional entrance oriented to an abutting public street. Additional entrances may be oriented to a private street or parking area. Entries shall be clearly visible and identifiable from the street, and delineated with elements such as roof overhangs, recessed entries, landscaping, or similar design features. Barrier-free entrances are encouraged.
44. Provide details showing that the primary street façade meets the door and window opening requirements of Section 28.060(2)(d). For nonresidential uses at ground floor level, windows and doors or other openings shall comprise at least sixty percent (60%) of the length and at least forty percent (40%) of the area of the ground floor of the primary street facade. At least fifty percent (50%) of windows on the primary street facade shall have the lower sill within three (3) feet of grade. For residential uses at ground level, a minimum of fifteen percent (15%) of the ground level of residential facades or side and rear facades not fronting a public street shall consist of windows and door openings. On upper stories, window or balcony openings shall occupy a minimum of fifteen percent (15%) of the upper-story wall area.
45. Provide a detail of the specific bird-safe glass treatment product that will be used.
46. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

47. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following three (3) items:

48. Provide fire access lanes in accordance with MGO 34 and the IFC 2021 edition.
49. MFD recommends improving access to the stairs from the lobby in order to facilitate healthier living and quicker emergency response by emergency services.
50. Consider exiting from the proposed roof terraces and security. Required means of egress are not permitted to be locked.

Please contact Ann Freiwald of the Parks Division at (608) 243-2848 if you have any questions regarding the following item:

51. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the West Park-Infrastructure Impact Fee district. Please reference ID# 22047 when contacting Parks about this project.

Please contact Brandon Sly of the Forestry Section at (608) 266-4816 if you have any questions regarding the following eight (8) items:

52. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
53. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
54. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.

55. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.
56. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
57. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
58. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608) 266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
59. Applicant shall work with City Forestry and Engineering during the right of way design process to address street tree and utility conflicts. Any street tree removals due to utility improvements within the right of way shall be reviewed and approved by the Board of Public Works. Any approval of Privilege in Streets Agreements shall be reviewed by City Forestry for street tree impacts.

Please contact Jeff Belshaw of the Madison Water Utility at (608) 261-9835 if you have any questions regarding the following item:

60. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact Tim Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following two (2) items:

61. To facilitate City transit planning efforts, the applicant shall identify the accessible pedestrian connection between the building entrance(s) and the existing public sidewalk along the nearest point of the Odana Road and Yellowstone Drive public rights-of-way.
62. The applicant shall include the location of these facilities on the final documents filed with their permit application, so that Metro Transit may review and effectively plan for City transit access to this property.

Please contact Jessica Vaughn of the Urban Design Commission at (608) 267-8740 if you have any questions regarding the following four (4) items:

63. Revisit the grey metal panel that comes down into the brick on the south elevation; needs revision.
64. Update the planting plan to show plantings in a more random pattern versus in large drifts of singular plants.
65. Provide a pedestrian connection from the building to Yellowstone Drive with a crosswalk through the drive aisle.
66. On the northwest and southwest frontages, incorporate a streetscape design including columnar trees.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and [site plan review fee pursuant to Section 28.206](#) of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at sprapplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email sprapplications@cityofmadison.com regarding questions or if you need alternative filing options. The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. The [site plan review fee pursuant to Section 28.206](#) can be mailed in, dropped in the drop box at the Madison Municipal Building, or you can make an appointment at the Zoning counter to pay the fee. Checks should be made out to "City Treasurer." If you mail in the check, please include the application form with the project address and contact information. Zoning staff typically suggest making an appointment with the Zoning counter to pay the fee as they are the quickest.

Mailing Address: City of Madison Building Inspection. P.O. Box 2984. Madison, WI 53701-2984

Zoning Counter Appointment: <https://www.cityofmadison.com/dpced/bi/schedule-a-counter-appointment/3423/>

3. City Agencies who submitted conditions of approval will review your revised plans to verify that their **conditions**, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, (608) 267-4908.
5. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
6. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.
7. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

*Signature of Property Owner
(If Not Applicant)*

cc: Timothy Troester, Engineering Division
Jeff Quamme, Engineering Division – Mapping Section
Sean Malloy, Traffic Engineering
Jenny Kirchgatter, Zoning Administrator
Bill Sullivan, Fire Department
Ann Freiwald, Parks Division
Brandon Sly, Forestry
Jeff Belshaw, Water Utility
Bryan Johnson, Streets Division
Tim Sobota, Metro Transit
Jessica Vaughn, Urban Design Commission

LNDUSE-2022-00101

For Official Use Only, Re: Final Plan Routing

☒	Planning Div. (Wells)	☒	Engineering Mapping Sec.
☒	Zoning Administrator	☒	Parks Division
☒	City Engineering	☒	Urban Design Commission
☒	Traffic Engineering	☒	Recycling Coord. (R&R)
☒	Fire Department	☒	Forestry
☒	Water Utility	☒	Metro Transit