

Evaluating Energy Savings Potential for Deep Well Pump Variable Frequency Drive Installation for the Madison Water Utility

Connor Mancosky
Madison Water Utility Water Board Meeting
July 25, 2017




Civil and Environmental Engineering
UNIVERSITY OF WISCONSIN-MADISON

Research Objective


- Determine energy savings potential of VFD installation for existing Madison Water Utility deep well pumps
- Build on the results of work done by previous graduate students




VFD Example: Madison, Wisconsin – Well 6




Unit Well 30 Energy Intensity Curve




Utility-Wide Results




Unit Well 30 Energy Intensity Curve



Unit Well 30 Energy Savings Estimates




Top Candidates for VFD Installation



Unit Well 30 Operation

Operation Before VFD

- 1.87 MGD production
- Deep well pump
 - 2,410 gpm
 - 13 hrs/day
- Booster pump
 - 1,300 gpm
 - 24 hrs/day



Operation After VFD


- 1.86 MGD production
- Deep well pump
 - 1,450 gpm
 - 21.5 hrs/day
- Booster pump
 - 1,280 gpm
 - 24 hrs/day

Estimated Savings:
595 kWh/day \$65/day (\$23,700/yr) \$36/MG

Unit Well 30 Energy Savings

Energy Use Before VFD

- 3,980 kWh/day
- 2,130 kWh/MG
- Operation costs
 - \$380/day
 - \$207/MG



Energy Use After VFD

- 3,440 kWh/day
- 1,850 kWh/MG
- Operation costs
 - \$320/day
 - \$170/MG

Observed Savings:
540 kWh/day \$60/day (\$22,000/yr) \$37/MG

Long-term Savings Update

VFD Operation: December 2016 – June 2017

Savings Compared to December 2015 – June 2016

- 277 kWh/MG energy intensity savings
- \$25.40/MG savings
- 94,550 kWh saved
- \$8,660 saved

Savings Compared to June 2016 – November 2016

- 288 kWh/MG energy intensity savings
- \$26.70/MG savings
- 97,940 kWh saved
- \$9,090 saved

Expected payback of 1.5 years

Conclusions

- Deep well pumps have significant potential for energy savings with VFD installation because of the potential to reduce drawdown and head
 - Nearly 100,000 kWh and \$9,000 of savings 6 months after VFD installation at Unit Well 30, the top-ranked well in the system.
 - Remaining top candidates for VFD installation are Unit Wells 6, 13, 11, and 18. Estimated yearly savings of 470,000 kWh and \$52,000 at these sites.
- Considering only energy savings, VFD installation may not be effective at every well (e.g. Unit Well 14 or Unit Well 26).

Recommendations

- Continue installing VFDs based on energy savings potential
 - Prioritize VFD installation at Unit Well 6, where expected cost savings >\$15,000 per year
- Continue to expand the study of VFD installation to include systems of several wells or entire pressure zones.

Future Research Options

- Continue to pursue strategies to reduce the \$2.6 million annual budget for energy
- Research system optimization from an energy use standpoint
- Explore ways to manage and reduce electric utility demand charges
- Identify if VFDs provide additional water quality benefits