



The existing roof for the North Storage Building has settled to the point where it no longer drains waters. Puddles are 1-2 inches deep. The existing roof is 30 years old & leaking