

SUMMARY OF PUBLIC WORK STANDARD SPECIFICATION REVISIONS – 2025

STANDARD SPECIFICATIONS

REVISED SPECS

Section 207- SEEDING

- Add a requirement to send seed bag labels to project manager
- Update no mow mix to exclude annual rye
- Update requirements for seeding/matting so that we require a “no stratification” native seed mix to be applied if seeding occurs during summer months and overseeding in fall when using no stratification mix.
- Additional information on seed mixes and erosion matting
 - Initial seeding needs to be installed under matting. If seeded between June 15 and October 15 using non stratification seed mix, the Contractor shall be required to overseed with a stratification seed mix on top of existing erosion control matting
- Changes to terrace seed mix to match what is commercially available

Section 209

Modifications for drought watering to remove reference to U.S. Drought Monitor and address localized drought. Drought watering, less than ½” of total accumulated rainfall over 14 days or greater than seven (7) days in a row greater than 95 degrees.

Section 301.9 CONCRETE SLURRY

Add Type B Slurry, which will consist of:

- 2700 lb Sand
- 100 lb Portland Cement
- 300 lb Class C Fly Ash
- 50 gal. Water

Section 507.2(d) Inlets

Modify casting 10. To be R-3808-0007 to match the respective Standard Detail Drawings.

507.3(b) PRECAST REQUIREMENTS

Delete the bullet point that states “Precast SAS show drawings for private developments are not required.”

BID ITEMS

REVISED ITEMS

21030 POLYMER STABILIZATION, SY (Modifying bid number only)

NEW ITEM

20712 NO STRATIFICATION NATIVE SEED MIX, SY

21052 INLET PROTECTION, RIGID FRAME, COMPLETE, EACH

DELETED ITEMS

20850 SOD DROUGHT WATERING

20851 SEED DROUGHT WATERING

DETAIL DRAWINGS

REVISED DETAIL

SDD 5.3.3 to also allow surface mounting of the railings if called out by the Engineer. ((Emailed Daniel))

NEW DETAIL

NONE

DELETED DETAILS

NONE