



Department of Planning & Community & Economic Development

Planning Division

Meagan Tuttle, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

March 13, 2025

Kevin Burow

Knothe & Bruce Architects

8401 Greenway Blvd, Ste 900

Middleton, WI 53562

RE: Legistar ID 86734 & 86991; Accela 'LNDUSE-2025-00006' -- Approval of zoning map amendment, demolition permits, and conditional uses at 922-926 North Fair Oaks Avenue

Dear Kevin Burow:

At its March 3 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your requests for demolition permits for two residential buildings at 922-926 North Fair Oaks Avenue. At its March 11 meeting, the Common Council, meeting in regular session, found the standards met and approved your request for a zoning map amendment changing the zoning of 922-926 North Fair Oaks Avenue from TR-C1 to CC-T (Commercial Corridor – Transitional district). In order to receive final approval of your requests, and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following one (1) item:

1. Section 28.185(9)(b) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9)(b) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission approval.

Please contact Brenda Stanley of the City Engineering Division at (608) 261-9127 if you have any questions regarding the following ten (10) items:

2. The area adjacent to this proposed development has been determined by City Engineering to have a known flooding risk. Engineering has set the minimum protective lowest entrance elevation opening at an elevation of 876.00. This standard is not intended to be protective in all cases. The Developer is strongly encouraged to complete their own engineering analysis to determine and meet a protective elevation which they are comfortable with. In no case shall the protective elevation be set below the minimum threshold determined by City Engineering.

3. The applicant shall connect to or extend public storm sewer connecting directly to a public storm structure that is either in the public sidewalk or terrace area, or inlet at the curb on the side of the street, adjacent to the development. Any storm lateral extension crossing any lanes of traffic or running longitudinally within a public street right of way for over 20ft, in order to connect to the public system, shall be considered a private storm sewer lateral and will require an approved and recorded privilege in streets agreement. (POLICY)
4. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
5. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
6. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
7. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
8. This site appears to disturb less than one (1) acre of land. No submittal to the WDNR, CARPC or Department of Safety and Professional Services (DSPS) is required as the City of Madison Building Inspection Department is an approved agent for DSPS.
9. Revise plan set to show more information on proposed drainage for the site. Use either spot elevations and drainage arrows or proposed contours to show the required drainage information. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement. (POLICY)
10. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.
Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html> Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
11. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10-year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

12. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Jeff Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following two (2) items:

13. Provide a final site plan representing the final site conditions showing any improvements or pavements to remain.
14. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following one (1) item:

15. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.

Please contact Matt Hamilton of the Fire Department at (608) 266-4457 if you have any questions regarding the following one (1) item:

16. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Ron Blumer at rblumer@cityofmadison.com or (608) 266 -4198.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:

17. Private wells may have served the parcels associated with this project prior to municipal water service connections. The existing properties will require an internal and external survey for potential unabandoned private wells prior to proceeding with demolition. Any remaining unused/unpermitted private wells existing on this parcel must be properly abandoned according to Wisconsin Administrative Code NR 812 and Madison General Ordinance 13.21 prior to the demolition of the property. Please contact water utility staff at (608) 2664654 to schedule an on-site private well survey prior to demolition, otherwise for additional information regarding well abandonment procedures and potential well abandonment reimbursement programs. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Please contact Trent Schultz of the Parking Utility at (608) 246-5806 if you have any questions regarding the following one (1) item:

18. The agency reviewed this request and has recommended no conditions of approval. A Transportation Demand Management (TDM) Plan may be required as part of future development, per MGO 16.03.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.


Please now follow the procedures listed below for obtaining your demolition permits and conditional use:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at SPRapplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after

consultation with the Alderperson of the District, approve an extension for up to one (1) year from the expiration date.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
Planner

cc: Jacob Moskowitz, Asst. Zoning Administrator
Brenda Stanley, City Engineering Division
Jeff Quamme, City Engineering Division – Mapping
Sean Malloy, Traffic Engineering Division
Matt Hamilton, Fire Department
Jeff Belshaw, Water Utility
Trent Schultz, Parking Utility
Bryan Johnson, Recycling Coordinator

I hereby acknowledge that I understand and will comply with the above conditions of approvals.

Signature of Applicant

Signature of Property Owner (if not the applicant)

LNDUSE-2025-00006			
For Official Use Only, Re: Final Plan Routing			
☐	Planning Div. (Punt)	☒	Engineering Mapping Sec.
☒	Zoning Administrator	☐	Parks Division
☒	City Engineering	☐	Urban Design Commission
☒	Traffic Engineering	☒	Recycling Coord. (R&R)
☒	Fire Department	☒	Water Utility
☐	Metro Transit	☐	Forestry
☒	Parking Utility	☐	