

Department of Planning & Community & Economic Development

### **Planning Division**

Heather Stouder, Director

Madison Municipal Building, Suite 017 215 Martin Luther King Jr. Boulevard Madison, Wisconsin 53703 Phone: (608) 266-4635 www.cityofmadison.com

\*\*BY E-MAIL ONLY\*\*

September 15, 2023

Aaron Williams University of Wisconsin-Madison 21 N Park Street, #6101 Madison, Wisconsin 53715-1211

RE: Consideration of a demolition permit to demolish two residential buildings at 209 Bernard Court and 911 Clymer Place; consideration of a demolition permit to demolish two-family residence at 923 Clymer Place; amending Section 28.022-00289 of the Madison General Ordinances to amend the Campus–Institutional (CI) District Master Plan for the University of Wisconsin-Madison Campus for the portion of the campus generally addressed as 232 N Park Street and 915-935 W Johnson Street, to include specific plans for the proposed Levy Hall Academic Building; consideration of a request to rezone 923 Clymer Place and 207 N Brooks Street from TR-U2 (Traditional Residential–Urban 2 District) to CI (Campus–Institutional District); and consideration of a request to rezone 209 Bernard Court, 911 Clymer Place, and 908 W Dayton Street from TR-U2 to CI.. (LNDUSE-2023-00039; ID 78199, 79460, 78874, 78912, and 78913)

### Dear Aaron;

On September 5, 2023, the Common Council **approved** your rezoning requests and the amendment to the Campus–Institutional (CI) District Master Plan for the University of Wisconsin-Madison Campus related to proposed Levy Hall. On August 28, 2023, the Plan Commission found the standards met and **approved** your demolition permit requests.

Prior to issuance of any City permits, etc. related to your project, the conditions of approval in the following sections shall be satisfied:

### Please contact Tim Troester of the City Engineering Division at (608) 267-1995 if you have any questions regarding the following eighteen (18) items:

1. The applicant shall connect to or extend public storm sewer connecting directly to a public storm structure that is either in the public sidewalk or terrace area, or inlet at the curb on the side of the street, adjacent to the development. Any storm lateral extension crossing any lanes of traffic or running longitudinally within a public street right of way for over 20 feet, in order to connect to the public system, shall be considered a private storm sewer lateral and will require an approved and recorded privilege in streets agreement.

- 2. Obtain a permit to excavate in the right of way for completing the improvements in the public right of way. The permit application is available on the City Engineering Division website. As a condition of the permit, a deposit to cover estimated City expenses will be required.
- 3. Construct sidewalk, terrace, curb and gutter, and pavement according to a plan as approved by City Engineer.
- 4. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to City Engineering Division sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder ((608) 261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff.
- 5. Obtain a Privilege In Streets Agreement for any encroachments inside the public right of way.
- 6. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development.
- 7. An Erosion Control Permit is required for this project.
- 8. A Storm Water Management Report and Storm Water Management Permit is required for this project.
- 9. A Storm Water Maintenance Agreement (SWMA) is required for this project.
- 10. This site appears to disturb over one (1) acre of land and requires a permit from the Wisconsin Department of Natural Resources (WDNR) for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR-216 and NR-151; however, a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue its permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at (608) 273-5612 of the WDNR to discuss this requirement. The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or the Capital Area Regional Planning Commission (CARPC) is required for this project to proceed.
- 11. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.
- 12. This project will disturb 20,000 square feet or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.
- 13. Demonstrate compliance with MGO Sections 37.07 and 37.08 regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.

- 14. This project will require a concrete management plan and a construction dewatering plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit.
- 15. This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering (608) 266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.
- 16. Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website as required by MGO Chapter 37.
- 17. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Storm Water Management Plan & Report shall include compliance with the following:

Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering.

By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10-year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first half-inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first half-inch of rainfall, either green or non-green infrastructure may be used.

Reduce TSS by 80% off of the proposed development when compared with the existing site.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any best management practices (BMP) used to meet stormwater management requirements on this project.

18. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

# Please contact Julius Smith of the City Engineering–Mapping Section at (608) 264-9276 if you have any questions regarding the following ten (10) items:

- 19. Sidewalk easements may be necessary along Clymer Place to accommodate turning and drop-off movements requested in prior meetings. Work with City Engineering and Traffic Engineering staff on street section on movement plan in Clymer and contact Engineering Mapping if easements for a moved section of public walk are needed.
- 20. The proposed new building crosses an underlying platted lot line. Prepare a Certified Survey Map (CSM) and for approval by the City to dissolve underlying lot lines to comply with fire codes, City ordinances and City policies. The CSM shall be approved by the City, recorded with the Dane County Register of Deeds, and new tax parcel information available prior to issuance of a building permit.
- 21. Grant a public sidewalk to the City on the face of the prior submitted CSM along W Johnson Street.
- 22. Release the six-foot wide Right-of-way Grant Underground Electric to Madison Gas and Electric per Document No. 2311525 for at least the portion the building will occupy.
- 23. The site plan indicates planters encroaching into the W Johnson Street right of way. The applicant shall confirm and note on the plans all encroachments, including, (but not limited to) balconies, roof overhangs and underground vaults. Make an application with City of Madison Office of Real Estate Services for a privilege in streets agreement. An approval of the development does not constitute or guarantee approval of any encroachments within a public right of way.
- 24. Coordinate and request from the utility companies serving this area the easements required to serve this development. Those easements shall be properly shown, dimensioned and labeled on the final plat.
- 25. The developer/contractor/owner responsible for permission easements and/or agreements necessary to accomplished work shown outside of parcel limits, on 213 and 219 N Brooks Street.
- 26. Identify on the plans the lot and block numbers of recorded Certified Survey Map or plat.
- 27. Provide a full and complete legal description of the site or properties being subjected to this application on the site plan.
- 28. On Sheet G005, under the text of Levy Hall, correct the spelling of 'University.'

# Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following fifteen (15) items:

- 29. The applicant shall work with the Traffic Engineering and City Engineering Divisions on the final configuration of Clymer Place. The applicant shall provide turning movement diagrams for Traffic Engineering approval showing operations on Clymer Place.
- 30. The applicant shall submit for review a waste removal plan, which shall include vehicular turning movements..

- 31. The applicant shall submit for review a Commercial Delivery Plan. This plan will include times, vehicle size, use of loading zones and all related turning movements.
- 32. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawing shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
- 33. The developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
- 34. The City Traffic Engineer may require public signing and marking related to the development; the developer shall be financially responsible for such signing and marking.
- 35. All parking facility design shall conform to the standards in MGO Section 10.08(6).
- 36. All bicycle parking adjacent pedestrian walkways shall have a two (2)-foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
- 37. The applicant shall not utilize public row to satisfy code requirement unless approved by the City Traffic Engineer
- 38. The applicant shall adhere to all vision triangle requirements as set in MGO Section 27.05 (no visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO Section 27.05(2)(bb), Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
- 39. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, ((608) 267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign-off.

- 40. Items in the right of way are not approvable through the site plan approval process. Make a note on all pages showing improvements in the right of way that states: The right of way is the sole jurisdiction of the City of Madison and is subject to change at any time per the recommendation/plan of Traffic Engineering and City Engineering Divisions.
- 41. The applicant shall provide a clearly defined five-foot walkway from the front door to the public right of way clear of all obstructions to assist citizens with disabilities, especially those who use a wheelchair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
- 42. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
- 43. Note: This site presents difficult constructability issues; access to neighboring sites must be maintained at all times, protected walkways will be constructed and maintained as soon as possible and little to no access to the public right of way on W Johnson Street will be granted for construction purposes. Provide a detailed construction plan to Traffic Engineering for review by the Traffic Control Specialist (Mike Duhr) prior to final signoff.

# Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following item:

44. Access to the public fire hydrant at the corner of Clymer Place and Bernard Court shall be maintained at all times.

# Please contact Jeff Belshaw of the Madison Water Utility at (608) 261-9835 if you have any questions regarding the following two (2) items:

- 45. A private well may have served this parcel prior to the municipal water service connection. Any remaining unused/unpermitted private wells existing on this parcel must be properly abandoned according to Wisconsin Administrative Code NR-812 and MGO Section 13.21 prior to the demolition of the property. Please contact Water Utility staff at (608) 266-4654 to schedule an on-site private well survey prior to demolition, otherwise for additional information regarding well abandonment procedures and potential well abandonment reimbursement programs. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.
- 46. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days' notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (http://www.cityofmadison.com/water/plumbers-contractors), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Avenue. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size and obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have

questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

# Please contact Bradley Hofmann of the City Forestry Section at (608) 267-4908 if you have any questions regarding the following ten (10) items:

- 47. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
- 48. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
- 49. City Forestry will issue a street tree removal permit for six trees: 2-inch oak and 2-inch elm within west side N Park Street terrace and 4-inch, 5-inch, and 5-inch crabapples, and 14-inch elm within center median of N Park Street tree due to underground utility installation. The contractor shall contact City Forestry at (608)266-4816 to obtain permit. Add as a note on both the demolition and landscape plan set.
- 50. The contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.
- 51. As defined by the Section 107.13 of *City of Madison Standard Specifications for Public Works Construction*: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing.
- 52. Section 107.13(g) of *City of Madison Standard Specifications for Public Works Construction* addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
- 53. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and,

extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.

- 54. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
- 55. Additional street trees are needed for this project. Tree planting specifications can be found in Section 209 of *City of Madison Standard Specifications for Public Works Construction*. All street tree planting locations and tree species within the right of way shall be determined by City Forestry. A landscape plan and street tree planting plan shall be submitted in PDF format to City Forestry for approval of planting locations within the right of way and tree species. All available street tree planting locations shall be planted within the project boundaries. Add following note on both the landscape and street tree plan sets: At least one week prior to street tree planting, Contractor shall contact City Forestry at (608) 266-4816 to schedule inspection and approval of nursery tree stock and review planting specifications with the landscaper.
- 56. No later than five business days prior to forming concrete and constructing tree grate sites, the contractor shall contact City Forestry at (608) 266-4816 to identify and locate underground conflicts (utilities, vaults, conduit) or other underground obstructions and determine grate locations. The contractor will be required to obtain the grate, matching frame and/or tree guard. Tree grate type and matching frame: Neenah 4x8 (R-8815-A). Tree guard Neenah (R-8501-4818). Add as a note on both the landscape and street tree plan set.

### Please contact my office at (608) 261-9632 if you have questions about the following item:

57. Submit PDFs of the relevant master plan pages for the Levy Hall project and additional CI-zoned parcels to Planning and Zoning staff for inclusion in the Campus–Institutional (CI) District Master Plan for the University of Wisconsin-Madison Campus, including data on the bulk and area of the proposed building not accounted for in the approved campus master plan.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

### Please now follow the procedures listed below for obtaining City permits related to your project:

- The applicant shall resubmit a PDF copy of the plan set and any other supporting materials that are necessary, as specified in this letter to <u>sprapplications@cityofmadison.com</u>. (Note: A 20MB email limit applies and multiple transmittals may be required.).
- 2. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.

3. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void two (2) years after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to one (1) year from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at (608) 261-9632 or <a href="mailto:tparks@cityofmadison.com">tparks@cityofmadison.com</a>.

Sincerely,

Timothy M. Parks

TimothyMParks

Planner

cc: Tim Troester, City Engineering Division
Julius Smith, City Engineering Division
Sean Malloy, Traffic Engineering Division
Jenny Kirchgatter, Asst. Zoning Administrator
Bill Sullivan, Madison Fire Department
Jeff Belshaw, Madison Water Utility
Bradley Hofmann, Forestry Section

LNDUSE-2023-00039			
For Official Use Only, Re: Final Plan Routing			
$\boxtimes$	Planning Div. (T. Parks)	$\boxtimes$	Engineering Mapping Sec.
$\boxtimes$	Zoning Administrator		Parks Division
$\boxtimes$	City Engineering		Urban Design Commission
$\boxtimes$	Traffic Engineering		Recycling Coordinator
$\boxtimes$	Fire Department	$\boxtimes$	Other: Forestry Section
$\boxtimes$	Water Utility		Other: