



Department of Planning & Community & Economic Development

Planning Division

Meagan Tuttle, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

January 13, 2026

Todd Buhr
JSD Professional Services, Inc.
507 W Verona Rd Ste 500
Verona, WI 53593

RE: LNDCSM-2025-00039; Legistar ID 90617 – Certified Survey Map – 33 W Johnson St

Dear Todd Buhr:

Your two-lot certified survey of property located at 33 West Johnson Street, Section 14, Township 07N, Range 09E, City of Madison, Dane County, Wisconsin, is hereby **conditionally approved**. The property is proposed to be zoned UMX (Urban Mixed Use district). The conditions of approval from the reviewing agencies to be satisfied prior to final approval and recording of the CSM are:

Please contact Gretchen Aviles Pineiro of the City Engineering Division at 608-266-4089 if you have questions regarding the following four (4) items:

1. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
2. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
3. A minimum of two (2) working days prior to requesting City Engineering signoff on the plat/csm contact either Tim Troester (West) at 261-1995 (tetroester@cityofmadison.com) or Brenda Stanley (East) at 608-261-9127 (bstanley@cityofmadison.com) to obtain the final stormwater utility charges that are due and payable prior to sub-division of the properties. The stormwater utility charges (as all utility charges) are due for the previous months of service and must be cleared prior to the land division (and subsequent obsolesces of the existing parcel). (POLICY)
4. The property is a closed Wisconsin Department of Natural Resources (WDNR) Bureau of Remediation and Redevelopment Tracking System (BRRTS) site (#02-13-590398 FORMER MADISON AREA TECHNICAL COLLEGE (MATC) and #02-13-001696 MADISON CTY - DAYTON ST RAMP). If contamination is encountered, follow all WDNR and Department of Safety and Professional Services (DSPS) regulations for proper handling and disposal.

Please contact Jeff Quamme of the City Engineering Division–Mapping Section at 608-266-4097 if you have questions regarding the following eleven (11) items:

5. For continuity, all labels and titles for the existing and new sidewalk easements shall be: Permanent Limited Easement (PLE) for Public Sidewalk to match CSM 14965. All labels and titles need to match.
6. The new sidewalk easement along W Dayton St shall only include the area not already granted as an easement. It shall not overlap existing easement areas.
7. There are two underground vaults subject to an existing Encroachment Agreement per Doc No 4897069. This agreement shall be amended or released and new agreements recorded due to the proposed land division and separation of the lands subject to this agreement. The document shall be recorded after the CSM has been recorded.
8. The plans for future development of Lot 1 proposes for the relocation of a subsurface electrical vault within the public right of way of W Johnson St to be sited on Lot 2. This vault is to provide electrical service for Lot 1. The Applicant shall coordinate and provide separate easement documents necessary for Madison Gas and Electric to serve Lot 2 for review prior to final sign off. The easement document(s) shall be recorded post CSM.
9. Wisconsin Administrative Code A-E 7.08 identifies when Public Land System (PLS) tie sheets must be filed with the Dane County Surveyor's office. The Developer's Surveyor and/or Applicant must submit copies of required tie sheets or monument condition reports (with current tie sheet attached) for all monuments, including center of sections of record, used in this survey, to Jeff Quamme, City Engineering (jrquamme@cityofmadison.com)
10. Prior to Engineering final sign-off by main office for Plats or Certified Survey Maps (CSM), the final Plat or CSM in pdf format must be submitted by email transmittal to Engineering Land Records Coordinator Jeff Quamme (jrquamme@cityofmadison.com) for final technical review and approval. This submittal must occur a minimum of two working days prior to final Engineering Division sign-off.
11. Conditions of approval noted herein are not intended to be construed as a review determining full compliance with City of Madison Ordinances and State of Wisconsin Statutes. The licensed professional preparing the land division is fully responsible for full compliance with all Ordinances and Statutes regulating this proposed land division.
12. Correct the orientation of all of the north arrows to be correct. Correct the block number to the southwest to Block 64.
13. The Owner's Certificate shall be revised to Owner's Certificate of Dedication an the word dedication added to the certification. There are new rights be granted to the City of Madison on the CSM and needs to be acknowledged. Also the notary shall be revised to reflect the true owner to execute the certificate.
14. This Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the

parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction or early start.

15. Submit to Jeff Quamme, prior to Engineering sign-off of the subject plat, one (1) digital CADD drawing in a format compatible with AutoCAD. The digital CADD file(s) shall be referenced to the Dane County Coordinate System and shall contain, at minimum, the list of items stated below, each on a separate layer/level name. The line work, preferably closed polylines for lot lines, shall be void of gaps and overlaps and match the final recorded plat:

- a) Right-of-Way lines (public and private)
- b) Lot lines
- c) Lot numbers
- d) Lot/Plat dimensions
- e) Street names
- f) Easement lines (i.e. all shown on the plat including wetland & floodplain boundaries.)

NOTE: This Transmittal is a separate requirement from the required Engineering Streets Section for design purposes. The Developer/Surveyor shall submit new updated final plat, electronic data for any changes subsequent to any submittal.

Please contact Sean Malloy of the Traffic Engineering Division at 608-266-5987 if you have questions regarding the following two (2) items:

16. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a minimum eight (8)-foot wide sidewalk, six (6)-foot terrace, and additional one (1) foot for maintenance, where applicable, along their site's frontage of W. Johnson Street.

17. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a minimum eight (8)-foot wide sidewalk, six (6)-foot terrace, and additional one (1) foot for maintenance, where applicable, along their site's frontage of W. Dayton Street.

Please contact Matt Hamilton of the Fire Department at 608-266-4457 if you have questions regarding the following one (1) item:

18. Document cross access easements between Lot 1 and Lot 2 for fire service access hose lays per fire access plan.

Please contact Emma Krug of the Parks Division at 608-263-6850 if you have questions regarding the following one (1) item:

19. The following note should be included on the CSM: "LOTS WITHIN THIS SUBDIVISION ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED."

Please contact Trent Milliken of the Office of Real Estate Services at 608-266-5940 if you have any questions regarding the following eleven (11) items:

20. Prior to approval sign-off by the Office of Real Estate Services ("ORES"), the Owner's Certificate(s) on the CSM shall be executed by all parties of interest having the legal authority to do so, pursuant to

Wis. Stats. 236.21(2)(a). Said parties shall provide documentation of legal signing authority to the notary or authentication attorney at the time of execution. The title of each certificate shall be consistent with the ownership interest(s) reported in the most recent title report.

If any of the land within the CSM boundary is under contract for sale or purchase, and said transfer will be conducted at the time of CSM recording, an escrow agreement may be necessary. Please discuss closing plans with ORES in advance of CSM signoff.

When possible, the executed original hard stock recordable CSM shall be presented at the time of ORES approval sign-off. If not, the City and the Register of Deeds are now accepting electronic signatures. A PDF of the CSM containing electronic signatures shall be provided to ORES to obtain approval sign-off.

21. Prior to CSM approval sign-off, an executed and notarized or authenticated certificate of consent for all mortgagees/vendors shall be included following the Owner's Certificate(s).
22. All ownership consents and certifications for the subject lands shall conform to Wis. Stats. 236.21(2) and 236.29 by including the language ...surveyed, divided, mapped and dedicated....
23. If any portion of the lands within the CSM boundary are subject to an Option to Purchase or other Option interest please include a Certificate of Consent for the option holder and have it executed prior to CSM sign-off, if said ownership interest meets the criteria set forth by Wis. Stat. Sec. 236.34 and Sec. 236.21(2)(a).
24. A Consent of Lessee certificate shall be included on the CSM for all tenant interests in excess of one year, recorded or unrecorded, and executed prior to CSM sign-off.
25. The lands within the CSM boundary are located within TID 50, a Tax Incremental Financing District. Discussions with Joe Gromacki, the City of Madison's tax increment financing coordinator, may be necessary before recording the CSM if a TIF application is required. Mr. Gromacki can be reached at 608-267-8724 or jgromacki@cityofmadison.com. If a TIF Loan has been authorized for the project, please inform ORES staff (Trent Milliken – tmilliken@cityofmadison.com).
26. As of 11/7/25, 2024 real estate taxes are paid in full for 0709-144-2399-5 and are not owed for 0709-144-2303-6 due to its exempt status.
27. As of 11/7/25, there are no special assessments reported. All known special assessments are due and payable prior to CSM approval sign-off. If special assessments are levied against the property during the review period and prior to CSM approval sign-off, they shall be paid in full pursuant to Madison General Ordinance Section 16.23(4)(f)(3).
28. Pursuant to Madison City Ordinance Section 16.23(4)(c)(1), the owner shall furnish an updated title report to ORES via email to Trent Milliken (tmilliken@cityofmadison.com), as well as the survey firm preparing the proposed CSM. The report shall search the period subsequent to the date of the initial title report (10/3/2025) submitted with the CSM application and include all associated documents that have been recorded since the initial title report.
A title commitment may be provided, but will be considered only as supplementary information to the title report update. Surveyor shall update the CSM with the most recent information reported in the title update. ORES reserves the right to impose additional conditions of approval in the event the title update contains changes that warrant revisions to the CSM.

29. "North" arrow currently pointing to actual NE – refer to CSM 14965.
30. If all parties of interest agree that certain easements from prior plats or CSM's of record are no longer necessary, the release documents for said easements shall be recorded prior to CSM approval sign-off, with the recording information for the release included as a Note on the proposed CSM.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

A resolution approving the CSM and authorizing the City to sign it and any other documents related to the proposed land division will be reviewed by the Common Council at its January 27, 2026 meeting.

Prior to City Engineering final sign-off by the main office of the CSM, the final CSM shall be submitted to the Engineering Division Surveyor/ Land Records Coordinator for final technical review and approval. This submittal must occur a minimum of two working days prior to final Engineering Division signoff. E-mail submittal of the final CSM in PDF form is preferred. Transmit to jrquamme@cityofmadison.com.

As soon as the comments and conditions have been satisfied, the original along with the revised Certified Survey Map, with all signatures and approvals from the reviewing agencies, shall be brought to this office for final signoff. You or your client may then record the certified survey at the Dane County Register of Deeds. For information on recording procedures and fees, contact the Register of Deeds at 266-4141.

Any appeal from this action, including the conditions of approval, must be filed with the Circuit Court within 30 days from the date of this letter. **The approval of this CSM shall be null and void if not recorded in twelve (12) months from the date of the approving resolution or this letter, whichever is later.**

If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
Planner

cc: Gretchen Aviles Pineiro, City Engineering Division
 Jeff Quamme, City Engineering Division–Mapping Section
 Sean Malloy, Traffic Engineering Division
 Matt Hamilton, Fire Department
 Emma Krug, Parks Division
 Trent Milliken, Office of Real Estate Services