

Firchow, Kevin

From: Sullivan, William
Sent: Thursday, October 23, 2014 7:58 AM
To: Firchow, Kevin
Cc: [REDACTED]
Subject: RE: Steensland Plans & Willy

Matt,

Here is Fire's comments.

Due to the relocation of the structure and the change of use to a 3-unit MGO 34.02, IBC 903.2.8, IBC 907.2.9, requires the installation of an automatic fire sprinkler and fire alarm system.

Bill

Bill Sullivan

Fire Protection Engineer
City of Madison Fire Department
30 W. Mifflin Street, 9th Floor
Madison, WI 53703
608.261.9658 (Phone)
wsullivan@cityofmadison.com
www.madisonfire.org



From: Firchow, Kevin
Sent: Wednesday, October 22, 2014 9:48 AM
To: Sullivan, William
Subject: FW: Steensland Plans & Willy

Bill –

Did you have a report for 312 Wisconsin?

From: Matthew Aro [mailto:[REDACTED]]
Sent: Wednesday, October 22, 2014 9:45 AM
To: Firchow, Kevin
Subject: RE: Steensland Plans & Willy

MFD send in their report yet?

From: Firchow, Kevin [mailto:KFirchow@cityofmadison.com]
Sent: Wednesday, October 22, 2014 9:44 AM