



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Agenda - Approved

BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

Tuesday, October 20, 2015

12:15 PM

215 Martin Luther King, Jr. Blvd.
Room 260 (Madison Municipal Building)

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below immediately.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese inmediatamente al número de teléfono que figura a continuación.

Yog tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntaub ntawv ua lwm yam los sis lwm cov kev pab kom siv tau qhov kev pab, kev ua num los sis kev pab cuam no, thov hu rau tus xov tooj hauv qab no tam sim no.

Building Inspections, (608) 266-4551

CALL TO ORDER / ROLL CALL

APPROVAL OF MINUTES

September 15, 2015: <http://madison.legistar.com/Calendar.aspx>

PUBLIC COMMENT

DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

PETITION FOR VARIANCE, AREA EXCEPTIONS OR APPEALS

1. [40456](#) 109 E. Lakeside Street (C-10-50-2015)

Charlie Ethridge of Glueck Architects appeals IBC 705.8. The rule requires that from 0 to 3 feet openings are not permitted. This is an existing building that is undergoing a change of use. There is a permanent utility easement along the wall in question so it cannot be built upon. The Madison Fire Department supports the variance.

ADJOURNMENT