



Department of Planning & Community & Economic Development

Planning Division

Katherine Cornwell, Director

Madison Municipal Building, Suite LL-100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
Fax (608) 267-8739
www.cityofmadison.com

June 15, 2015

Al Larson
Madison Water Utility
119 E. Olin Ave.
Madison, WI 53713

RE: Approval of a partial demolition to construct an addition to an existing building in the Traditional Employment (TE) District.

Dear Mr. Larson:

At its June 8, 2015 meeting, the Plan Commission found the standards met and **approved** your request for the demolition of a street facing facade of an existing building for construction of a new addition at 855 East Main Street, subject to the conditions below. In order to receive final approval of the demolition, and for any necessary permits to be issued for your project, the following conditions shall be met:

Please contact my office at 266-5974 if you have any questions regarding the following 2 items:

1. Final plans submitted for review and approval by staff shall meet any conditions recommended by the Urban Design Commission.
2. Final plans submitted for review and approval by staff shall include detailed specifications and a planting and maintenance plan for the 3,011 square foot green roof element.

Please contact Janet Schmidt of the City Engineering Division at 261-9688 if you have questions regarding the following 18 items:

3. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD) prior to issuance of any building permits for new construction. When the recorded CSM image is available from the ROD, the Assessor's Office can then create the new Address-Parcel-Owner (APO) data in GEO so that the Accela system can upload this data and permit issuance made available for this new land record.
4. The site plan shall include the boundary and dimensions of the Lot per the pending Certified Survey Map application.
5. The new addition appears to overlap an MG&E Easement per Doc No. 2058635. Coordination with MG&E in regard to the easement and possible release is recommended.
6. Water Utility uses 110 S Paterson St. 855 E Main St has been inactivated.
7. The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass. (POLICY).

8. The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development (POLICY).
9. All damage to the pavement on S. Paterson and E. Main Street, adjacent to this development shall be restored in accordance with the City of Madison's Pavement Patching Criteria. For additional information please see the following link:
<http://www.cityofmadison.com/engineering/patchingCriteria.cfm> (POLICY)
10. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in the ROCK RIVER TMDL ZONE and by Resolution 14-00043 passed by the City of Madison Common Council on 1/21/2014. You will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR.
11. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.
12. The site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process.

Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm> (NOTIFICATION)
13. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - a) Reduce TSS by 80% (control the 5 micron particle) off of newly developed areas compared to no controls
 - b) Provide oil & grease control from the first 1/2" of runoff from parking areas.
 - c) Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by MGO Chapter 37.

Stormwater management plans shall be submitted and approved by City Engineering prior to signoff.

14. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set (POLICY and MGO 37.09(2)).

PDF submittals shall contain the following information:

- a) Building footprints
 - b) Internal walkway areas
 - c) Internal site parking areas
 - d) Lot lines and right-of-way lines
 - e) Street names
 - f) Stormwater Management Facilities
 - g) Detail drawings associated with Stormwater Mgmt Facilities (including if applicable planting plans.
15. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files, including:
 - a) SLAMM DAT files
 - b) RECARGA files
 - c) TR-55/HYDROCAD/Etc
 - d) Sediment loading calculations

If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided (POLICY and MGO 37.09(2))

16. This project appears to require construction dewatering and/or possibly permanent dewatering and is in an area with potential groundwater contamination. The applicant shall be required obtain the approval of Public Health – Madison & Dane County for this discharge. It can be anticipated that this will required completion of a boring on site and testing of water encountered for possible contaminates. Approval shall be granted before plans are approved for building permit release.

Contact Kirsti Sorsa for more information at 608-243-0356 or ksorsa@publichealthmdc.com.

17. This project appears to require construction dewatering. A dewatering plan shall be submitted to City Engineering as part of the Erosion Control Permit.
18. The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction (MGO 37.05(7)).

This permit application is available on line at

<http://www.cityofmadison.com/engineering/permits.cfm>

19. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. NOTE: As of January 1, 2013 new plugging procedures and permit fees go into effect. The new procedures and revised fee schedule is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14)).

20. All outstanding Madison Metropolitan Sewerage District (MMSD) are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Schmidt (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4)).

Please contact Kay Rutledge of the Parks Division at 266-4714 if you have any questions about the following 4 items:

21. Forestry will approve of the two ash removals (under high voltage power lines) on S Paterson St. Contractor shall contact City Forestry at least one week prior to removal to obtain a tree removal permit.
22. The proposed planting plan will need to be revised. Please submit a site plan (in PDF format) to Dean Kahl – dkahl@cityofmadison.com or 266-4816. Approval and permitting of tree planting shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan. Tree planting specifications can be found in section 209 of *City of Madison Standard Specifications for Public Works Construction* - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part2.pdf>.
23. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266-4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry. Tree protection specifications can be found in section 107.13 of *City of Madison Standard Specifications for Public Works Construction* - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part1.pdf>.
24. Please reference ID# 15127 when contacting Parks about this project.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions about the following item:

25. Madison Fire Department recommends the installation of a residential fire sprinkler system in accordance with NFPA 13D and SPS 382.30(3)(e). Additional information is available at the Home Fire Sprinkler Coalition website: <http://www.homefiresprinkler.org/Consumer/ConsHome.html>

Please contact Dennis Cawley of the Water Utility at 266-4651 if you have any questions about the following item:

26. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.

Please contact Matt Tucker, Zoning Administrator at 266-4569 if you have any questions about the following 3 items:

27. Provide a reuse/recycling plan, to be reviewed and approved by The City's Recycling Coordinator, Mr. George Dreckmann, prior to a demolition permit being issued.
28. Sec. 28.12(12)(e) of the Madison Zoning Ordinance requires the submittal of documentation demonstrating compliance with the approved reuse and recycling plan. Please note, the owner must submit documentation of recycling and reuse within 60 days of completion of demolition.
29. Sec. 28.185(9)(a). A demolition or removal permit is valid for one (1) year from the date of the Plan Commission

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency. No building permits shall be issued until the applicant has met all of the conditions of approval stated in this letter.

Please now follow the procedures listed below for obtaining your permits:

1. Please revise the plans per the above conditions and file **nine (9)** sets of complete, fully dimensioned, and to-scale plans, along with the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code. Also provide any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval.
3. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the issuance of said building permit.

If you have any questions regarding obtaining the demolition permit, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 266-5974.

Sincerely,

Heather Stouder, AICP
Planner

cc: Janet Schmidt, City Engineering Division
Jeff Quamme, City Engineering Division
Matt Tucker, Zoning Administrator
Bill Sullivan, Fire Department
Kay Rutledge, Parks Division
Al Martin, Urban Design
George Dreckmann, Streets Division

I hereby acknowledge that I understand and will comply with the above conditions of approval for this demolition permit.

Signature of Applicant

Signature of Property Owner (if not Applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (H. Stouder)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Metro Transit