

**PLANNING DIVISION REPORT
DEPARTMENT OF PLANNING AND COMMUNITY
AND ECONOMIC DEVELOPMENT
of July 18, 2007**

RE: LD. # 07046, Demolition Permit – 2110 N. Sherman Avenue

1. Requested Action: Approval of a demolition permit to allow an existing one-story restaurant located at 2110 N. Sherman Avenue to be razed and a new two-story office building to be constructed.
2. Applicable Regulations: Section 28.04 (22) provides the guidelines and regulations for the approval of demolition permits.
3. Report Prepared By: Timothy M. Parks, Planner

GENERAL INFORMATION

1. Applicant & Property Owner: Dan Martinson, Martinson Real Estate; 2110 N. Sherman Avenue; Madison.

Agent: Roger Smith, Design Coalition Architects; 2088 Atwood Avenue; Madison.
2. Development Schedule: The applicant wishes to begin construction in spring 2008, with completion anticipated that fall.
3. Location: Approximately 0.33-acres generally located on the west side of N. Sherman Avenue between Winchester and Vahlen streets; Aldermanic District 12; Madison Metropolitan School District.
4. Existing Conditions: A one-story, approximately 1,600 square-foot former fast food restaurant, which was converted into the applicant's real estate office, zoned C1 (Limited Commercial District).
5. Proposed Land Use: A two-story, 5,790 square-foot office building.
6. Surrounding Land Use and Zoning:
North: Hair salon and barbershop, zoned C1 (Limited Commercial District); St. Paul's Lutheran Church, zoned R1 (Single-Family Residence District);
South: Brentwood Terrace Apartments, zoned R5 (General Residence District);
East: Insurance offices, two-family dwelling, zoned C1;
West: Single-family residences, zoned R1.

7. Adopted Land Use Plan: The Comprehensive Plan identifies the subject site and the other nearby properties in C1 zoning for "neighborhood mixed-use" development. The other properties in the area are recommended for low-density residential uses. The site is also located within the boundaries of the Brentwood Village-Packers-Sherman Neighborhood Plan, though staff could not identify any specific land use recommendations in that plan that relate to this property.
8. Environmental Corridor Status: The subject site is not located in a mapped environmental corridor.
9. Public Utilities & Services: The property is served by a full range of urban services.

STANDARDS FOR REVIEW

This application is subject to the demolition standards of Section 28.04 (22).

ANALYSIS, EVALUATION & CONCLUSION

The applicant wishes to demolish an existing former Dairy Queen restaurant located at 2110 N. Sherman Avenue in C1 commercial zoning, which the applicant previously converted into a real estate office. The one-story building contains approximately 1,600 square feet of space and is located near the center of the 0.33-acre site, which is nearly entirely hard-surfaced and includes two driveways onto N. Sherman Avenue. Eleven parking stalls are located onsite, with nine of the spaces located between the building and N. Sherman Avenue. The site is located along a low-density, mixed commercial-residential section of N. Sherman Avenue, with a hair salon/barbershop and church to the north, two one-story office buildings to the east and a 22-unit apartment to the south. Single-family residences border the subject site to the west.

The applicant wishes to construct a two-story, 5,790 square-foot office building to replace the existing converted structure. The new building will include up to four tenant spaces, with access to of the interior spaces through a single public entrance to be located at the northeastern corner of the building. The new building will be set back 30 feet from the western property line adjacent to the R1-zoned single-family residences to the west. The proposed rear yard setback conforms to the Zoning Ordinance requirement for rear yards in C1, which calls for a 30-foot rear yard for a two-story building. The plans show a secondary building entrance to the rear yard, where a patio will be provided for tenants. Parking for the new building will be provided in 14 stalls located between the building and the street, with access to the site to be provided by the northern of the two existing driveways. The southern driveway will be removed. Two additional parking spaces will be provided between the northern wall of the new building and northern property line in front of a 480 square-foot detached storage building that will also be constructed. The Zoning Administrator has determined that 19 parking stalls are required to serve this development. The

applicant has submitted a request to the Zoning Administrator to administratively reduce the required off-street parking for this development as allowed in the Zoning Ordinance. An existing line of mature shrubs located along the western property line will remain to screen the rear of the new building from the single-family residences to the west.

The building will be an angular, modern-styled structure that will stand approximately 25 feet in height and be faced with either fiber cement siding or EIFS. The one-story storage building in the northwestern corner of the site will be constructed to match the exterior of the main building. Visual interest will be added to the new building through the addition of an overhang that will extend most of the length of the first floor along the eastern, front elevation and wrap around to the southern wall and a 1.5-story conference room area located along the front wall that acts to vary the roofline. Overall, staff believes that the new building is generally well designed, but encourages the applicant to strongly consider using the more durable fiber cement siding versus the less durable EIFS, especially given the size of the exterior application. If EIFS is to be used for the entire exterior of the building, staff encourages the applicant to consider using a masonry wainscot to keep the EIFS material above ground level and away from groundwater, which will also have the secondary effect of enhancing the exterior appearance of the structure.

The applicant has provided a small selection of pictures of the interior and exterior of the building to be demolished and staff has conducted a windshield survey of the site. The existing 1,600 square-foot building appears to be in average condition for a building of its age, and staff has no information that would indicate that the building is not structurally sound or capable of being rehabilitated or repaired. However, staff believes that the proposed redevelopment of the property allows this site to continue to be economically productive for the foreseeable future and should substantially comply with the demolition standards. The new two-story building is well designed, stands as a greater utilization of the site than the previous one-story restaurant/ small office building, and represents a needed investment in this portion of the N. Sherman Avenue corridor. The proposed development will also reduce the amount of impervious surface present on the property through the inclusion of the required yards for the office building and storage building. It is also unlikely that the proposed development proposal would be financially feasible if the existing building remained and was expanded to provide the same amount of gross floor area proposed with the new building.

RECOMMENDATION

The Planning Division recommends that the Plan Commission find the demolition standards are met and **approve** the demolition of an existing 1,600 square-foot office building to allow a new two-story, 5,790 square-foot office building to be built at 2110 N. Sherman Avenue, subject to input at the public hearing and the following conditions:

1. Comments from reviewing agencies.

ID #07046

2118 N. Sherman Ave.

July 18, 2007

Page 4

2. That the applicant submit a revised landscaping plan per Planning Division approval that:
 - a.) provides the approximate width and height and species of the 18 shrubs located along the western property line, and;
 - b.) provides landscaping (including size and species) to be planted along the southern and eastern property lines to screen the parking lot from the residential property to the south and N. Sherman Avenue.



**Department of Public Works
City Engineering Division**

608 266 4751

Larry D. Nelson, P.E.
City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
608 264 9275 FAX
1 866 704 2315 Textnet

Deputy City Engineer
Robert F. Phillips, P.E.

Principal Engineers
Michael R. Dalley, P.E.
Christina M. Bachmann, P.E.
John S. Fahrney, P.E.
Gregory T. Fries, P.E.

Facilities & Sustainability
Jeanne E. Hoffman, Manager
James C. Whitney, A.I.A.

Operations Supervisor
Kathleen M. Cryan

Hydrogeologist
Joseph L. DeMorett, P.G.

GIS Manager
David A. Davis, R.L.S.

DATE: July 10, 2007
TO: Plan Commission
FROM: Larry D. Nelson, P.E., City Engineer
SUBJECT: 2110 North Sherman Avenue Demolition

The City Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

- | |
|---|
| <p>1. Submit final floor and unit plans for proposed two-story office to City Engineering, Lori Zenchenko lzenchenko@cityofmadison.com or 266-5952 to coordinate an address plan.</p> |
|---|

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

Engineering Division Review of Planned Community Developments, Planned Unit Developments and Conditional Use Applications.

Name: 2110 North Sherman Avenue Demolition

General

- 1.1 The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
- 1.2 The site plan shall identify lot and block numbers of recorded Certified Survey Map or Plat.
- 1.3 The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing and proposed utility locations and landscaping.
- 1.4 The site plan shall identify the difference between existing and proposed impervious areas.
- 1.5 The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
- 1.6 Coordinate all necessary new interior addresses associated with this proposed development with City Engineering Program Specialist Lori Zenchenko lzenchenko@cityofmadison.com or (608) 266-5952

15



- 1.7 The site plan shall include a full and complete legal description of the site or property being subjected to this application.

Right of Way / Easements

- 2.1 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.2 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.3 The Applicant shall Dedicate a Permanent Limited Easement for grading and sloping _____ feet wide along _____.
- 2.4 The City Engineer has reviewed the need for pedestrian and bicycle connections through the development and finds that no connections are required.
- 2.5 The Applicant shall Dedicate a Permanent Limited Easement for a pedestrian / bicycle easement _____ feet wide from _____ to _____.
- 2.6 The Developer shall provide a private easement for public pedestrian and bicycle use through the property running from _____ to _____.
- 2.7 The developer shall be responsible for the ongoing construction and maintenance of a path within the easement. The maintenance responsibilities shall include, but not be limited to, paving, repaving, repairing, marking and plowing. The developer shall work with the City of Madison Real Estate Staff to administer this easement. Applicable fees shall apply.
- 2.8 The Public Sanitary Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
- a. The property owner reserves the right to use and occupy the Public Sanitary Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sanitary sewer facilities.
 - b. No above-ground improvements shall be located in the Public Sanitary Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public sanitary sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
 - c. Plantings and landscaping within the Public Sanitary Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
 - d. The property owner shall not change the grade of the Public Sanitary Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.
 - e. The Public Sanitary Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.
- 2.9 The Public Sidewalk Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
- a. The property owner reserves the right to use and occupy the Public Sidewalk Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sidewalk improvements.
 - b. No above-ground improvements will be allowed in the Public Sidewalk Easement Area(s) by the property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
 - c. Plantings and landscaping within the Public Sidewalk Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
 - d. The property owner shall not change the grade of the Public Sidewalk Easement Area(s) without the prior written approval of the City's Engineering Division.
 - e. The Public Sidewalk Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.
- 2.10 The Public Storm Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
- a. The property owner reserves the right to use and occupy the Public Storm Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public storm sewer facilities.
 - b. No above-ground improvements shall be located in the Public Storm Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public storm sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
 - c. Plantings and landscaping within the Public Storm Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be

- removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Storm Sewer Easement Area(s) without the prior written approval of the City's Engineering Division. The Public Storm Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

- 2.11 The Public Water Main Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
- a. The property owner reserves the right to use and occupy the Public Water Main Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public water main facilities.
- b. No above-ground improvements will be allowed in the Public Water Main Easement Area(s) by the property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
- c. Plantings and landscaping within the Public Water Main Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Water Main Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Water Main Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

Streets and Sidewalks

- 3.1 The Applicant shall execute a waiver of notice and hearing on the assessments for the improvement of [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.2 **Value of sidewalk installation over \$5000.** The Applicant shall Construct Sidewalk to a plan approved by the City Engineer along _____.
- 3.3 **Value of sidewalk installation under \$5000.** The Applicant shall install public sidewalk along _____. The Applicant shall obtain a Street Excavation Permit for the sidewalk work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. All work must be completed within six months or the succeeding June 1, whichever is later. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.4 The Applicant shall execute a waiver of their right to notice and hearings on the assessments for the installation of sidewalk along [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.5 The Applicant shall grade the property line along ____ to a grade established by the City Engineer. The grading shall be suitable to allow the installation of sidewalk in the future without the need to grade beyond the property line. The Applicant shall obtain a Street Excavation permit prior to the City Engineer signing off on this development. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.6 The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
- 3.7 **Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation.** The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 3.8 The Applicant shall make improvements to _____ in order to facilitate ingress and egress to the development. The improvement shall include a (Describe what the work involves or strike this part of the comment.) _____
- 3.9 The Applicant shall make improvements to _____. The improvements shall consist of _____.
- 3.10 The approval of this Conditional Use does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
- 3.11 The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City

Engineer shall approve the grade of the entrances prior to signing off on this development.

- 3.12 The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
- 3.13 The Applicant shall obtain a privilege in streets agreement for any encroachments inside the public right of way. The approval of this development does not constitute or guarantee approval of the encroachments.
- 3.14 The Applicant shall provide the City Engineer with the proposed soil retention system to accommodate the restoration. The soil retention system must be stamped by a Professional Engineer. The City Engineer may reject or require modifications to the retention system.
- 3.15 The Applicant shall complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate shall be approved by the City. The Construction Engineer shall be notified prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced.
- 3.16 All work in the public right-of-way shall be performed by a City licensed contractor.
- 3.17 Installation of "Private" street signage in accordance with 10.34 MGO is required.

Storm Water Management

- 4.1 The site plans shall be revised to show the location of all rain gutter down spout discharges.
- 4.2 Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public storm sewer.
- 4.3 The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
- 4.4 The applicant shall show storm water "overflow" paths that will safely route runoff when the storm sewer is at capacity.
- 4.5 The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
- 4.6 The City of Madison is an approved agent of the Department of Commerce. This proposal contains a commercial building and as such, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
- 4.7 This development includes multiple building permits within a single lot. The City Engineer and/or the Director of the Inspection Unit may require individual control plans and measures for each building.
- 4.8 If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds.
- 4.9 Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - Detain the 2 & 10-year storm events.
 - Detain the 2, 10, & 100-year storm events.
 - Control 40% TSS (20 micron particle).
 - Control 80% TSS (5 micron particle).
 - Provide infiltration in accordance with NR-151.
 - Provide substantial thermal control.
 - Provide oil & grease control from the first 1/2" of runoff from parking areas.

Stormwater management plans shall be submitted and approved by City Engineering prior to signoff.

- 4.10 The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
- 4.11 A portion of this project comes under the jurisdiction of the US Army Corp of Engineers and WDNR for wetland or flood plain issues. A permit for those matters shall be required prior to construction on any of the lots currently within the jurisdictional flood plain.

15

- 4.12 The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain the following data, each on a separate layer name/level number:
- a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) Lot lines
 - g) Lot numbers
 - h) Lot/Plat dimensions
 - i) Street names

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com . Include the site address in this transmittal.

- 4.13 NR-151 of the Wisconsin Administrative Code will be effective on October 1, 2004. Future phases of this project shall comply with NR 151 in effect when work commences. Specifically, any phases not covered by a Notice of Intent (NOI) received from the WDNR under NR-216 prior to October 1, 2004 shall be responsible for compliance with all requirements of NR-151 Subchapter III. As most of the requirements of NR-151 are currently implemented in Chapter 37 of the Madison General Ordinances, the most significant additional requirement shall be that of infiltration.

NR-151 requires infiltration in accord with the following criteria. For the type of development, the site shall comply with one of the three (3) options provided below:

Residential developments shall infiltrate 90% of the predevelopment infiltration amount, 25% of the runoff from the 2-year post development storm or dedicated a maximum of 1% of the site area to active infiltration practices.

Commercial development shall infiltrate 60% of the predevelopment infiltration amount, 10% of the runoff from the 2-year post development storm or dedicate a maximum of 2% of the site area to active infiltration practices.

- 4.14 The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set.

PDF submittals shall contain the following information:

- a) Building footprints.
- b) Internal walkway areas.
- c) Internal site parking areas.
- d) Lot lines and right-of-way lines.
- e) Street names.
- f) Stormwater Management Facilities.
- g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

- 4.15 The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:

- a) SLAMM DAT files.
- b) RECARGA files.
- c) TR-55/HYDROCAD/Etc...
- d) Sediment loading calculations

If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.

- 4.16 The area adjacent to this proposed development has a known flooding risk. All entrances shall be 2-feet above the adjacent sidewalk elevation or 1-foot above the 100-year regional flood elevation (whichever is greater). This includes garage entrances.

Utilities General

- 5.1 The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.2 The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 5.3 All proposed and existing utilities including gas, electric, phone, steam, chilled water, etc shall be shown on the plan.
- 5.4 The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the

storm sewer construction. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

- 5.5 The site plans shall be revised to show the location of existing utilities, including depth, type, and size in the adjacent right-of-way.
- 5.6 The developer shall provide information on how the Department of Commerce's requirements regarding treatment of storm water runoff, from parking structures, shall be satisfied prior to discharge to the public sewer system. Additionally, information shall be provided on which system (storm or sanitary) the pipe shall be connected to.

Sanitary Sewer

- 6.1 Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
- 6.2 All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Dailey (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff.
- 6.3 Each unit of a duplex building shall be served by a separate and independent sanitary sewer lateral.
- 6.4 The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

July 12, 2007

TO: Plan Commission
FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager
SUBJECT: **2110 North Sherman Avenue –Demolition– 2 Story Office Building**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Roger Smith
Fax: 608-246-8670
Email: roger@designcoalition.org

DCD: DJM: dm

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: June 30, 2007

To: Plan Commission
From: Kathy Voeck, Assistant Zoning Administrator
Subject: 2110 N. Sherman Avenue

Present Zoning District: C-1

Proposed Use: Demolish former restaurant to allow new 2 story office building

Conditional Use: 28.04(22) Demolition of a principal building requires Plan Commission approval.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.**

GENERAL OR STANDARD REVIEW COMMENTS

1. Provide a physical barrier at the property lines adjacent to neighbors where pavement is to the property line.
2. Provide effective 6' – 8' high screening along the lot lines of this commercial district adjoining a residential zoning district. (Rear and left side)
3. Provide a 20' rear yard setback for the 1 story storage building.
4. Meet applicable State building and State setback requirements. Contact the building permit staff regarding these requirements. (distance between buildings and to property lines, etc.)
5. Note: An office building under 10,000 sq. ft. requires no loading area. Retail between 5,000 sq. ft. and 10,000 sq. ft. requires 1 (10' x 35') area exclusive of drive aisles and maneuvering space.
6. Provide a detailed landscape plan. Show species and sizes of landscape elements. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) Contact zoning staff regarding landscaping/screening requirements.

7. Lighting is not required. However, if it is provided, it must comply with City of Madison outdoor lighting standards. (See parking lot packet). Lighting will be limited to .08 watts per square foot for office use.
8. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 of the Madison General Ordinances. Permits must be issued by the Zoning Section of the Department of Planning and Development

ZONING CRITERIA

| Bulk Requirements | Required | Proposed |
|--------------------------|---|-------------------|
| Lot Area | 6,000 sq. ft. | 14,459 sq. ft. |
| Lot width | 50' | 100' |
| Usable open space | n/a | n/a |
| Front yard | 20' for 50' adj. to res. (0' rest) | 64' |
| Side yards | 6' left, 0' right | 8' left, 3' right |
| Rear yard | 30' 2 story building 20' 1 story storage bldg. | adequate (3) |
| Floor area ratio | n/a | n/a |
| Building height | 3 stories/40' | 2 stories |

| Site Design | Required | Proposed |
|----------------------------|-----------------|-----------------------------|
| Number parking stalls | 19 | 16 (Parking reduction app.) |
| Accessible stalls | 1 | provided |
| Loading | n/a office use | (5) |
| Number bike parking stalls | 2 | 5 provided |
| Landscaping | Yes | (6) |
| Lighting | No | (7) |

| Other Critical Zoning Items | |
|------------------------------------|-----|
| Flood plain | No |
| Barrier free (ILHR 69) | Yes |

With the above conditions, the proposed project **does** comply with all of the above requirements.



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: July 11, 2007
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **2110 N. Sherman Ave.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. As required by MGO 10.34 and IFC 505.1, all residential and commercial buildings must have the approved address posted. The address numbers shall be 4 inches in height, numbers shall be in contrast to the background and visible from the street.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan